

John S. Keenan Vice President Brunswick Nuclear Plant Progress Energy Carolinas, Inc.

JUL 0 2 2003

**SERIAL: BSEP 03-0106** TSC-2002-09

U.S. Nuclear Regulatory Commission **ATTN: Document Control Desk** Washington, DC 20555-0001

- Brunswick Steam Electric Plant, Unit Nos. 1 and 2 Subject: Docket Nos. 50-325 and 50-324/License Nos. DPR-71 and DPR-62 **Response to Request for Additional Information Core Flow Operating Range Expansion** (NRC TAC No. MB6692 and MB6693)
- Reference: Letter from Mr. John S. Keenan to the U.S. Nuclear Regulatory Commission (Serial: BSEP 02-0169), "Request for License Amendments -Core Flow Operating Range Expansion," dated November 12, 2002

Ladies and Gentlemen:

On November 12, 2002, Progress Energy Carolinas, Inc. requested a revision to the Technical Specifications (TSs) for the Brunswick Steam Electric Plant (BSEP), Units 1 and 2. The proposed license amendments revise TSs, as necessary, to support an expansion of the core flow operating range (i.e., Maximum Extended Load Line Limit Analysis Plus (MELLLA+)).

On June 3, 2003, the NRC provided a verbal request for additional information (RAI) concerning the single recirculation loop operation setpoint for the Average Power Range Monitor Simulated Thermal Power - High scram function. The response to this RAI is enclosed.

Please refer any questions regarding this submittal to Mr. Edward T. O'Neil, Manager - Support Services, at (910) 457-3512.

Sincerely,

John S. Keenan

P.O. Box 10429 Southport, NC 28461

T> 910.457.2496 F> 910.457.2803 Document Control Desk BSEP 03-0106 / Page 2

MAT/mat

÷

Enclosure:

Response to Request for Additional Information (RAI) 3

John S. Keenan, having been first duly sworn, did depose and say that the information contained herein is true and correct to the best of his information, knowledge and belief; and the sources of his information are officers, employees, and agents of Carolina Power & Light Company.

Notary (Seal)

My commission expires: August 29,2004

cc:

U. S. Nuclear Regulatory Commission, Region II ATTN: Mr. Luis A. Reyes, Regional Administrator Sam Nunn Atlanta Federal Center 61 Forsyth Street, SW, Suite 23T85 Atlanta, GA 30303-8931

U. S. Nuclear Regulatory Commission ATTN: NRC Resident Inspector 8470 River Road Southport, NC 28461-8869

U. S. Nuclear Regulatory Commission (Electronic Copy Only) ATTN: Ms. Brenda L. Mozafari (Mail Stop OWFN 8G9) 11555 Rockville Pike Rockville, MD 20852-2738

Ms. Jo A. Sanford Chair - North Carolina Utilities Commission P.O. Box 29510 Raleigh, NC 27626-0510

Ms. Beverly O. Hall, Section Chief Radiation Protection Section, Division of Radiation Protection North Carolina Department of Environment and Natural Resources 3825 Barrett Drive Raleigh, NC 27609-7221

## Response to Request for Additional Information (RAI) 3

## **Background**

On November 12, 2002, Progress Energy Carolinas, Inc. requested a revision to the Technical Specifications (TSs) for the Brunswick Steam Electric Plant (BSEP), Units 1 and 2. The proposed license amendments revise TSs, as necessary, to support an expansion of the core flow operating range (i.e., Maximum Extended Load Line Limit Analysis Plus (MELLLA+)).

On June 3, 2003, the NRC provided a verbal request for additional information (RAI) concerning the single recirculation loop operation setpoint for the Average Power Range Monitor Simulated Thermal Power - High scram function. The response to this RAI follows.

## NRC Question 3-1

In support of the licensee's MELLLA+ upgrade, the licensee referenced GE Nuclear Energy Report NEDC-33063P, "Safety Analysis Report for Brunswick Steam Electric Plant Units 1 and 2 Maximum Extended Load Line Limit Analysis Plus," dated November 2002 (M+SAR). Section 5.3.1, "APRM Flow-biased Scram," stated, "MELLLA+ does not apply to single loop operation (SLO). Therefore, no SLO flow-biased expressions are provided." The licensee's proposed allowable value (AV) for TS Table 3.3.1.1-1, Function 2.b, Average Power Range Monitor Simulated Thermal Power - High (STP-Hi), is given by the equation

 $\leq$  0.61W + 65.2% RTP and  $\leq$  117.1% RTP

Note (b) states,

 $\leq$  [0.61 (W -  $\Delta$ W) + 65.2% RTP] when reset for single loop operation per LCO 3.4.1, "Recirculation Loops Operating." The Value of  $\Delta$ W is defined in plant procedures.

Provide the basis for incorporating a MELLLA+ SLO flow-biased function in the TS that is not supported by the MELLLA+ licensing topical report (M+LTR) referenced in the licensee's submittal.

## Response to NRC Question 3-1

As stated in Sections 1.2.4 and 5.3.1, Single Loop Operation (SLO) is prohibited when operating in the MELLLA+ region. This is reflected in the proposed change to Limiting Condition for Operation 3.4.1, "Recirculation Loops Operating," which states, in part:

One recirculation loop may be in operation provided the plant is not operating in the MELLLA+ region defined in the COLR...

BSEP 03-0106 Enclosure Page 2 of 2

The proposed change to the Allowable Value (AV) for Function 2.b of Table 3.3.1.1-1 does not alter the proposed change to LCO 3.4.1, rather it is a result of the existing design associated with the BSEP flow-biased scram function. Specifically, the BSEP flow-biased scram function has a fixed flow-biased slope. The proposed change to MELLLA flow-biased scram for SLO allows use of the same flow-biased slope as for the two loop operation scram for MELLLA+. The affect of the proposed change is to apply a more conservative setpoint for SLO than the previous MELLLA setpoint.

-