

Dominion Nuclear Connecticut, Inc.
Millstone Power Station
Rope Ferry Road
Waterford, CT 06385



Dominion™

JUL - 1 2003

Docket No. 50-336
B18931

RE: 10 CFR 50.90

U.S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, DC 20555

Millstone Power Station, Unit No. 2
Regulatory Commitment Related to
License Basis Document Change Request 2-1-02 (TAC No. MB5008)

In a letter dated May 7, 2002, Dominion Nuclear Connecticut, Inc. (DNC) proposed changes to the Millstone Unit No. 2 (MP2) Technical Specifications which included changes to the control room isolation actuation function.⁽¹⁾ During Nuclear Regulatory Commission (NRC) review of that application, a question arose as to the level of redundancy for the function. DNC subsequently concluded that a second channel had been added in response to a Three Mile Island action item (TMI ACTION ITEM II.D.3.4), however, reference to the second channel had not previously been incorporated into the MP2 Technical Specifications.

Upon discovery, DNC generated a Condition Report and established administrative controls to ensure both channels are appropriately maintained until a new license amendment request is submitted. This matter was discussed with the NRC staff and it was agreed that DNC would docket a commitment in this regard.

To that end, DNC hereby commits to submit a license amendment request to reflect two channels of control room isolation actuation instrumentation.

⁽¹⁾ J. A. Price letter to US NRC, "Millstone Nuclear Power Station, Unit No. 2 License Basis Document Change Request (LBDCR) 2-1-02 Limiting Safety System Settings and Instrumentation," dated May 7, 2002.

A001

The regulatory commitment contained in this letter is located in Attachment 1.

If you should have any questions regarding this submittal, please contact Mr. Ravi Joshi at (860) 440-2080.

Very truly yours,

DOMINION NUCLEAR CONNECTICUT, INC.



J. Alan Price
Site Vice President - Millstone

Sworn to and subscribed before me

this 1st day of July, 2003

Diane M. Phillippo
Notary Public

My Commission expires 12/31/2005

DIANE M. PHILLIPO
NOTARY PUBLIC
MY COMMISSION EXPIRES 12/31/2005

Attachment

cc: H. J. Miller, Region I Administrator
R. B. Ennis, NRC Senior Project Manager, Millstone Unit No. 2
Millstone Senior Resident Inspector

Director
Bureau of Air Management
Monitoring and Radiation Division
Department of Environmental Protection
79 Elm Street
Hartford, CT 06106-5127

Docket No. 50-336
B18931

Attachment 1

Millstone Power Station, Unit No. 2

List of Regulatory Commitments

List of Regulatory Commitments

The following table identifies action committed to by Dominion Nuclear Connecticut, Inc. (DNC) in this document.

Number	Commitment	Due
B18931-01	DNC hereby commits to submit a license amendment request to reflect two channels of control room isolation actuation instrumentation.	July 31, 2004