

July 22, 2003

MEMORANDUM TO: L. Raghavan, Section Chief, Section 1
Project Directorate III
Division of Licensing Project Management

FROM: John G. Lamb, Project Manager, Section 1 /RA/
Project Directorate III
Division of Licensing Project Management

SUBJECT: SUMMARY OF PHONE CALL HELD ON JULY 8, 2003, REGARDING
BULLETIN 2003-01, "POTENTIAL IMPACT OF DEBRIS BLOCKAGE
ON EMERGENCY SUMP RECIRCULATION AT PRESSURIZED-
WATER REACTORS" (TAC NO. MB6454)

This is a summary of a phone call held on July 8, 2003, between the Nuclear Regulatory Commission (NRC) staff, the Nuclear Energy Institute (NEI), and Progress Energy regarding Bulletin 2003-01, "Potential Impact of Debris Blockage on Emergency Sump Recirculation at Pressurized-Water Reactors."

NEI submitted a list of 73 questions to the NRC staff in advance of a June 30, 2003, public meeting regarding Bulletin 2003-01. The NRC staff responded to most of NEI's questions in a document which was handed out to the attendees of the June 30, 2003, meeting (Attachment). Subsequently, NEI and Progress Energy requested a phone call with the NRC staff to clarify question number 61 of its submittal. The participants of the phone call were:

<u>NRC</u>	<u>NEI</u>	<u>Progress Energy</u>
J. Lamb	J. Butler	W. McGown
R. Architzel		K. Heffner
J. Lehning		J. Darrel
		T. Austin
		J. Springer
		D. Porter

The discussion during the phone call consisted of three main areas: (1) preemptive measures within the design and licensing bases without NRC approval; (2) preemptive measures outside the design and licensing bases needing NRC approval; and (3) sump distress signs beyond the design and licensing bases, taking actions beyond the design and licensing bases, and NRC approval of the actions.

NEI stated that it would send an electronic mail message to the NRC staff with NEI's and Progress Energy's understanding of question number 61. The NRC staff stated that it would consider the information when it answers question number 57 of NEI's submittal.

Attachment: NRC Staff Responses to NEI Questions

July 22, 2003

MEMORANDUM TO: L. Raghavan, Section Chief, Section 1
Project Directorate III
Division of Licensing Project Management

FROM: John G. Lamb, Project Manager, Section 1 /RA/
Project Directorate III
Division of Licensing Project Management

SUBJECT: SUMMARY OF PHONE CALL HELD ON JULY 8, 2003, REGARDING
BULLETIN 2003-01, "POTENTIAL IMPACT OF DEBRIS BLOCKAGE
ON EMERGENCY SUMP RECIRCULATION AT PRESSURIZED-
WATER REACTORS" (TAC NO. MB6454)

This is a summary of a phone call held on July 8, 2003, between the Nuclear Regulatory Commission (NRC) staff, the Nuclear Energy Institute (NEI), and Progress Energy regarding Bulletin 2003-01, "Potential Impact of Debris Blockage on Emergency Sump Recirculation at Pressurized-Water Reactors."

NEI submitted a list of 73 questions to the NRC staff in advance of a June 30, 2003, public meeting regarding Bulletin 2003-01. The NRC staff responded to most of NEI's questions in a document which was handed out to the attendees of the June 30, 2003, meeting (Attachment). Subsequently, NEI and Progress Energy requested a phone call with the NRC staff to clarify question number 61 of its submittal. The participants of the phone call were:

<u>NRC</u>	<u>NEI</u>	<u>Progress Energy</u>
J. Lamb	J. Butler	W. McGown
R. Architzel		K. Heffner
J. Lehning		J. Darrel
		T. Austin
		J. Springer
		D. Porter

The discussion during the phone call consisted of three main areas: (1) preemptive measures within the design and licensing bases without NRC approval; (2) preemptive measures outside the design and licensing bases needing NRC approval; and (3) sump distress signs beyond the design and licensing bases, taking actions beyond the design and licensing bases, and NRC approval of the actions.

NEI stated that it would send an electronic mail message to the NRC staff with NEI's and Progress Energy's understanding of question number 61. The NRC staff stated that it would consider the information when it answers question number 57 of NEI's submittal.

Attachment: NRC Staff Responses to NEI Questions

DISTRIBUTION

PUBLIC	RBouling
PDIII-1 Reading	RArchitzel
LRaghavan	JLehning
JLamb	SWeerakkody

OFFICE	PDIII-1/PM	PDIII-1/LA	PDIII-1/SC
NAME	JLamb	RBouling	LRaghavan
DATE	07/22/03	07/16/03	07/22/03

ADAMS Accession No. ML031940003 (Memo)

ML031970112 (NEI Questions)

ADAMS Accession No. ML031810371 (Attachment)

ML031970114 (Package)

OFFICIAL RECORD COPY