

July 11, 2003

Mr. R. T. Ridenoure
Division Manager - Nuclear Operations
Omaha Public Power District
Fort Calhoun Station FC-2-4 Adm.
P.O. Box 550
Fort Calhoun, NE 68023-0550

SUBJECT: CORRECTION TO AMENDMENT NO. 218 FOR THE FORT CALHOUN
STATION, UNIT NO. 1 (TAC NO. MB7498)

Dear Mr. Ridenoure:

On May 8, 2003, the Commission issued Amendment No. 218 to Facility Operating License No. DPR-40 for the Fort Calhoun Station, Unit No. 1 (FCS). The amendment made administrative and editorial changes to several of the FCS Technical Specifications and was in response to your application dated January 27, 2003.

Due to an administrative error, page 3-0a did not reflect a change that was previously made in Amendment No. 215. The corrected page 3-0a is enclosed. We apologize for any inconvenience this may have caused.

Sincerely,

/RA/

Alan B. Wang, Project Manager, Section 2
Project Directorate IV
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Enclosure: Page 3-0a

cc w/encl: See next page

July 11, 2003

Mr. R. T. Ridenoure
Division Manager - Nuclear Operations
Omaha Public Power District
Fort Calhoun Station FC-2-4 Adm.
P.O. Box 550
Fort Calhoun, NE 68023-0550

SUBJECT: CORRECTION TO AMENDMENT NO. 218 FOR THE FORT CALHOUN
STATION, UNIT NO. 1 (TAC NO. MB7498)

Dear Mr. Ridenoure:

On May 8, 2003, the Commission issued Amendment No. 218 to Facility Operating License No. DPR-40 for the Fort Calhoun Station, Unit No. 1 (FCS). The amendment made administrative and editorial changes to several of the FCS Technical Specifications and was in response to your application dated January 27, 2003.

Due to an administrative error, page 3-0a did not reflect a change that was previously made in Amendment No. 215. The corrected page 3-0a is enclosed. We apologize for any inconvenience this may have caused.

Sincerely,

/RA/

Alan B. Wang, Project Manager, Section 2
Project Directorate IV
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Enclosure: Page 3-0a

cc w/encl: See next page

DISTRIBUTION:

PUBLIC

PDIV-2 Reading

RidsNrrDlpmLpdiv (HBerkow)

RidsNrrPMAWang

RidsNrrLAEPeyton

RidsAcrsAcnwMailCenter

WBeckner

RidsRgn4MailCenter (AHowell)

RJenkins (NRR/DE/EEIB)

FAkstulewicz (NRR/DSSA/SRXB)

ADAMS Accession No.: ML031960625

NRR-106

OFFICE	PDIV-2/PM	PDIV-2/LA	PDIV-2/SC
NAME	AWang	EPeyton:esp	SDembek
DATE	7/11/03	7/11/03	7/11/03

DOCUMENT NAME: C:\ORPCheckout\FileNET\ML031960625.wpd

OFFICIAL RECORD COPY

Ft. Calhoun Station, Unit 1

cc:

Winston & Strawn
ATTN: James R. Curtiss, Esq.
1400 L Street, N.W.
Washington, DC 20005-3502

Chairman
Washington County Board of Supervisors
P.O. Box 466
Blair, NE 68008

Mr. John Kramer, Resident Inspector
U.S. Nuclear Regulatory Commission
P.O. Box 310
Fort Calhoun, NE 68023

Regional Administrator, Region IV
U.S. Nuclear Regulatory Commission
611 Ryan Plaza Drive, Suite 400
Arlington, TX 76011-4005

Ms. Sue Semerera, Section Administrator
Nebraska Health and Human Services
Systems
Division of Public Health Assurance
Consumer Services Section
301 Centennial Mall, South
P.O. Box 95007
Lincoln, NE 68509-5007

Mr. David J. Bannister, Manager
Fort Calhoun Station
Omaha Public Power District
Fort Calhoun Station FC-1-1 Plant
P.O. Box 550
Fort Calhoun, NE 68023-0550

Mr. John B. Herman
Manager - Nuclear Licensing
Omaha Public Power District
Fort Calhoun Station FC-2-4 Adm.
P.O. Box 550
Fort Calhoun, NE 68023-0550

Mr. Daniel K. McGhee
Bureau of Radiological Health
Iowa Department of Public Health
401 SW 7th Street, Suite D
Des Moines, IA 50309

Mr. Richard P. Clemens
Division Manager - Nuclear Assessments
Omaha Public Power District
Fort Calhoun Station
P.O. Box 550
Fort Calhoun, NE 68023-0550

3.0 **SURVEILLANCE REQUIREMENTS**

3.0.1 Each surveillance requirement shall be performed within the specified surveillance interval with a maximum allowable extension not to exceed 25 percent of the specified surveillance interval.

3.0.2 The surveillance intervals are defined as follows:

<u>Notation</u>	<u>Title</u>	<u>Frequency</u>
S	Shift	At least once per 12 hours
D	Daily	At least once per 24 hours
W	Weekly	At least once per 7 days
BW	Biweekly	At least once per 14 days
M	Monthly	At least once per 31 days
Q	Quarterly	At least once per 92 days
SA	Semiannual	At least once per 184 days
A	Annually	At least once per 366 days
R	Refueling	At least once per 18 months
P	Start up	Prior to Reactor Start up, if not completed in the previous week.

Exception to these intervals are stated in the individual Specifications.

3.0.3 The provisions of Specifications 3.0.1 and 3.0.2 are applicable to all codes and standards referenced within the Technical Specifications. The requirements of the Technical Specifications shall have precedence over the requirements of the codes and standards referenced within the Technical Specifications.

3.0.4 Surveillance Requirements shall be met during the MODES or other specified conditions in the individual Limiting Conditions for Operation, unless otherwise stated in the Surveillance Requirement. Failure to meet a Surveillance, whether such failure is experienced during the performance of the Surveillance or between performances of the Surveillance, shall be failure to meet the OPERABILITY requirements for the corresponding Limiting Condition for Operation. Failure to perform a Surveillance Requirement within the allowed surveillance interval, defined by Specifications 3.0.1 and 3.0.2 shall constitute noncompliance with the OPERABILITY requirements for the corresponding Limiting Condition for Operation except as provided in Specification 3.0.5. The time limits of the ACTION requirements are applicable at the time it is identified that a Surveillance Requirement has not been performed. Surveillance Requirements do not have to be performed on inoperable equipment.

3.0.5 If it is discovered that a Surveillance was not performed within its specified surveillance interval, then compliance with the requirement to declare the OPERABILITY requirements for the Limiting Condition for Operation not met may be delayed, from the time of discovery, up to 24 hours or up to the limit of the specified surveillance interval, whichever is greater. This delay period is permitted to allow performance of the Surveillance. A risk evaluation shall be performed for any Surveillance delayed greater than 24 hours and the risk impact shall be managed.