

July 15, 2003

Licensee: STP Nuclear Operating Company
Facility: South Texas Project, Unit 1
SUBJECT: SUMMARY OF HEADQUARTERS, REGION IV, AND STP NUCLEAR OPERATING COMPANY (STPNOC) TELEPHONE CONVERSATION ON MAY 20, 2003 REGARDING SOUTH TEXAS PROJECT, UNIT 1, BMI LEAKAGE ISSUE; SUPPLEMENTAL INSPECTIONS (TAC NO. MB8435)

On May 20, 2003, the NRC Headquarters and Region IV special inspection team staff held a telephone conference with STPNOC, the licensee for South Texas Project Unit 1. The conference call was a follow up of inspection of the licensee's activities following the discovery of an apparent leakage at the interface of reactor vessel bottom head and bottom mounted instrument (BMI) penetrations 1 and 46.

At this phone call the licensee went through a list of potential supplemental inspection activities that the licensee is considering. The licensee stated that it was evaluating the feasibility of performing a pressurized helium leakage test to visualize the leakage pathways that resulted in the April 12, 2003, discovery of leakage deposit indications under BMI penetrations 1 and 46. To look for evidence of any wastage, the licensee planned to perform a visual examination of the internal surface of the nozzles and the reactor pressure vessel nozzle bores' inside wall after the removal of the Alloy 600 tubes during the planned repairs. The licensee additionally discussed the use of ultrasonic inspections to interrogate the bottom of the reactor vessel for possible wastage. The licensee will also perform profilometry of penetration numbers 1 and 46 using eddy current probes, a 'straight rod' test to investigate the penetrations' alignment and roundness, and examination of material of Alloy 600 from tubes removed during the repair process. The licensee will also obtain and evaluate 'boat' samples from the tubes in penetration numbers 1 and 46. The licensee also discussed using eddy current techniques to interrogate the J-groove weld surface. The licensee further confirmed that it was not likely to pursue other options that were previously discussed, including molds of the inside surface of nozzles, and x-ray diffraction studies of a J-groove weld mockup.

The NRC staff stated that it concurred with the licensee's assessment that obtaining boat samples from the penetrations would yield extremely valuable information with regard to root cause determination. The NRC staff asked to be kept informed of the windows of opportunity, as they presented themselves, to pursue the above supplemental inspections; and as the licensee made final decisions and pursued a full array of planned tests.

/RA/

Mohan C. Thadani, Senior Project Manager, Section 1
Project Directorate IV
Division of Licensing and Project Management
Office of Nuclear Reactor Regulation

South Texas, Unit 1

cc:

Mr. Cornelius F. O'Keefe
Senior Resident Inspector
U.S. Nuclear Regulatory Commission
P. O. Box 910
Bay City, TX 77414

A. Ramirez/C. M. Canady
City of Austin
Electric Utility Department
721 Barton Springs Road
Austin, TX 78704

Mr. L. K. Blaylock
Mr. W. C. Gunst
City Public Service Board
P. O. Box 1771
San Antonio, TX 78296

Mr. C. A. Johnson/A. C. Bakken
AEP Texas Central Company
P. O. Box 289
Mail Code: N5022
Wadsworth, TX 77483

INPO
Records Center
700 Galleria Parkway
Atlanta, GA 30339-3064

Regional Administrator, Region IV
U.S. Nuclear Regulatory Commission
611 Ryan Plaza Drive, Suite 400
Arlington, TX 76011

D. G. Tees/R. L. Balcom
Texas Genco, LP
P. O. Box 1700
Houston, TX 77251

Judge, Matagorda County
Matagorda County Courthouse
1700 Seventh Street
Bay City, TX 77414

A. H. Gutterman, Esq.
Morgan, Lewis & Bockius
1111 Pennsylvania Avenue, NW
Washington, DC 20004

Mr. T. J. Jordan, Vice President
Engineering & Technical Services
STP Nuclear Operating Company
P. O. Box 289
Wadsworth, TX 77483

S. M. Head, Manager, Licensing
Nuclear Quality & Licensing Department
STP Nuclear Operating Company
P. O. Box 289, Mail Code: N5014
Wadsworth, TX 77483

Environmental and Natural Resources
Policy Director
P. O. Box 12428
Austin, TX 78711-3189

Jon C. Wood
Matthews & Branscomb
112 East Pecan, Suite 1100
San Antonio, TX 78205

Arthur C. Tate, Director
Division of Compliance & Inspection
Bureau of Radiation Control
Texas Department of Health
1100 West 49th Street
Austin, TX 78756

Brian Almon
Public Utility Commission
William B. Travis Building
P. O. Box 13326
1701 North Congress Avenue
Austin, TX 78701-3326

South Texas, Unit 1

-2-

cc:

Susan M. Jablonski
Office of Permitting, Remediation
and Registration
Texas Commission on
Environmental Quality
MC-122
P.O. Box 13087
Austin, TX 78711-3087

Mr. Terry Parks, Chief Inspector
Texas Department of Licensing
and Regulation
Boiler Division
P. O. Box 12157
Austin, TX 78711

Mr. Ted Enos
4200 South Hulen
Suite 630
Ft. Worth, Texas 76109

Mr. James J. Sheppard
President and Chief Executive Officer
STP Nuclear Operating Company
South Texas Project Electric
Generating Station
P. O. Box 289
Wadsworth, TX 77483

Licensee: STP Nuclear Operating Company July 15, 2003

Facility: South Texas Project, Unit 1

SUBJECT: SUMMARY OF HEADQUARTERS, REGION IV, AND STP NUCLEAR OPERATING COMPANY (STPNOC) TELEPHONE CONVERSATION ON MAY 20, 2003 REGARDING SOUTH TEXAS PROJECT, UNIT 1, BMI LEAKAGE ISSUE; SUPPLEMENTAL INSPECTIONS (TAC NO. MB8435)

On May 20, 2003, the NRC Headquarters and Region IV special inspection team staff held a telephone conference with STPNOC, the licensee for South Texas Project Unit 1. The conference call was a follow up of inspection of the licensee's activities following the discovery of an apparent leakage at the interface of reactor vessel bottom head and bottom mounted instrument (BMI) penetrations 1 and 46.

At this phone call the licensee went through a list of potential supplemental inspection activities that the licensee is considering. The licensee stated that it was evaluating the feasibility of performing a pressurized helium leakage test to visualize the leakage pathways that resulted in the April 12, 2003, discovery of leakage deposit indications under BMI penetrations 1 and 46. To look for evidence of any wastage, the licensee planned to perform a visual examination of the internal surface of the nozzles and the reactor pressure vessel nozzle bores' inside wall after the removal of the Alloy 600 tubes during the planned repairs. The licensee additionally discussed the use of ultrasonic inspections to interrogate the bottom of the reactor vessel for possible wastage. The licensee will also perform profilometry of penetration numbers 1 and 46 using eddy current probes, a 'straight rod' test to investigate the penetrations' alignment and roundness, and examination of material of Alloy 600 from tubes removed during the repair process. The licensee will also obtain and evaluate 'boat' samples from the tubes in penetration numbers 1 and 46. The licensee also discussed using eddy current techniques to interrogate the J-groove weld surface. The licensee further confirmed that it was not likely to pursue other options that were previously discussed, including molds of the inside surface of nozzles, and x-ray diffraction studies of a J-groove weld mockup.

The NRC staff stated that it concurred with the licensee's assessment that obtaining boat samples from the penetrations would yield extremely valuable information with regard to root cause determination. The NRC staff asked to be kept informed of the windows of opportunity, as they presented themselves, to pursue the above supplemental inspections; and as the licensee made final decisions and pursued a full array of planned tests.

/RA/

Mohan C. Thadani, Senior Project Manager, Section 1
Project Directorate IV
Division of Licensing and Project Management
Office of Nuclear Reactor Regulation

Docket No. 50-498

ACCESSION NO: ML031970005

NRC-001

OFFICE	PDIV-1/PM	PDIV-1/LA	RIV	PDIV-1/SC
NAME	MThadani	MMcAllister	WJohnson via e-mail	RGramm
DATE	7/15/2003	7/15/2003	7/15/2003	7/15/2003

OFFICIAL RECORD COPY

DISTRIBUTION FOR SUMMARY OF MAY 20, 2003, MEETING WITH NRC HEADQUARTERS, NRC REGION IV, AND STPNOC RE: BOTTOM MOUNTED INSTRUMENTATION PENETRATION LEAKAGE INDICATIONS

Dated: July 15, 2003

DISTRIBUTION:

PUBLIC

PDIV-1 Reading

RidsNrrAdpt (BSheron/MKotzalas)

RidsNrrDlpm (LMarsh/ELeeds)

RidsNrrDlpmLpdiv-1 (RGramm)

RidsNrrPMMThadani

RidsNrrLAMMcAllister

RidsNrrDe (RBarrett)

RidsRgn4MailCenter (AHowell)

RidsRgn4MailCenter (WJohnson)

RidsAcrcAcnwMailCenter

RidsOgcRp

RidsNrrDeEmcb (WBateman)

RidsNrrDeEmcb (SCoffin)

RidsNrrDeEmcb (ESullivan)

MFields, EDO

RidsNrrDlpmLpdiv (HBerkow)

RidsNrrDeEmcb (EAndruszkiewicz)

RidsNrrDeEmcb (AHiser)

RidsNrrDeEmcb (MMitchell)

RidsNrrDeEmeb (KManoly)

RidsNrrDeEmeb (DTerao)

RidsNrrDeEmeb (MHartzman)

RidsNrrDripRorp (JFoster)

RidsNrrDripRorp (SLee)

RidsNrrPMWReckley

RidsNrrPMSBloom

CMoyer

WCullen

TMensah

CGratton