State of New Jersey

James E. McGreevey
Governor

Department of Environmental Protection
Division of Environmental Safety, Health,
and Analytical Programs
Radiation Protection Programs
Bureau of Nuclear Engineering
P. O. Box 415
Trenton, New Jersey 08625-0415
Tel (609) 984-7700
Fax (609) 984-7513

Bradley M. Campbell
Commissioner

June 27, 2003

United States Nuclear Regulatory Commission
Document Control Desk
Washington, DC 20555

Dear Sir:

Subject: Salem Generating Station, Units 1 and 2
Docket Nos. 50-272 and 50-311
License Change Request S02-07
Request for Change to Technical Specifications
Pressure Sensor Response Time Testing

PSEG Nuclear LLC submitted the proposed change to the Salem Units 1 and 2 Technical Specifications by letter to the NRC dated April 11, 2003. The proposed change will modify Surveillance Requirements 4.3.1.1.3, 4.3.2.1.3 and Bases Sections B3/4.3.1 and B3/4.3.2 concerning response time testing of the ESF Actuation System (ESFAS) and the Reactor Trip System (RTS). These changes are based on WCAP-13632, Revision 2 which was approved by the NRC in a letter dated September 5, 1995.

The BNE recommends that approval of these changes be limited to only the pressure and differential pressure sensors identified in WCAP-13632, Revision 2 as specified on page 15 of the NRC's evaluation of this WCAP that was attached to the NRC's September 5, 1995 letter.

If you need to discuss the subject further, please contact Elliot Rosenfeld at (609) 984-7548.

Sincerely,

Kent W. Tosch, Manager
Bureau of Nuclear Engineering

A001

Distribution

Dr. Jill Lipoti, DEP
Dennis Zannoni, DEP
Dr. Robert Bores, NRC
Robert Fretz, NRC Licensing Project Manager
Daniel Orr, Sr Resident Inspector
Gabor Salamon, PSEG Nuclear LLC