



State of New Jersey

James E. McGreevey
Governor

Department of Environmental Protection
Division of Environmental Safety, Health,
and Analytical Programs
Radiation Protection Programs
Bureau of Nuclear Engineering
P. O. Box 415
Trenton, New Jersey 08625-0415
Tel (609) 984-7700
Fax (609) 984-7513

Bradley M. Campbell
Commissioner

June 20, 2003

United States Nuclear Regulatory Commission
Document Control Desk
Washington, DC 20555

Dear Sir:

**Subject: Salem Generating Station, Units 1 and 2
Docket Nos. 50-272 and 50-311
License Change Request S03-02
Request for Changes to Technical Specifications Table 3.3-1, Reactor Trip
System Instrumentation**

PSEG Nuclear LLC submitted the proposed change to the Salem Units 1 and 2 Technical Specifications by letter to the NRC dated April 10, 2003. The proposed change will modify the "Condition and Setpoint" description for permissive P-7 to reflect the locations of the pressure taps as part of the turbine upgrade/electrical power uprate program.

The BNE has no comments on the proposed change. If you need to discuss the subject further, please contact Elliot Rosenfeld at (609) 984-7548.

Sincerely,

**Kent W. Tosch, Manager
Bureau of Nuclear Engineering**

A001

Distribution

Dr. Jill Lipoti, DEP
Dennis Zannoni, DEP
Dr. Robert Bores, NRC
Robert Fretz, NRC Licensing Project Manager
Daniel Orr, Sr Resident Inspector
Gabor Salamon, PSEG Nuclear LLC