



## State of New Jersey

James E. McGreevey  
Governor

Department of Environmental Protection  
Division of Environmental Safety, Health,  
and Analytical Programs  
Radiation Protection Programs  
Bureau of Nuclear Engineering  
P. O. Box 415  
Trenton, New Jersey 08625-0415  
Tel (609) 984-7700  
Fax (609) 984-7513

Bradley M. Campbell  
Commissioner

June 20, 2003

United States Nuclear Regulatory Commission  
Document Control Desk  
Washington, DC 20555

Dear Sir:

**Subject:** Salem Generating Station, Units 1 and 2  
Docket Nos. 50-272 and 50-311  
License Change Request S03-02  
Request for Changes to Technical Specifications Table 3.3-1, Reactor Trip  
System Instrumentation

PSEG Nuclear LLC submitted the proposed change to the Salem Units 1 and 2 Technical Specifications by letter to the NRC dated April 10, 2003. The proposed change will modify the "Condition and Setpoint" description for permissive P-7 to reflect the locations of the pressure taps as part of the turbine upgrade/electrical power uprate program.

The BNE has no comments on the proposed change. If you need to discuss the subject further, please contact Elliot Rosenfeld at (609) 984-7548.

Sincerely,

Kent W. Tosch, Manager  
Bureau of Nuclear Engineering

A001

Distribution

Dr. Jill Lipoti, DEP  
Dennis Zannoni, DEP  
Dr. Robert Bores, NRC  
Robert Fretz, NRC Licensing Project Manager  
Daniel Orr, Sr Resident Inspector  
Gabor Salamon, PSEG Nuclear LLC