

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
E. One channel inoperable.	-----NOTE----- The inoperable channel, or one additional channel for functions 6, 7, and 8.b may be bypassed for up to 4 hours for surveillance testing of other channels. For functions 2.b, 3.a, 3.b, and 14.a only the inoperable channel may be bypassed for surveillance testing of other channels.	
	E.1 Place channel in trip. <u>OR</u>	6 hours
	E.2 Be in MODE 3.	12 hours
F. One Intermediate Range Neutron Flux channel inoperable.	F.1 Reduce THERMAL POWER to < P-6. <u>OR</u>	24 hours
	F.2 Increase THERMAL POWER to > P-10.	24 hours
G. Two Intermediate Range Neutron Flux channels inoperable.	G.1 -----NOTE----- Limited boron concentration changes associated with RCS inventory control or limited plant temperature changes are allowed.  Suspend operations involving positive reactivity additions.  <u>AND</u>	Immediately
	G.2 Reduce THERMAL POWER to < P-6.	2 hours
H. Not used		

(continued)

**ACTIONS (continued)**

CONDITION	REQUIRED ACTION	COMPLETION TIME
I. One Source Range Neutron Flux channel inoperable.	I.1 <del>NOTE</del> Limited boron concentration changes associated with RCS inventory control or limited plant temperature changes are allowed.  Suspend operations involving positive reactivity additions.	Immediately
J. Two Source Range Neutron Flux channels inoperable.	J.1      Open reactor trip breakers (RTBs).	Immediately

(continued)

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
K. One Source Range Neutron Flux channel inoperable.	K.1 Restore channel to OPERABLE status.	48 hours
	<u>OR</u>	
	K.2.1 Initiate action to fully insert all rods.	48 hours
	<u>AND</u>	
	K.2.2 Place the Control Rod System in a condition incapable of rod withdrawal.	49 hours
L. Required Source Range Neutron Flux channel inoperable.	L.1 -----NOTE----- Plant temperature changes are allowed provided the temperature change is accounted for in the calculated SDM. ----- Suspend operations involving positive reactivity additions.	Immediately
	<u>AND</u>	
	L.2 Perform SR 3.1.1.1.	1 hour <u>AND</u> Once per 12 hours thereafter
M. One channel inoperable.	-----NOTE----- The inoperable channel or one additional channel for function 8.a may be bypassed for up to 4 hours for surveillance testing of other channels. For functions 9, 10, 12, and 13, only the inoperable channel may be bypassed for surveillance testing of other channels. -----	
	M.1 Place channel in trip.	6 hours
	<u>OR</u>	
	M.2 Reduce THERMAL POWER to < P-7.	12 hours
N. Not used		

(continued)

### 3.4 REACTOR COOLANT SYSTEM (RCS)

#### 3.4.5 RCS Loops-MODE 3

##### LCO 3.4.5

Two RCS loops shall be OPERABLE, and either:

- a. Two RCS loops shall be in operation when the Rod Control System is capable of rod withdrawal; or
- b. One RCS loop shall be in operation when the Rod Control System is not capable of rod withdrawal.

-----NOTE-----

All reactor coolant pumps may be removed from operation for  $\leq 1$  hour per 8 hour period provided:

- a. No operations are permitted that would cause introduction of coolant into the RCS with boron concentration less than required to meet the SDM of LCO 3.1.1; and
  - b. Core outlet temperature is maintained at least 10°F below saturation temperature.
- 

APPLICABILITY: MODE 3.

#### ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One required RCS loop inoperable.	A.1 Restore required RCS loop to OPERABLE status.	72 hours
B. Required Action and associated Completion Time of Condition A not met.	B.1 Be in MODE 4.	12 hours
C. One required RCS loop not in operation, with Rod Control System capable of rod withdrawal.	C.1 Restore required RCS loop to operation.	1 hour
	<u>OR</u> C.2 Place the Rod Control System in a condition incapable of rod withdrawal.	1 hour

(continued)

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
D. Four RCS loops inoperable.  <u>OR</u>  No RCS loop in operation.	D.1 Place the Rod Control System in a condition incapable of rod withdrawal.	Immediately
	<u>AND</u>  D.2 Suspend operations that would cause introduction of coolant into the RCS with boron concentration less than required to meet SDM of LCO 3.1.1.	Immediately
	<u>AND</u>  D.3 Initiate action to restore one RCS loop to OPERABLE status and operation.	Immediately

SURVEILLANCE REQUIREMENTS

SURVEILLANCE		FREQUENCY
SR 3.4.5.1	Verify required RCS loops are in operation.	12 hours
SR 3.4.5.2	Verify steam generator secondary side water levels are $\geq 15\%$ for required RCS loops.	12 hours
SR 3.4.5.3	Verify correct breaker alignment and indicated power are available to the required pump that is not in operation.	7 days

### 3.4 REACTOR COOLANT SYSTEM (RCS)

#### 3.4.6 RCS Loops-MODE 4

##### LCO 3.4.6

Two loops consisting of any combination of RCS loops and residual heat removal (RHR) loops shall be OPERABLE, and one loop shall be in operation.

##### NOTES

1. All reactor coolant pumps (RCPs) and RHR pumps may be removed from operation for  $\leq 1$  hour per 8 hour period provided:
  - a. No operations are permitted that would cause introduction of coolant into the RCS with boron concentration less than required to meet the SDM of LCO 3.1.1; and
  - b. Core outlet temperature is maintained at least 10°F below saturation temperature.
2. No RCP shall be started with any RCS cold leg temperature  $\leq$  Low Temperature Overpressure Protection (LTOP) arming temperature specified in the PTLR unless the pressurizer water level is less than 50%, OR the secondary side water temperature of each steam generator (SG) is  $< 50^\circ\text{F}$  above each of the RCS cold leg temperatures.

APPLICABILITY: MODE 4.

##### ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One required loop inoperable.	A.1 Initiate action to restore a second loop to OPERABLE status.	Immediately
	<p><u>AND</u></p> <p>A.2 <u>NOTE</u> Only required if one RHR loop is OPERABLE.</p> <p>Be in MODE 5.</p>	24 hours

(continued)

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
B. Two required loops inoperable. <u>OR</u>	B.1 Suspend operations that would cause introduction of coolant into the RCS with boron concentration less than required to meet SDM of LCO 3.1.1.	Immediately
No RCS or RHR loop in operation.	<u>AND</u> B.2 Initiate action to restore one loop to OPERABLE status and operation.	Immediately

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
SR 3.4.6.1 Verify one RHR or RCS loop is in operation.	12 hours
SR 3.4.6.2 Verify SG secondary side water levels are $\geq 15\%$ for required RCS loops.	12 hours
SR 3.4.6.3 Verify correct breaker alignment and indicated power are available to the required pump that is not in operation.	7 days

### 3.4 REACTOR COOLANT SYSTEM (RCS)

#### 3.4.7 RCS Loops-MODE 5, Loops Filled

- LCO 3.4.7      One residual heat removal (RHR) loop shall be OPERABLE and in operation, and either:
- a.    One additional RHR loop shall be OPERABLE; or
  - b.    The secondary side water level of at least two steam generators (SGs) shall be  $\geq 15\%$ .

---

#### NOTES

---

1.    The RHR pump of the loop in operation may be removed from operation for  $\leq 1$  hour per 8 hour period provided:
    - a.    No operations are permitted that would cause introduction of coolant into the RCS with boron concentration less than required to meet the SDM of LCO 3.1.1; and
    - b.    Core outlet temperature is maintained at least  $10^{\circ}\text{F}$  below saturation temperature.
  2.    One required RHR loop may be inoperable for up to 2 hours for surveillance testing provided that the other RHR loop is OPERABLE and in operation.
  3.    No reactor coolant pump shall be started with any RCS cold leg temperature  $\leq$  Low Temperature Overpressure Protection (LTOP) arming temperature specified in the PTLR unless the pressurizer water level is less than 50%, OR the secondary side water temperature of each SG is  $< 50^{\circ}\text{F}$  above each of the RCS cold leg temperatures.
  4.    All RHR loops may be removed from operation during planned heatup to MODE 4 when at least one RCS loop is in operation.
- 

APPLICABILITY:    MODE 5 with RCS loops filled



**ACTIONS**

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One RHR loop inoperable. <u>AND</u>  Required SGs secondary side water levels not within limits.	A.1 Initiate action to restore a second RHR loop to OPERABLE status.  <u>OR</u>  A.2 Initiate action to restore required SG secondary side water levels to within limits.	Immediately    Immediately
B. Required RHR loops inoperable. <u>OR</u>  No RHR loop in operation.	B.1 Suspend operations that would cause introduction of coolant into the RCS with boron concentration less than required to meet SDM of LCO 3.1.1.  <u>AND</u>  B.2 Initiate action to restore one RHR loop to OPERABLE status and operation.	Immediately    Immediately

**SURVEILLANCE REQUIREMENTS**

SURVEILLANCE	FREQUENCY
SR 3.4.7.1 Verify one RHR loop is in operation.	12 hours
SR 3.4.7.2 Verify SG secondary side water level is $\geq 15\%$ in required SGs.	12 hours
SR 3.4.7.3 Verify correct breaker alignment and indicated power are available to the required RHR pump that is not in operation.	7 days

### 3.4 REACTOR COOLANT SYSTEM (RCS)

#### 3.4.8 RCS Loops-MODE 5, Loops Not Filled

LCO 3.4.8 Two residual heat removal (RHR) loops shall be OPERABLE and one RHR loop shall be in operation.

#### NOTES

1. All RHR pumps may be removed from operation for  $\leq 1$  hour provided:
  - a. The core outlet temperature is maintained at least 10°F below saturation temperature.
  - b. No operations are permitted that would cause introduction of coolant into the RCS with boron concentration less than required to meet the SDM of LCO 3.1.1; and
  - c. No draining operations to further reduce the RCS water volume are permitted.
2. One RHR loop may be inoperable for  $\leq 2$  hours for surveillance testing provided that the other RHR loop is OPERABLE and in operation.

APPLICABILITY: MODE 5 with RCS loops not filled.

#### NOTE

While this LCO is not met, entry into MODE 5, Loops Not Filled, from MODE 5, Loops Filled, is not permitted.

#### ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One RHR loop inoperable.	A.1 Initiate action to restore RHR loop to OPERABLE status.	Immediately
B. Required RHR loops inoperable. <u>OR</u>	B.1 Suspend operations that would cause introduction of coolant into the RCS with boron concentration less than required to meet SDM of LCO 3.1.1.	Immediately
No RHR loop in operation.	<u>AND</u> B.2 Initiate action to restore one RHR loop to OPERABLE status and operation.	Immediately

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. (continued)	A.2.3 Suspend operations involving positive reactivity additions that could result in loss of required SDM or boron concentration.	Immediately
	<u>AND</u> A.2.4 Initiate action to restore required offsite power circuit to OPERABLE status.	Immediately
B. The required DG inoperable. <u>OR</u> The required supply train of the DFO transfer system inoperable.	B.1 Suspend CORE ALTERATIONS.	Immediately
	<u>AND</u> B.2 Suspend movement of irradiated fuel assemblies.	Immediately
	<u>AND</u> B.3 Suspend operations involving positive reactivity additions that could result in loss of required SDM or boron concentration.	Immediately
	<u>AND</u> B.4 Initiate action to restore required DG to OPERABLE status.	Immediately

### 3.8 ELECTRICAL POWER SYSTEMS

#### 3.8.5 DC Sources-Shutdown

**LCO 3.8.5**      The Class 1E DC electrical power subsystem shall be OPERABLE to support the DC electrical power distribution subsystem(s) required by LCO 3.8.10, "Distribution Systems-Shutdown."

**APPLICABILITY:**    MODES 5 and 6,  
During movement of irradiated fuel assemblies.

#### ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One or more required DC electrical power subsystems inoperable.	A.1    Declare affected required feature(s) inoperable.	Immediately
	<u>OR</u>	
	A.2.1    Suspend CORE ALTERATIONS.	Immediately
	<u>AND</u>	
	A.2.2    Suspend movement of irradiated fuel assemblies.	Immediately
	<u>AND</u>	
	A.2.3    Suspend operations involving positive reactivity additions that could result in loss of required SDM or boron concentration.	Immediately
	<u>AND</u>	
	A.2.4    Initiate action to restore required DC electrical power subsystems to OPERABLE status.	Immediately

### 3.8 ELECTRICAL POWER SYSTEMS

#### 3.8.8 Inverters-Shutdown

**LCO 3.8.8**      The Class 1E UPS Inverters shall be OPERABLE to support the onsite Class 1E 120 VAC vital bus electrical power distribution subsystem(s) required by LCO 3.8.10, "Distribution Systems-Shutdown."

**APPLICABILITY:**    MODES 5 and 6,  
During movement of irradiated fuel assemblies.

#### ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One or more required inverters inoperable.	A.1    Declare affected required feature(s) inoperable.	Immediately
	<u>OR</u>	
	A.2.1    Suspend CORE ALTERATIONS.	Immediately
	<u>AND</u>	
	A.2.2    Suspend movement of irradiated fuel assemblies.	Immediately
	<u>AND</u>	
	A.2.3    Suspend operations involving positive reactivity additions that could result in loss of required SDM or boron concentration.	Immediately
	<u>AND</u>	
	A.2.4    Initiate action to restore required inverters to OPERABLE status.	Immediately

### 3.8 ELECTRICAL POWER SYSTEMS

#### 3.8.10 Distribution Systems-Shutdown

**LCO 3.8.10**      The necessary portion of the Class 1E AC, DC, and 120 VAC vital bus electrical power distribution subsystems shall be OPERABLE to support equipment required to be OPERABLE.

**APPLICABILITY:**    MODES 5 and 6,  
During movement of irradiated fuel assemblies.

#### ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One or more required AC, DC, or 120 VAC vital bus electrical power distribution subsystems inoperable.	A.1      Declare associated supported required feature(s) inoperable.	Immediately
	<u>OR</u>	
	A.2.1    Suspend CORE ALTERATIONS.	Immediately
	<u>AND</u>	
	A.2.2    Suspend movement of irradiated fuel assemblies.	Immediately
	<u>AND</u>	
	A.2.3    Suspend operations involving positive reactivity additions that could result in loss of required SDM or boron concentration.	Immediately
	<u>AND</u>	

(continued)

### 3.9 REFUELING OPERATIONS

#### 3.9.3 Nuclear Instrumentation

LCO 3.9.3 Two source range neutron flux monitors shall be OPERABLE.

APPLICABILITY: MODE 6

#### ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One required source range neutron flux monitor inoperable.	A.1 Suspend CORE ALTERATIONS except for latching control rod drive shafts and friction testing of individual control rods.	Immediately
	<u>AND</u> A.2 Suspend operations that would cause introduction of coolant into the RCS with boron concentration less than required to meet the boron concentration of LCO 3.9.1.	Immediately
B. Two required source range neutron flux monitors inoperable.	B.1 Initiate action to restore one source range neutron flux monitor to OPERABLE status.	Immediately
	<u>AND</u> B.2 Perform SR 3.9.1.1.	Once per 12 hours

#### SURVEILLANCE REQUIREMENTS

SURVEILLANCE		FREQUENCY
SR 3.9.3.1	Perform CHANNEL CHECK.	12 hours
SR 3.9.3.2	<p>-----NOTE----- Neutron detectors are excluded from CHANNEL CALIBRATION.</p> <p>----- Perform CHANNEL CALIBRATION.</p>	24 months

### 3.9 REFUELING OPERATIONS

#### 3.9.5 Residual Heat Removal (RHR) and Coolant Circulation - High Water Level

LCO 3.9.5 One RHR loop shall be OPERABLE and in operation.

**NOTE**

The required RHR loop may be removed from operation for  $\leq 1$  hour per 8 hour period, provided no operations are permitted that would cause introduction of coolant into the Reactor Coolant System (RCS) with boron concentration less than that required to meet the minimum required boron concentration of LCO 3.9.1.

The required RHR loop may be removed from operation for  $\leq 2$  hours per 8 hour period for performance of leak testing the RHR suction isolation valves provided no operations are permitted that would cause reduction of the RCS boron concentration.

APPLICABILITY: MODE 6 with the water level  $\geq 23$  ft above the top of reactor vessel flange.

#### ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. RHR loop requirements not met.	A.1 Suspend operations that would cause introduction of coolant into the RCS with boron concentration less than required to meet the boron concentration of LCO 3.9.1.	Immediately
	<u>AND</u>	
	A.2 Suspend loading irradiated fuel assemblies in the core.	Immediately
	<u>AND</u>	
	A.3 Initiate action to satisfy RHR loop requirements.	Immediately
	<u>AND</u>	
	A.4 Close all containment penetrations providing direct access from containment atmosphere to outside atmosphere.	4 hours



### 3.9 REFUELING OPERATIONS

#### 3.9.6 Residual Heat Removal (RHR) and Coolant Circulation - Low Water Level

**LCO 3.9.6** Two RHR loops shall be OPERABLE, and one RHR loop shall be in operation.

**APPLICABILITY:** MODE 6 with the water level < 23 ft above the top of reactor vessel flange.

**NOTE**

While this LCO is not met, entry into a MODE or other specified condition in the APPLICABILITY is not permitted.

#### ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. Less than the required number of RHR loops OPERABLE.	A.1 Initiate action to restore required RHR loops to OPERABLE status.	Immediately
	<u>OR</u> A.2 Initiate action to establish $\geq 23$ ft of water above the top of reactor vessel flange.	Immediately
B. No RHR loop in operation.	B.1 Suspend operations that would cause introduction of coolant into the RCS with boron concentration less than required to meet the boron concentration of LCO 3.9.1.	Immediately
	<u>AND</u> B.2 Initiate action to restore one RHR loop to operation.	Immediately
	<u>AND</u> B.3 Close all containment penetrations providing direct access from containment atmosphere to outside atmosphere.	4 hours