

July 16, 2003

Mr. John L. Skolds  
Chairman and CEO  
AmerGen Energy Company, LLC  
4300 Winfield Road  
5<sup>th</sup> Floor  
Warrenville, IL 60555

SUBJECT: OYSTER CREEK GENERATING STATION- NRC INSPECTION REPORT  
50-219/03-006

Dear Mr. Skolds:

On June 6, 2003, the U. S. Nuclear Regulatory Commission (NRC) completed an engineering team inspection at your Oyster Creek reactor facility. The enclosed report presents the results of that inspection. The results of this inspection were discussed on June 6, 2003, with Mr. Ernie Harkness and other members of your staff.

This inspection examined activities conducted under your license as they relate to safety and compliance with the Commission's rules and regulations and with the conditions of your operating license. The inspectors reviewed selected procedures and records, observed activities, and interviewed personnel.

Based on the results of this inspection no findings of significance were identified.

In accordance with 10 CFR 2.790 of the NRC's "Rules of Practice," a copy of this letter and its enclosure will be available electronically for public inspection in the NRC Public Document Room or from the Publicly Available Records (PARS) component of NRC's document system (ADAMS). ADAMS is accessible from the NRC Web site at <http://www.nrc.gov/reading-rm/adams.html> (the Public Electronic Reading Room). We appreciate your cooperation.

Sincerely,

**/RA/ by Joseph G. Schoppy for**

Lawrence T. Doerflein, Chief  
Systems Evaluation Branch  
Division of Reactor Safety

Docket No. 50-219  
License No. DPR-16

Enclosure: Inspection Report 50-219/03-006  
w/Attachment: Supplemental Information

cc w/encl:

Chief Operating Officer, Exelon

Senior Vice President - Nuclear Services, Exelon

Vice President - Mid-Atlantic Regional Operations Support, Exelon

Senior Vice President - Mid-Atlantic Regional Operating Group, Exelon

Vice President - Licensing and Regulatory Affairs, Exelon

Site Vice President, Oyster Creek Nuclear Generating Station, AmerGen

Director Licensing, Exelon

Plant Manager, Oyster Creek Generating Station, AmerGen

Regulatory Assurance Manager Oyster Creek, AmerGen

Vice President, General Counsel and Secretary, Exelon

Manager Licensing - Oyster Creek and Three Mile Island, Exelon

Correspondence Control Desk, Exelon

J. Matthews, Esquire, Morgan, Lewis & Bockius LLP

Mayor of Lacey Township

K. Tosch - Chief, New Jersey Department of Environmental Protection

R. Shadis, New England Coalition Staff

BNE Manager, State of New Jersey

N. Cohen, Coordinator - Unplug Salem Campaign

E. Gbur, Coordinator - Jersey Shore Nuclear Watch

E. Zobian, Coordinator - Jersey Shore Anti Nuclear Alliance

Mr. John L. Skolds

3

**Distribution w/enc.: (VIA E-MAIL)**

Region I Docket Room (with concurrences)  
 R. Summers, DRP - Senior Resident Inspector  
 H. Miller, RA  
 J. Wiggins, DRA  
 J. Rogge, DRP  
 R. Barkley, DRP  
 J. Jolicoeur, OEDO  
 R. Laufer, NRR  
 J. Andersen, NRR  
 P. Tam, Acting PM, NRR  
 T. Colburn, Backup PM, NRR  
 W. Lanning, DRS  
 R. Crlenjak, DRS  
 DRS File

DOCUMENT NAME: C:\ORPCheckout\FileNET\ML031970789.wpd

After declaring this document "An Official Agency Record" it **will** be released to the Public.

To receive a copy of this document, indicate in the box: "C" = Copy without attachment/enclosure "E" = Copy with attachment/enclosure "N" = No copy

OFFICE	RI/DRS	RI/DRS	RI/DRP			
NAME	MModes	LDoerflein/JGS for	NPerry			
DATE	07/15/03	07/16/03	07/ /03	07/ /03	07/ /03	

OFFICIAL RECORD COPY

U. S. NUCLEAR REGULATORY COMMISSION

REGION I

Docket No: 50-219

License No: DPR-16

Report No: 50-219/03-006

Licensee: AmerGen Energy Company, LLC (AmerGen)

Facility: Oyster Creek Generating Station

Location: Forked River, New Jersey

Dates: May 19 - 23, and June 2 - 6, 2003

Inspectors: Michael Modes, Senior Reactor Inspector, Team Leader  
Stephen Pindale, Senior Reactor Inspector  
Mel Gray, Senior Reactor Inspector  
Paul Kaufman, Senior Reactor Inspector  
Leonard Cheung, Senior Reactor Inspector  
Thomas Burns, Reactor Inspector  
Fred Jaxheimer, Reactor Inspector  
Jennifer Bobiak, Intern (Accompaniment only)

Approved by: Lawrence T. Doerflein, Chief  
Systems Evaluation Branch  
Division of Reactor Safety

Enclosure

## SUMMARY OF FINDINGS

IR 05000219/2003-006; 5/19/2003 - 5/23/2003 and 6/2/2003 - 6/6/2003; Oyster Creek Generating Station; engineering team inspection.

The inspection was conducted by a team of region based inspectors during the period May 19, 2003, to June 6, 2003. No findings of significance were identified. The NRC's program for overseeing the safe operation of commercial nuclear power reactors is described in NUREG-1649, "Reactor Oversight Process," Revision 3, dated July 2000.

A. NRC-Identified and Self-Revealing Findings

No findings of significance were identified

B. Licensee-Identified Violations

None.

## REPORT DETAILS

### 1. REACTOR SAFETY

Cornerstones: Initiating Events, Mitigating Systems, and Barrier Integrity

#### 1R21 Safety System Design and Performance Capability (IP 71111.21)

##### a. Inspection Scope

The team reviewed the Oyster Creek design and performance capability of the isolation condenser (IC) system and selected interfacing and supporting systems. Using risk insights derived from the NRC "Risk Informed Inspection Notebook for Oyster Creek Generation," the inspectors focused on the IC system capability to remove decay heat from the reactor coolant system in response to a postulated reactor trip and loss of the normal power conversion system. The likelihood of the initiating event of a plant transient is one in ten years. The team focused on components and procedures that would mitigate the consequences of a transient without the plant power conversion system. Systems interfacing with the IC during this accident sequence are: the AC motor-operated isolation valves, the DC motor-operated isolation valves, the shell-side vent lines, the control rod drive (CRD) pumps, IC make-up, and the diesel fire pumps. The team also reviewed the core spray system in the alternate path of IC make-up alignment.

The inspectors reviewed the Oyster Creek Safety Analysis Report, technical specifications, and docketed correspondence in order to understand the IC licensing basis and design function. The inspectors confirmed the IC safety function is to remove decay heat and depressurize the reactor coolant system in the event the main condenser heat sink is unavailable, because the main condenser is part of the normal power conversion system. System operating procedures, including emergency operating procedures and surveillance procedures, were reviewed to ensure they supported the IC system licensing, design bases, and technical specification requirements. The review included applicable surveillance test results and focused on the ability of the IC system to remove core decay heat, depressurize the reactor, and provide inventory control.

The inspectors confirmed the IC system consists of two redundant heat exchangers, or ICs. The shell side of each IC is filled with water to a level that covers the tube bundles and provides a minimum inventory for boil-off. The shell side is vented to the atmosphere. The IC tubes are connected to the reactor vessel steam dome. During normal power operation, the tube inlet headers are steam filled, but the submerged tube bundles themselves are filled with reactor coolant water, called condensate, at normal pressure and temperature. The tube bundle outlet headers return to the reactor vessel via normally closed power operated condensate return valves, such that the IC tube bundles form a closed loop with the reactor coolant system. The system automatically initiates on a high reactor coolant system pressure or low reactor vessel level signal by opening the normally closed condensate return valves. Reactor coolant flows through the IC tube bundles by natural circulation. The ICs cool the reactor coolant (and remove

Enclosure

decay heat) by boiling the shell side water inventory and venting the steam to the atmosphere. Operators can also manually initiate flow through the IC.

The inspectors reviewed design drawings to confirm the IC system configuration was consistent with the design assumptions for natural circulation. Plant walkdowns were completed to verify the IC configuration was in conformance with design documents. IC shell level indication was reviewed to ensure the configuration was consistent with calibration assumptions. The inspectors also walked down IC system equipment to ensure there were not significant indications of plant equipment problems, and to verify that minor equipment problems were being appropriately addressed in the Oyster Creek maintenance and corrective action program.

The inspectors reviewed IC shell side inventory thermal calculations to verify they correctly calculated the shell side water inventory necessary to provide for the decay heat levels assumed in the design basis. Calculation assumptions regarding IC shell water volume, temperature, level indication and decay heat load were reviewed and compared to monitored plant parameters to ensure the assumptions were technically justified. The inspectors compared the calculation conclusions to plant procedural guidance and acceptance criteria for IC level to verify the IC's capacity to absorb heat was being maintained as assumed in the calculations. Furthermore, the inspectors reviewed problems, identified by Oyster Creek personnel and entered into their corrective action program, regarding IC calculation and procedure issues. These issues were reviewed to determine the nature and extent of the problems and verify that the ICs remained capable of performing their safety function during design basis accident conditions.

The inspectors determined that portions of the condensate transfer, fire protection water, and core spray systems were credited in the design basis with refilling the IC shells to replenish water boiled off in removing decay heat and maintain the IC tubes covered. The nonsafety-related condensate transfer system was the preferred make-up path to the IC shells, providing flow from the condensate storage tank (CST). The inspectors reviewed plant historical data and pump and valve test data that demonstrated the condensate transfer system capability to provide adequate make-up. Since the CST provides water to multiple systems, including the CRD make-up to the reactor coolant system after a reactor trip, calculations tabulating system users were reviewed to verify the CST volume provides adequate make-up to multiple sources as assumed in the design basis.

Hydraulic calculations were reviewed for the fire protection system make-up source. The inspectors determined that the diesel driven fire pumps were credited as a back-up make-up source, providing fire water to the IC shells via either of two diesel driven fire pumps. The inspectors reviewed the hydraulic calculations to verify they were technically adequate, and that the fire protection system design matched the assumed configuration. Periodic valve and pump test procedures were reviewed to ensure they confirmed manual and automatic equipment functions could be completed as assumed in the calculations.

The inspectors further determined that the Oyster Creek licensing basis credited make-up to the IC from the torus via a core spray pump during certain natural external events, because the torus provides a water source protected from tornado and flooding effects. The inspectors reviewed hydraulic and pipe stress calculations to verify they were technically correct, and that the core spray system design matched the plant configuration. The inspectors also reviewed the implementing plant operating procedures to ensure they were consistent with the licensing basis. Specifically, procedural controls were reviewed that prevented a core spray topping pump from automatically starting as assumed in the pipe stress calculations.

The inspectors determined that the installed IC make-up sources to each IC flow through an air operated valve that operators control remotely. The valve actuators were provided with air accumulators so the valves remain available on loss of normal control air. The inspectors reviewed calculations to verify the accumulators were sized to provide adequate air to operate the make-up valves during a loss of control air. Additionally, the inspectors verified that the valves were accessible in the plant and could be manually operated by handwheel if required.

The team reviewed the IC's automatic initiation logic (elementary diagrams) to verify that the initiation signal was generated, based on a one-out-of-two twice logic using four sets of instruments, by a persistent (>1.5 seconds) reactor pressure above 1060 psig or reactor pressure vessel (RPV) water level below the low-low set point of 86 inches above the top-of-fuel. The team also reviewed the control circuitry for the normally-closed IC outlet isolation valves (DC motor operated) to verify that the valves could be opened or closed by the automatic initiation signal or by manual actions. In addition, the team reviewed the pipe rupture protection logic to verify that when a high flow of greater than 300% normal flow was detected for more than 27 seconds, as sensed by two inlet (steam) and two outlet (condensate) flow switches for each condenser, all isolation valves would be closed. The team also reviewed the instrument and time delay relay calibration records to verify that the required set point accuracy was maintained.

The inspectors reviewed a temporary modification implemented in May 2002 to replace a section of a degraded multi-conductor underground control cable for the diesel fire pumps. The team reviewed the diesel fire pump wiring diagrams to verify that a failure of this control cable could only affect the remote start capability and status indications in the control room for Fire Pump 1-1 and that the other diesel fire pump would not be affected.

The inspectors further reviewed hydraulic calculations applicable to the CRD system make-up function to the reactor coolant system. The team verified the CRD pump design had adequate margin to provide the required flow through the system, and that sufficient minimum pump flow protection was provided. Test results were also reviewed that indicated valves in the flow path can be manually operated at the make-up flows consistent with the design basis.

The design and testing of the automatic IC's start circuitry was reviewed to verify the tests were being completed in accordance with technical specification requirements, and



that sensing instruments that provided initiation signals were calibrated within the accuracy assumed in the design basis. The inspectors further reviewed the high energy line break protection circuitry that automatically isolates the ICs on indications of a pipe rupture. The inspectors' review focused on the setpoint time delays to verify that they ensured the system would isolate as required, but would not cause spurious isolations during normal IC system initiation.

The inspectors reviewed a sample of permanent modifications, repairs, and replacements to the selected systems to assure these activities maintained the design basis of the systems. In addition, the inspectors reviewed preventive and corrective maintenance activities were performed as scheduled using controlled procedures. The inspectors evaluated a sample of surveillance and post maintenance test results to verify system capability was verified and design basis maintained. The inspectors reviewed selected reports of nondestructive examination of system components, where degradation would result in an increase in risk to core damage, to verify compliance with the American Society for Mechanical Engineers Boiler and Pressure Vessel Code, Section XI.

b. Findings

No findings of significance were identified.

4OA2 Identification and Resolution of Problems

a. Inspection Scope

The inspectors reviewed a sample of corrective action reports associated with the IC system, condensate transfer, CRD and fire protection system, as identified in the Documents Reviewed section, to verify that AmerGen was identifying issues at an appropriate threshold, entering them in the corrective action program, and taking appropriate corrective actions. Also, the inspectors evaluated corrective actions to confirm that repairs and/or modifications to components had no adverse impact on the system design basis.

b. Findings

No findings of significance were identified.

4OA6 Meetings, including Exit

On June 6, 2003, the inspection team presented the inspection results to Mr. E. Harkness and other members of AmerGen management. AmerGen management acknowledged the findings presented. The inspectors confirmed that proprietary information was not provided or examined during the inspection.

## SUPPLEMENTAL INFORMATION

### KEY POINTS OF CONTACT

#### Licensee Personnel

E. Harkness	Site Vice President
M. Newcomer	Acting Manager Engineering
T. Quintenz	Mgr Mechanical Structural Design
P. Bloss	Mgr Electrical, I & C, NSSS
T. Powel	Mgr Balance of Plant
D. Garnes	Mgr. Electrical, I & C Design

#### New Jersey State Representative

R. Pinney	NJ Department of Environmental Protection
-----------	---

#### NRC Personnel

S. Dennis	Acting Senior Resident Inspector
R. Summers	Senior Resident Inspector

### LIST OF ITEMS OPENED, CLOSED, AND DISCUSSED

#### Opened and Closed

None

#### Closed

None

### LIST OF ACRONYMS

AC	Alternating Current
AmerGen	AmerGen Energy Company, LLC
CRD	Control Rod Drive
CST	Condensate Storage Tank
DC	Direct Current
IC	Isolation Condenser
NRC	Nuclear Regulatory Commission
RPV	Reactor Pressure Vessel

## LIST OF DOCUMENTS REVIEWED

### Drawings

GE148F262	Emergency Condenser Flow Diagram
GE885D781	Core Spray Flow Diagram
GE237E798	Recirculation System Flow Diagram
JC19479	Fire Protection Water System Flow Diagram
BR2004	Condensate Transfer System Flow Diagram
BR2013	Control Instrument Air System Flow Diagram
BR 3029	Emergency Condenser Isolation Control: Sheet 2, Revision 22; Sheet 2A, Revision 23;
GE 157B6397	Emergency Condenser Isolation Outlet Valve V-14-0034 Elementary Diagram, Sheet 15, Revision 29.
GE 157B6350	Emergency Condenser Return Isolation Outlet Valve V-14-0036 Elementary Diagram, Sheet 152A, Revision 3.
GE 157B6350	Emergency Condenser Inlet Isolation Valve V-14-0030 Elementary Diagram, Sheet 151A, Revision 4.
BR E1102	Emergency Condenser Isolation Outlet Valve V-14-0035 Elementary Diagram, Sheet 15, Revision 29.
GE 237E566	Reactor Protection System (for Isolation Condenser Actuation) Elementary Diagram, Sheet 9, Revision 4.
DJP 3D-811-18-1003	Fire Diesel Pump 1-1 Electrical Connection Diagram, Revision 1.
DJP 3D-811-17-1001	Fire Diesel Pump 1-1 Electrical Elementary Diagram, Revision 1.
DJP DWG-H750-003	Fire Diesel Pump 1-1 Electrical Modification Elementary Diagram, Revision 0
NU5060E6003	Core Spray Drywell Isolation Electrical Elementary Diagram, Sheet 2, Revision 23.
E1132	CRD Feed Pump NC08A Elementary Diagram, Revision 13.

### Procedures

Isolation Condenser "B" Shell Water Level Level Instrument Calibration (1G06B)	609.3.008	Rev 20
Isolation Condenser Automatic Actuation Bistable Calibration and Test	609.3.113	Rev 20
Isolation Condenser Isolation Test and Calibration	609.3.002	Rev 51
Core Spray System 1 Instrument Channel Calibration, Test and System Operability	610.3.105	Rev 48
CRD Pump Operability Test	617.4.001	Rev 35
Oyster Creek Site Fire Protection Program	101.2	Rev 49
Control Rod Drive System	302.1	Rev 79
Control Rod Drive Manual Control System	302.2	Rev 20
Reactor Vessel Head Cooling System Operation	306	Rev 17
Isolation Condenser System	307	Rev 81
Emergency Core Cooling System Operation	308	Rev 71

Condensate Transfer System	316.1	Rev 38
Isolation Condenser Makeup Line Check Valve In-service Test	609.4.010	Rev 4
Isolation Condenser Valve Operability and In-service Test	609.4.001	Rev 49
Condensate Transfer Pump Operability and In-service Test	644.4.002	Rev 31
Condensate Storage Tank Level Indicator LI-424-993 Calibration	644.3.004	Rev 2
RPV Control - No ATWS	2000-EMG-3200.01A	Rev 10
RPV Control - With ATWS	2000-EMG-3200.01B	Rev 12
Emergency Depressurization - No ATWS	2000-EMG-3200.04A	Rev 4
Emergency Depressurization - With ATWS	2000-EMG-3200.04B	Rev 4
Steam Cooling	2000-EMG-3200.05	Rev 5
RPV Flooding - No ATWS	2000-EMG-3200.08A	Rev 4
RPV Flooding - With ATWS	2000-EMG-3200.08B	Rev 4
Fire Protection Program	CC-AA-211	Rev 0
Isolation Condenser "B" Shell Water Level Instrument Calibration	609.3.008	Rev 21
Operation of SEEDS Software	820.4	Rev 4
Station Blackout	200-ABN-3200.37	Rev 13
Core Spray Makeup to the Isolation Condensers	308, Attachment 12	Rev 71
Plant Fire Protection System	333	Rev 73
Low Voltage Power Circuit Breaker Corrective/Preventive Maintenance	2400-SME-3915.08	
Conduct of Installed Instrument Calibration and Maintenance	2400-ADM-3660.01	

#### Operator Lesson Plans

8280.0.0023, Rev. 6, Isolation Condensers

828.0.0057, Rev. 2, Make-up, Demineralize Water and Condensate Transfer System

System Health Overview Report, Emergency ISO Condensers

System Health Overview Report, Core Spray/ADS

MA-MA-716-009, Rev 1, Preventive Maintenance (PM) Work Order Process

Work Orders

C0551149,	Replace Relay RD68AX, CRD Pump NC08-A
C0551150,	Replace Relay RD68BX, CRD Pump NC08-B
C2002990,	Replace Bad Section of Cable 63-337, Fire Protection Diesel No. 1
C2002178,	Replace Under Voltage Devices, CRD Pump P-15-1B
R0539289,	480V SWGR Breaker Inspection, Cleaning and Testing, CRD Train "A"
C0535604,	Perform CKTBRK PM, CRD Pump P-15-1B
R2019642	Isolation Condenser Isolation and Calibration, June 29, 2001.
AR2046885	"A" Isolation Condenser Level Indication Loop Calibration.
AR2051570	Isolation Condenser "B" Shell Water Level Instrument Calibration
R2035263/2035230	CRD A & B Pump Operability Test, May 16, 2003
R2031104	CRD B Pump Operability Test, April 16, 2003.

Action Request

A2010563, Local Leak Rate Testing of Isolation Condenser Isolation Valves  
A2013593, Review of Scope of Relay Replacement Program  
A2013591, Scram Derate Action Items  
A2031857, Install Jumper for Cable 63-377, Fire Diesel Control Cable  
A2025225, Install New Relay in Fire Diesel 1-2 Control Panel

Calculations

C-1302-735-E320-040	C-1302-424-5360-003	C-1302-811-E310-030
C-1302-211-E320-126	C-1302-424-5360-004	C-1302-815-E310-001
C-1302-421-5360-008	C-1302-424-E170-012	C-1302-211-5360-049
C-1302-424-2253-002	C-1302-424-E320-001	C-1302-211-5360-033
C-1302-424-5320-008	C-1302-536-5360-003	C-1302-211-E540-125
C-1302-424-5320-010	C-1302-810-5360-003	3731-71-11-002
C-1302-424-5360-001	C-1302-811-5360-004	

Corrective Action (CAP)

O2003-0994	O2000-2116	O2003-0770	O02003-1102 *
O2002-1954	O2000-1562	O2003-0980	O02003-1110 *
O2002-1441	O2001-0844	O2003-0994	O02003-1138 *
O2003-0995	O1998-1668	O1998-1790	O02003-1146 *
O2002-0104	O2001-0783	O2001-1783	O2003-1148 *
O2002-1089	O2003-1732	O2003-0867	O2003-1149 *
O2002-0420	O2003-0397	O2003-0801	O2003-1162 *
O2002-0116	O2003-0444	O2002-1904	

(\*Generated as result of NRC questions)

Examination Summary Sheets

OCR19-028, PT-031, Liquid Penetrant Examination of Weld NC-4-001B, Safe End, CRD  
 OCR19-046, D-053, Ultrasonic Examination of Weld NE-2-225, ISO Condenser  
 OCR19-046, PT-028, Liquid Penetrant Examination of Weld NE-2-225, ISO Condenser

### Surveillance Test Procedures

Procedure 609.4.001, Isolation Condenser Valve Operability and In-Service Test, Rev 49, completed under work order R2026990, 1/17/03

Procedure 609.4.007, Fire Water Make-up to Isolation Condenser IST, Rev 13, completed under work order R2023802, 11/18/02

Procedure 619.3.004, Primary Containment Isolation Functional Test, Rev 42, completed under work order R0808506, 10/22/02

Procedure 609.3.003, Isolation Condenser Automatic Actuation Sensor Calibration and Test, Rev 46, completed 4/9/03 under work order R2019124

Procedure 609.3.012, Isolation Condenser Isolation Test and Calibration - A2/B2 Sensors First, Rev 7, completed 1/17/03 under work order R2022724

Test Procedure 247/11, Fire Diesel Pump 1-1 Functional Test, completed 5/14/02

### Design Change Packages, and Safety Evaluations

EJ2002-012,	Temporary Modification, 1-1 Fire Diesel Temporary Control Cable, Revision 1.
OC-2002-S-0306	50.59 Screening for 1-1 Fire Diesel Temporary Control/Alarm Cable, Revision 0.

### Miscellaneous

Safety Evaluation 315403-31, Justification for Revised Isolation Condenser High Flow Trip, Revision 1, September 30, 1994

Safety Evaluation 000661-017, Removal of Isolation Condenser Vent Radiation and Containment Spray/Emergency Service Water Heat Exchanger Monitoring System, Rev 2, 8/15/95

Post-Transient Report Number 97-148, 8/1/97

Design Specification 21A1607, Oyster Creek Emergency Condensers, Rev 1, July 1966

Vendor Manual VPF#1350-16-2, Instructions for Care and Operation of Emergency Condenser, January 1967

Operations Plant Manual, Module 23, Isolation Condenser System, Rev 2, 1/8/92

Isolation Condenser Make-up Log, 1/30/01 to 4/24/03

Oyster Creek, UFSAR, Section 6.3, Update 11, Emergency Core Cooling System

Oyster Creek, UFSAR, Section 10.4.7, Update 11, Condensate and Feedwater Systems

Oyster Creek, UFSAR, Section 9.5.1, Update 7, Fire Protection Program