

July 24, 2003

Mr. John L. Skolds, Chairman  
and Chief Executive Officer  
AmerGen Energy Company, LLC  
4300 Winfield Road  
Warrenville, Illinois 60555

SUBJECT: CLINTON POWER STATION, UNIT 1 - CORRECTIONS TO AMENDMENT  
NO. 156 (TAC NO. MB3578)

Dear Mr. Skolds:

By letter dated June 12, 2003, the U.S. Nuclear Regulatory Commission issued Amendment No. 156 to Facility Operating License No. NPF-62 for the Clinton Power Station, Unit 1. The amendment revised Technical Specification (TS) 3.6.2.2, "Suppression Pool Water Level," and TS 3.6.2.4, "Suppression Pool Makeup (SPMU) System," to permit draining the reactor cavity pool portion of the upper containment pool in MODE 3, "Hot Shutdown," with the reactor vessel pressure less than 235 psig.

Your staff recently informed us of two administrative errors included in the Amendment. First, the amended paragraph 2.C.(2) of the Facility Operating License did not reference the associated Amendment number. In addition, Required Action A of TS 3.6.2.2 inadvertently introduced the word "OR" without an associated action.

Corrected pages to both the Amendment and TS 3.6.2.2 are enclosed. We apologize for any inconvenience this may have caused.

Sincerely,

*/RA/*

Douglas V. Pickett, Senior Project Manager, Section 2  
Project Directorate III  
Division of Licensing Project Management  
Office of Nuclear Reactor Regulation

Docket No. 50-461

Enclosures: 1. Corrected Amendment No. 156 to NPF-62  
2. Corrected TS 3.6.2.2

cc w/encls: See next page

July 24, 2003

Mr. John L. Skolds, Chairman  
and Chief Executive Officer  
AmerGen Energy Company, LLC  
4300 Winfield Road  
Warrenville, Illinois 60555

SUBJECT: CLINTON POWER STATION, UNIT 1 - CORRECTIONS TO AMENDMENT  
NO. 156 (TAC NO. MB3578)

Dear Mr. Skolds:

By letter dated June 12, 2003, the U.S. Nuclear Regulatory Commission issued Amendment No. 156 to Facility Operating License No. NPF-62 for the Clinton Power Station, Unit 1. The amendment revised Technical Specification (TS) 3.6.2.2, "Suppression Pool Water Level," and TS 3.6.2.4, "Suppression Pool Makeup (SPMU) System," to permit draining the reactor cavity pool portion of the upper containment pool in MODE 3, "Hot Shutdown," with the reactor vessel pressure less than 235 psig.

Your staff recently informed us of two administrative errors included in the Amendment. First, the amended paragraph 2.C.(2) of the Facility Operating License did not reference the associated Amendment number. In addition, Required Action A of TS 3.6.2.2 inadvertently introduced the word "OR" without an associated action.

Corrected pages to both the Amendment and TS 3.6.2.2 are enclosed. We apologize for any inconvenience this may have caused.

Sincerely,

**/RA/**

Douglas V. Pickett, Senior Project Manager, Section 2  
Project Directorate III  
Division of Licensing Project Management  
Office of Nuclear Reactor Regulation

Docket No. 50-461

Enclosures: 1. Corrected Amendment No. 156 to NPF-62  
2. Corrected TS 3.6.2.2

cc w/encls: See next page

Distribution w/encls:

PUBLIC	GHill (2)	GGrant, RIII
PD3-2 r/f	OGC	DPickett
ACRS	WBeckner	THarris

ADAMS Accession Number: ML032030193 (Package)  
ADAMS Accession Number: ML031980057 (Letter)  
ADAMS Accession Number: ML032030188 (Technical Specification)

OFFICE	PM:LPD3	LA:LPD3	SC:LPD3
NAME	DPickett	THarris	AMendiola
DATE	07/24/03	07/24/03	07/24/03

OFFICIAL RECORD COPY

Clinton Power Station, Unit 1

cc:

Senior Vice President - Nuclear Services  
Exelon Generation Company, LLC  
4300 Winfield Road  
Warrenville, Illinois 60555

Vice President - Mid-West Opns Support  
Exelon Generation Company, LLC  
4300 Winfield Road  
Warrenville, Illinois 60555

Senior Vice President - Mid-West  
Regional Operating Group  
Exelon Generation Company, LLC  
4300 Winfield Road  
Warrenville, Illinois 60555

Vice President - Licensing and  
Regulatory Affairs  
Exelon Generation Company, LLC  
4300 Winfield Road  
Warrenville, Illinois 60555

Manager Licensing - Clinton  
Exelon Generation Company, LLC  
4300 Winfield Road  
Warrenville, IL 60555

Regulatory Assurance Manager - Clinton  
AmerGen Energy Company, LLC  
Clinton Power Station  
RR3, Box 228  
Clinton, IL 61727-9351

Director- Licensing  
Mid-West Regional Operating Group  
Exelon Generation Company, LLC  
4300 Winfield Road  
Warrenville, Illinois 60555

Senior Counsel, Nuclear  
Mid-West Regional Operating Group  
Exelon Generation Company, LLC  
4300 Winfield Road  
Warrenville, Illinois 60555

Document Control Desk-Licensing  
Exelon Generation Company, LLC  
4300 Winfield Road  
Warrenville, Illinois 60555

Site Vice President - Clinton Power Station  
AmerGen Energy Company, LLC  
Clinton Power Station  
RR 3, Box 228  
Clinton, IL 61727-9351

Clinton Power Station Plant Manager  
AmerGen Energy Company, LLC  
Clinton Power Station  
RR 3, Box 228  
Clinton, IL 61727-9351

Resident Inspector  
U.S. Nuclear Regulatory Commission  
RR #3, Box 229A  
Clinton, IL 61727

R. T. Hill  
Licensing Services Manager  
General Electric Company  
175 Curtner Avenue, M/C 481  
San Jose, CA 95125

Clinton Power Station, Unit 1

cc:

Regional Administrator, Region III  
U.S. Nuclear Regulatory Commission  
801 Warrenville Road  
Lisle, IL 60532-4351

Chairman of DeWitt County  
c/o County Clerk's Office  
DeWitt County Courthouse  
Clinton, IL 61727

J. W. Blattner  
Project Manager  
Sargent & Lundy Engineers  
55 East Monroe Street  
Chicago, IL 62704

Illinois Department of Nuclear Safety  
Office of Nuclear Facility Safety  
1035 Outer Park Drive  
Springfield, IL 62704

AMERGEN ENERGY COMPANY, LLC

DOCKET NO. 50-461

CLINTON POWER STATION, UNIT 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 156  
License No. NPF-62

1. The U.S. Nuclear Regulatory Commission (the Commission) has found that:
  - A. The application for amendment by AmerGen Energy Company, LLC (the licensee), dated November 16, 2001, as supplemented by letters dated October 4, 2002, and March 28, 2003, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
  - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
  - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
  - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
  - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. NPF-62 is hereby amended to read as follows:

(2) Technical Specifications and Environmental Protection Plan

The Technical Specifications contained in Appendix A and the Environmental Protection Plan contained in Appendix B, as revised through Amendment No. 156