



444 South 16th Street Mall
Omaha NE 68102-2247

July 8, 2003
LIC-03-0095

U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, DC 20555-0001

Reference: Docket No. 50-285

SUBJECT: June 2003 Monthly Operating Report (MOR)

Pursuant to Fort Calhoun Station (FCS) Unit No. 1 Technical Specification 5.9.1.c, Omaha Public Power District (OPPD) submits the attached MOR for June 2003. No commitments are made to the NRC in this letter.

If you have any questions, please contact Mr. Erick Matzke at (402) 533-6855.

Sincerely,

R. L. Phelps
Division Manager
Nuclear Engineering

RLP/EPM/epm

Attachment

c: T. P. Gwynn, Acting NRC Regional Administrator, Region IV
A. B. Wang, NRC Project Manager
J. G. Kramer, NRC Senior Resident Inspector
INPO Records Center

IE24

LIC-03-0095
Attachment

OPERATING DATA REPORT

DOCKET NO. 50-285
UNIT NAME Fort Calhoun Station
DATE July 1, 2003
COMPLETED BY E. P. Matzke
TELEPHONE (402) 533-6855

REPORT PERIOD: June 2003

Design Electrical Rating (MWe-Net): 478
Maximum Dependable Capacity (MWe-Net): 478

	<u>MONTH</u>	<u>YR-TO-DATE</u>	<u>CUMULATIVE</u>
Number of Hours Reactor was Critical:	720	4,344	211,586
Number of Hours Generator was On-line:	720	4,344	210,272
Unit Reserve Shutdown Hours:			
Net Electrical Energy Generated (MWh):	341,527	2,026,371	91,042,401

UNIT SHUTDOWNS

No.	Date (yy/mm/dd)	Type F: Forced S: Scheduled	Duration (Hours)	Reason ¹	Method of Shutting Down Reactor ²	Cause & Corrective Action Comments

(1) Reason:

- A-Equipment Failure (Explain)
- B-Maintenance or Test
- C-Refueling
- D-Regulatory Restriction
- E-Operator Training/License Examination
- F-Administrative
- G-Operational Error (Explain)
- H-Other (Explain)

(2) Method:

- 1-Manual
- 2-Manual Trip/Scram
- 3-Automatic Trip/Scram
- 4-Continuation
- 5-Other (Explain)

OPERATIONS SUMMARY

The Fort Calhoun Station operated at 100% power the entire month.

SAFETY VALVE OR PORV CHALLENGES/FAILURES

No failures or challenges to safety valves or PORVs occurred during the month.