July 17, 2003

Dr. Nolan Hertel, Director Neely Nuclear Research Center Georgia Institute of Technology 900 Atlantic Drive Atlanta, GA 30332-0425

Dear Dr. Hertel:

SUBJECT: CORRECTION TO NRC INSPECTION REPORT NO. 50-160/2002-201

This letter refers to Inspection Report No. 50-160/2002-201 dated June 24, 2003, ADAMS Accession Number ML031490485.

Due to a word processing error, the exposure rate units, referred to in Section 7.b.4 of the report, were incorrect. The correct units are μ R/h, rather than R/h as shown in the report.

For your convenience we have enclosed a corrected report page.

We apologize for any inconvenience this may have caused. Should you have any questions concerning this letter, please contact Mr. Stephen Holmes at 301-415-8583.

Sincerely,

/RA by Paul Doyle, Acting for/

Patrick M. Madden, Section Chief Research and Test Reactors Section New, Research and Test Reactors Program (RNRP) Division of Regulatory Improvement Programs Office of Nuclear Reactor Regulation

Docket No. 50-160 License No. R-97

cc w/enclosure: Please see next page

Georgia Institute of Technology

CC:

Mr. Charles H. Badger Office of Planning and Budget Room 608 270 Washington Street, S.W. Atlanta, GA 30334

Mayor of City of Atlanta 55 Trinity Avenue, S.W. Suite 2400 Atlanta, GA 30335

Dr. William Vernetson Director of Nuclear Facilities Department of Nuclear Engineering Sciences University of Florida 202 Nuclear Sciences Center Gainesville, FL 32611

Joe D. Tanner, Commissioner Department of Natural Resources 47 Trinity Avenue, S.W. Atlanta, GA 30334

Dr. Rodney Ice, MORS Neely Nuclear Research Center Georgia Institute of Technology 900 Atlantic Drive Atlanta, GA 30332-0425

Ms. Pamela Blockey-O'Brien D23 Golden Valley Douglasville, GA 30134

Mr. E.F. Cobb Southern Nuclear Company 42 Iverness Center Birmingham, AL 35242

Dr. G. Wayne Clough, President Georgia Institute of Technology Carnegie Building Atlanta, GA 30332-0325 Ms. Glen Carrol 139 Kings Highway Decatur, GA 30030

Charles Bechhoefer, Chairman Atomic Safety and Licensing Board Panel U.S. NRC, MS: T3-F23 Washington, DC 20555-0001

Mr. James C. Hardeman, Jr. Manager, Environmental Radiation Program Environmental Protection Division Dept. of Natural Resources State of Georgia 4244 International Parkway Suite 114 Atlanta, GA 30354

Dr. Jean-Lou Chameau, Dean College of Engineering Georgia Institute of Technology 225 North Avenue Atlanta, GA 30332-0425

Dr. Peter S. Lam Atomic Safety and Licensing Board Panel U.S. NRC, MS: T3-F23 Washington, DC 20555-0001

Dr. J. Narl Davidson, Interim Dean Chair, Technical and Safety Review Committee Georgia Institute of Technology 225 North Avenue Atlanta, GA 3033-0360

Dr. Charles Liotta, Vice Provost of Research and Dean of Graduate Studies Georgia Institute of Technology 225 North Avenue Atlanta, GA 30332 Dr. Nolan Hertel, Director Neely Nuclear Research Center Georgia Institute of Technology 900 Atlantic Drive Atlanta, GA 30332-0425

Dear Dr. Hertel:

SUBJECT: CORRECTION TO NRC INSPECTION REPORT NO. 50-160/2002-201

This letter refers to Inspection Report No. 50-160/2002-201 dated June 24, 2003, ADAMS Accession Number ML031490485.

Due to a word processing error, the exposure rate units, referred to in Section 7.b.4 of the report, were incorrect. The correct units are μ R/h, rather than R/h as shown in the report.

For your convenience we have enclosed a corrected report page.

We apologize for any inconvenience this may have caused. Should you have any questions concerning this letter, please contact Mr. Stephen Holmes at 301-415-8583.

Sincerely,

/RA by Paul Doyle, Acting for/

Patrick M. Madden, Section Chief Research and Test Reactors Section New, Research and Test Reactors Program (RNRP) **Division of Regulatory Improvement Programs** Office of Nuclear Reactor Regulation

Docket No. 50-160 License No. R-97

cc w/enclosure: Please see next page

DISTRIBUTION:

PUBLIC	RNRP/R&TR r/f
SHolmes	CBassett
AAdams	CNagel

TDragoun PDoyle MMendonca FGillespie BDavis (Ltr.only O5-A4)

WEresian JLyons

Plsaac EHylton

TEMPLATE #: NRR-106

ADAMS ACCESSION NO.: ML031980548

OFFICIAL RECORD COPY							
C = COVER	E = COV	E = COVER & ENCLOSURE				N = NO COPY	
DATE	07/ 17 /2003		07/ 17 /2003		07/ 17 /2003		
NAME	EHylton:rdr		SHolmes		PMadden		
OFFICE	RNRP:LA		RNRP:RI		RNRP:SC		

were collected at each direct measurement location for determining removable gross alpha and gross beta activity. Wet smears were collected from areas adjacent to direct measurement locations to determine the H-3 and C-14 activity. Direct measurements were performed using gas proportional detectors coupled to ratemeter-scalers.

ESSAP identified an activity of 9,700 dpm/100 cm² over approximately 0.5 m^2 in the elevated area identified in the Bismuth Leak area, with an average activity of 1700 dpm/100 cm² over the contiguous one square meter area. The elevated area identified in the process equipment room was limited to approximately 100 cm² with an activity of 4,100 dpm/100 cm². An activity range of 2,700 to 5,100 dpm/100 cm² was determined for the concrete block in the air compressor room, which GIT claimed resulted from naturally occurring radioactive material in the blocks. Confirmatory scans on the interior and exterior of the room found the radiation levels to be evenly distributed throughout the blocks, confirming the activity was from the material used to make them. Removable activity levels ranged from 0 to 3 dpm/100 cm² for gross alpha and from -5 to 45 dpm/100 cm² for gross beta. H-3 removable activity levels ranged from 3 to 466 dpm/100 cm².

(4) Exposure Rate Measurements

ESSAP obtained background exposure rate measurements from various locations within the NNRC, having similar construction as the GTRR. The NNRC has a site history of radiological material usage; however, there are no other buildings similar in construction to the GTRR and NNRC on the GIT campus. Exposure rate measurements, using a microrem meter at one meter above the floor, were performed in the center of selected areas or rooms within the GTRR.

Average interior building exposure rates ranged from 9 to 25 μ R/h. Background exposure rates performed in the NNRC ranged from 18 to 20 μ R/h.

Exterior exposure rate measurements, using a microrem meter at one meter above the surface, were performed at five random locations from the reactor yard area surrounding the GTRR.

Average exterior exposure rates ranged from 14 to 18 μ R/h. Background exposure rates performed at various intersections on the GIT campus ranged from 12 to 20 μ R/h.

(5) Sampling

ESSAP collected surface soil (0-15 cm) samples at each exposure rate measurement location.

Analysis of the soil samples by gamma spectroscopy for gamma-emitting mixed fission and activation products identified Cs-137 at typical fall out concentrations. Radionuclide concentrations for Co-60 and Cs-137, which are the predominant radionuclides of concern at research reactor facilities ranged from -0.02 to 0.03