

- D. The licensee shall fully implement and maintain in effect all provisions of the Commission-approved physical security, guard training and qualification, and safeguards contingency plans including amendments made pursuant to the provisions of the Miscellaneous Amendments and Search Requirements revisions to 10 CFR 73.55 (51 FR 27817 and 27822) and to the authority of 10 CFR 50.90 and 10 CFR 50.54(p). The plans, which contain Safeguards Information protected under 10 CFR 73.21, are entitled: "River Bend Station Security Plan," with revisions submitted through May 25, 1995; "River Bend Station Guard Training and Qualification Plan," with revisions submitted through December 3, 1993; and "River Bend Station Contingency Plan," with revisions submitted through August 17, 1990. Changes made in accordance with 10 CFR 73.55 shall be implemented in accordance with the schedule set forth therein.
- E. Except as otherwise provided in the Technical Specifications or Environmental Protection Plan, EOI shall report any violations of the requirements contained in Section 2, Items C.(1); C.(3) through (9); and C.(11) through (16) of this license in the following manner: initial notification shall be made within 24 hours to the NRC Operations Center via the Emergency Notification System with written followup within 60 days in accordance with the procedures described in 10 CFR 50.73(b), (c) and (e).
- F. The licensee shall have and maintain financial protection of such type and in such amounts as the Commission shall require in accordance with Section 170 of the Atomic Energy Act of 1954, as amended, to cover public liability claims.
- G. This license is effective as of the date of issuance and shall expire at midnight on August 29, 2025.

FOR THE NUCLEAR REGULATORY COMMISSION

Original signed by

Harold R. Denton, Director  
Office of Nuclear Reactor Regulation

Enclosures:

1. Attachments 1-5
2. Appendix A - Technical Specifications (NUREG-1172)
3. Appendix B - Environmental Protection Plan
4. Appendix C - Antitrust Conditions

Date of Issuance: November 20, 1985

Revised: December 16, 1993

## 5.6 Reporting Requirements

---

### 5.6.2 Annual Radiological Environmental Operating Report (continued)

results are not available for inclusion with the report, the report shall be submitted noting and explaining the reasons for the missing results. The missing data shall be submitted in a supplementary report as soon as possible.

### 5.6.3 Radioactive Effluent Release Report

The Radioactive Effluent Release Report covering the operation of the unit during the previous calendar year shall be submitted by May 1 of each year. The report shall include a summary of the quantities of radioactive liquid and gaseous effluents and solid waste released from the unit. The material provided shall be consistent with the objectives outlined in the ODCM and process control program and in conformance with 10 CFR 50.36a and 10 CFR 50, Appendix I, Section IV.B.1.

### 5.6.4 Monthly Operating Reports

Routine reports of operating statistics and shutdown experience shall be submitted on a monthly basis no later than the 15th of each month following the calendar month covered by the report.

### 5.6.5 CORE OPERATING LIMITS REPORT (COLR)

- a. Core operating limits shall be established prior to each reload cycle, or prior to any remaining portion of a reload cycle, and shall be documented in the COLR for the following:
  - 1) LCO 3.2.1, Average Planar Linear Heat Generation Rate (APLHGR),
  - 2) LCO 3.2.2, Minimum Critical Power Ratio (MCPR)(including power and flow dependent limits).
  - 3) LCO 3.2.3, Linear Heat Generation Rate (LHGR)(including power and flow dependent limits).
  - 4) LCO 3.2.4, Fraction of Core Boiling Boundary (FCBB)
  - 5) LCO 3.3.1.1, RPS Instrumentation (RPS), Function 2.b
  - 6) LCO 3.3.1.3, Periodic Based Detection System (PBDS)
- b. The analytical methods used to determine the core operating limits shall be those previously reviewed and approved by the NRC, specifically those described in the following documents.

(continued)

---