

July 23, 2003

Mr. J. A. Scalice
Chief Nuclear Officer and
Executive Vice President
Tennessee Valley Authority
6A Lookout Place
1101 Market Street
Chattanooga, TN 37402-2801

SUBJECT: SEQUOYAH NUCLEAR PLANT, UNITS 1 AND 2 - WITHDRAWAL OF AN
AMENDMENT REQUEST (TAC NOS. MB9087 AND MB9088) (TSC 03-02)

Dear Mr. Scalice:

By letter dated May 22, 2003, you applied for amendments to the Sequoyah Nuclear Plant, Units 1 and 2, Facility Operating License Nos. DPR-77 and DPR-79, respectively. The proposed change would have modified the limiting condition for operation for Technical Specification (TS) Section 3.7.5, "Ultimate Heat Sink." Tennessee Valley Authority requested that the maximum emergency raw cooling water temperature requirement in TS 3.7.5.b be increased from 83 degrees Fahrenheit (°F) to 87 °F and that the minimum ultimate heat sink water elevation in TS 3.7.5.a be increased from 670 feet to 674 feet. Subsequently, by letter dated July 17, 2003, you withdrew the amendment request.

The Commission has filed the enclosed Notice of Withdrawal of Application for Amendment to Facility Operating License with the Office of the Federal Register for publication.

Sincerely,

/RA/

Michael L. Marshall, Jr., Senior Project Manager, Section 2
Project Directorate II
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket Nos. 50-327 and 50-328

Enclosure: Notice of Withdrawal

cc w/encl: See next page

July 23, 2003

Mr. J. A. Scalice
Chief Nuclear Officer and
Executive Vice President
Tennessee Valley Authority
6A Lookout Place
1101 Market Street
Chattanooga, TN 37402-2801

SUBJECT: SEQUOYAH NUCLEAR PLANT, UNITS 1 AND 2 - WITHDRAWAL OF AN
AMENDMENT REQUEST (TAC NOS. MB9087 AND MB9088) (TSC 03-02)

Dear Mr. Scalice:

By letter dated May 22, 2003, you applied for amendments to the Sequoyah Nuclear Plant, Units 1 and 2, Facility Operating License Nos. DPR-77 and DPR-79, respectively. The proposed change would have modified the limiting condition for operation for Technical Specification (TS) Section 3.7.5, "Ultimate Heat Sink." Tennessee Valley Authority requested that the maximum emergency raw cooling water temperature requirement in TS 3.7.5.b be increased from 83 degrees Fahrenheit (°F) to 87 °F and that the minimum ultimate heat sink water elevation in TS 3.7.5.a be increased from 670 feet to 674 feet. Subsequently, by letter dated July 17, 2003, you withdrew the amendment request.

The Commission has filed the enclosed Notice of Withdrawal of Application for Amendment to Facility Operating License with the Office of the Federal Register for publication.

Sincerely,

/RA/

Michael L. Marshall, Jr., Senior Project Manager, Section 2
Project Directorate II
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket Nos. 50-327 and 50-328

Enclosure: Notice of Withdrawal

cc w/encl: See next page

DISTRIBUTION

PUBLIC	MMarshall	SCahill	EHackett	PDII-2 Reading
AHowe	DSolorio	RGoel	JTatum	BClayton (Hard Copy)
RDennig	OGC	ACRS		

ADAMS Accession No: ML032040008

OFFICE	PDII-2/PM	PDII-2/LA	PDII-2/SC
NAME	MMarshall	BClayton	AHowe
DATE	07/22/03	07/22/03	07/22/03

OFFICIAL RECORD COPY

UNITED STATES NUCLEAR REGULATORY COMMISSIONTENNESSEE VALLEY AUTHORITYDOCKET NOS. 50-327 AND 50-328NOTICE OF WITHDRAWAL OF APPLICATION FORAMENDMENT TO FACILITY OPERATING LICENSE

The U.S. Nuclear Regulatory Commission (the Commission) has granted the request of Tennessee Valley Authority (the licensee) to withdraw its May 22, 2003, application for proposed amendments to Facility Operating License Nos. DPR-77 and DPR-79 for the Sequoyah Nuclear Plant, Units 1 and 2, in Hamilton County, Tennessee.

The proposed amendment would have revised the limiting condition for operation for Technical Specification (TS) Section 3.7.5, "Ultimate Heat Sink." The licensee requested that the maximum emergency raw cooling water temperature requirement in TS 3.7.5.b be increased from 83 degrees Fahrenheit (°F) to 87 °F and that the minimum ultimate heat sink water elevation in TS 3.7.5.a be increased from 670 feet to 674 feet.

The Commission had previously issued a Notice of Consideration of Issuance of Amendment published in the FEDERAL REGISTER on July 8, 2003 (68 FR 40719). However, by letter dated July 17, 2003, the licensee withdrew the proposed change.

For further details with respect to this action, see the application for amendment dated May 22, 2003, and the licensee's letter dated July 17, 2003, which withdrew the application for license amendments. Documents may be examined, and/or copied for a fee, at the NRC's Public Document Room (PDR), located at One White Flint North, Public File Area O1 F21, 11555 Rockville Pike (first floor), Rockville, Maryland. Publicly available records will be accessible electronically from the Agencywide Documents Access and Management Systems (ADAMS) Public Electronic Reading Room on the internet at the NRC Web site,

<http://www.nrc.gov/reading-rm/adams/html>. Persons who do not have access to ADAMS or who encounter problems in accessing the documents located in ADAMS, should contact the NRC PDR Reference staff by telephone at 1-800-397-4209, or 301-415-4737 or by email to pdr@nrc.gov.

Dated at Rockville, Maryland, this 23rd day of July 2003.

FOR THE NUCLEAR REGULATORY COMMISSION

/RA/

Michael L. Marshall, Jr., Senior Project Manager, Section 2
Project Directorate II
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Mr. J. A. Scalice
Tennessee Valley Authority

SEQUOYAH NUCLEAR PLANT

cc:

Mr. Karl W. Singer, Senior Vice President
Nuclear Operations
Tennessee Valley Authority
6A Lookout Place
1101 Market Street
Chattanooga, TN 37402-2801

Mr. Pedro Salas, Manager
Licensing and Industry Affairs
Sequoyah Nuclear Plant
Tennessee Valley Authority
P.O. Box 2000
Soddy Daisy, TN 37379

Mr. James E. Maddox, Vice President
Engineering & Technical Services
Tennessee Valley Authority
6A Lookout Place
1101 Market Street
Chattanooga, TN 37402-2801

Mr. D. L. Koehl, Plant Manager
Sequoyah Nuclear Plant
Tennessee Valley Authority
P.O. Box 2000
Soddy Daisy, TN 37379

Mr. Richard T. Purcell
Site Vice President
Sequoyah Nuclear Plant
Tennessee Valley Authority
P.O. Box 2000
Soddy Daisy, TN 37379

Senior Resident Inspector
Sequoyah Nuclear Plant
U.S. Nuclear Regulatory Commission
2600 Igou Ferry Road
Soddy Daisy, TN 37379

General Counsel
Tennessee Valley Authority
ET 11A
400 West Summit Hill Drive
Knoxville, TN 37902

Mr. Lawrence E. Nanney, Director
Division of Radiological Health
Dept. of Environment & Conservation
Third Floor, L and C Annex
401 Church Street
Nashville, TN 37243-1532

Mr. Robert J. Adney, General Manager
Nuclear Assurance
Tennessee Valley Authority
6A Lookout Place
1101 Market Street
Chattanooga, TN 37402-2801

County Executive
Hamilton County Courthouse
Chattanooga, TN 37402-2801

Mr. Mark J. Burzynski, Manager
Nuclear Licensing
Tennessee Valley Authority
4X Blue Ridge
1101 Market Street
Chattanooga, TN 37402-2801

Ms. Ann P. Harris
341 Swing Loop Road
Rockwood, Tennessee 37854