JUL 1 1 2003



LR-N03-0309

U. S. Nuclear Regulatory Commission Document Control Desk Washington, DC 20555

Gentlemen:

MONTHLY OPERATING REPORT SALEM GENERATING STATION UNIT 1 DOCKET NO. 50-272

In compliance with Section 6.9, Reporting Requirements for the Salem Unit 1 Technical Specifications, the operating statistics for June 2003 are being forwarded.

Sincerely,

Lon Waldinger

**Operations Director** 

**Attachments** 

C Distribution

Jeay

**DOCKET NO.: 50-272** 

UNIT: Salem 1

DATE: <u>7/8/03</u>

COMPLETED BY: F. Todd

TELEPHONE: (856) 339-1316

# Reporting Period June 2003

# **OPERATING DATA REPORT**

Design Electrical Rating (MWe-Net)
Maximum Dependable Capacity (MWe-Net)

No. of hours reactor was critical No. of hours generator was on line (service hours) Unit reserve shutdown hours Net Electrical Energy (MWH)

1130				
1096				
Month	Year-to-date	Cumulative		
720	4343	146531		
720	4343	141894		
0	0	0		
800200 4703574		144607540		

### **UNIT SHUTDOWNS**

NO.	DATE	TYPE F=FORCED S=SCHEDULED	DURATION (HOURS)	REASON (1)	METHOD OF SHUTTING DOWN THE REACTOR (2)	CORRECTIVE ACTION/ COMMENT
		1				

#### (1) Reason

- A Equipment Failure (Explain)
- **B** Maintenance or Test
- C Refueling
- D Regulatory Restriction
- E Operator Training/License Examination
- F Administrative
- G Operational Error (Explain)
- H Other

#### (2) Method

- 1 Manual
- 2 Manual Trip/Scram
- 3 Automatic Trip/Scram
- 4 Continuation
- 5 Other (Explain)

**DOCKET NO.:** <u>50-272</u>

UNIT: Salem 1

DATE: <u>7/8/03</u>

COMPLETED BY: R. Ritzman

TELEPHONE: (856) 339-1445

## **Summary Of Monthly Operating Experience**

- Salem 1 started the month at approximately 100% power.
- On June 14, power was reduced to approximately 79% due to a 500kv line outage. Power was returned to approximately 100% later that day.
- On June 25, power was again reduced to approximately 79% due to a 500kv line outage. Power was returned to approximately 100% on June 26.
- At the end of the month, Salem 1 completed 229 days of continuous on-line operation.