

JUL 11 2003

LR-N03-0308



U. S. Nuclear Regulatory Commission  
Document Control Desk  
Washington, DC 20555

Gentlemen:

**MONTHLY OPERATING REPORT  
HOPE CREEK GENERATING STATION  
DOCKET NO. 50-354**

In compliance with Section 6.9, Reporting Requirements for the Hope Creek Technical Specifications, the operating statistics for June 2003 are being forwarded.

Sincerely,

A handwritten signature in black ink, appearing to read "Lon Waldinger".

**Lon Waldinger  
Operations Director**

Attachments

C Distribution

*JE24*

DOCKET NO.: 50-354  
 UNIT: Hope Creek  
 DATE: 7/8/03  
 COMPLETED BY: F. Todd  
 TELEPHONE: (856) 339-1316

Reporting Period June 2003

**OPERATING DATA REPORT**

Design Electrical Rating (MWe-Net)  
 Maximum Dependable Capacity (MWe-Net)  
 No. of hours reactor was critical  
 No. of hours generator was on line (service hours)  
 Unit reserve shutdown hours  
 Net Electrical Energy (MWH)

1083		
1049		
Month	Year-to-date	Cumulative
720	3497	124613
720	3364	122182
0	0	0
743334	3405765	123884456

**UNIT SHUTDOWNS**

NO.	DATE	TYPE F=FORCED S=SCHEDULED	DURATION (HOURS)	REASON (1)	METHOD OF SHUTTING DOWN THE REACTOR (2)	CORRECTIVE ACTION/ COMMENT

(1) Reason

- A - Equipment Failure (Explain)
- B - Maintenance or Test
- C - Refueling
- D - Regulatory Restriction
- E - Operator Training/License Examination
- F - Administrative
- G - Operational Error (Explain)
- H - Other

(2) Method

- 1 - Manual
- 2 - Manual Trip/Scram
- 3 - Automatic Trip/Scram
- 4 - Continuation
- 5 - Other (Explain)

DOCKET NO.: 50-354  
UNIT: Hope Creek  
DATE: 7/8/03  
COMPLETED BY: R. Ritzman  
TELEPHONE: (856) 339-1445

### **Summary Of Monthly Operating Experience**

- The unit entered the month at approximately 100% reactor power.
- On June 18, power was reduced to approximately 42% due to the "A" Emergency Diesel Generator Intercooler Pump seal leak. Power was returned to approximately 100% on June 20.
- On June 25, the unit was reduced to approximately 79% power due to a 500kv line outage. Power was returned to approximately 100% on June 26.
- On June 30, power was reduced to approximately 76% due to a 13.8kv breaker trip. Power was returned to approximately 100% later that day.
- At the end of the month, Hope Creek completed 47 days of continuous on-line operation.