



NRC 2003-0061

GL 97-02


July 11, 2003

U.S. Nuclear Regulatory Commission  
ATTN: Document Control Desk  
Washington, D.C. 20555

DOCKETS 50-266 AND 50-301  
POINT BEACH NUCLEAR PLANT, UNITS 1 AND 2  
MONTHLY OPERATING REPORTS

Attached are monthly operating reports for Units 1 and 2 of the Point Beach Nuclear Plant for the calendar month of June 2003.

Sincerely,



A. J. Cayia  
Site Vice President

KML

Attachment

cc: J. D. Loock, PSCW  
NRC Regional Administrator  
NRC Resident Inspector  
NRC Project Manager

JE24

## OPERATING DATA REPORT

DOCKET NO. 50-266  
UNIT NAME POINT BEACH NUCLEAR PLANT - UNIT 1  
DATE 07/02/03  
COMPLETED BY Kim M. Locke  
TELEPHONE 920-755-6420

REPORTING PERIOD June - 2003

1. DESIGN ELECTRICAL RATING (MWE-NET) 522.0  
2. MAXIMUM DEPENDABLE CAPACITY (MWE-NET) 516.0

	<u>MONTH</u>	<u>YEAR TO DATE</u>	<u>CUMULATIVE</u>
3. NUMBER OF HOURS REACTOR WAS CRITICAL	720.0	4,343.0	235,942.4
4. NUMBER OF HOURS THE GENERATOR WAS ON LINE	720.0	4,343.0	232,401.5
5. UNIT RESERVED SHUTDOWN HOURS	0.0	0.0	846.9
6. NET ELECTRICAL ENERGY (MWH)	366,566.5	2,215,812.5	107,767,121.5

DATA REPORTED AND FACTORS CALCULATED AS REQUESTED IN NRC GENERIC LETTER 97-02 DATED MAY 15, 1997

**UNIT SHUTDOWNS**

DOCKET NO. 50-266  
 UNIT NAME: Point Beach, Unit 1  
 DATE: 7/02/2003  
 COMPLETED BY: Kim M. Locke  
 TELEPHONE: 755-6420

REPORTING PERIOD: June 2003  
 (Month/Year)

NO.	DATE	TYPE F: FORCED S: SCHEDULED	DURATION (HOURS)	REASON (1)	METHOD OF SHUTTING DOWN (2)	CAUSE/CORRECTIVE ACTIONS COMMENTS
N/A	N/A	N/A	N/A	N/A	N/A	N/A

**(1) Reason**

- A. Equipment Failure (Explain)
- B. Maintenance or Test
- C. Refueling
- D. Regulatory Restriction
- E. Operator Training/license Examination
- F. Administrative
- G. Operational Error (Explain)
- H. Other (Explain)

**(2) Method**

- 1 Manual
- 2 Manual Trip/Scram
- 3 Automatic Trip/Scram
- 4 Continuation
- 5. Other (Explain)

**SUMMARY:**

Unit 1 average daily power for the month of June was 509.1 MWe.  
 Fish intrusion on 6/30/2003, reduced power to 95%  
 There was one LER on Unit 1 in the month of June, LER 266/2003-001-00 – Degraded Grid Voltage Relays.

## OPERATING DATA REPORT

DOCKET NO. 50-301  
UNIT NAME POINT BEACH NUCLEAR PLANT - UNIT 2  
DATE 07/02/03  
COMPLETED BY Kim M. Locke  
TELEPHONE 920-755-6420

REPORTING PERIOD June - 2003

1. DESIGN ELECTRICAL RATING (MWE-NET) 522.0  
2. MAXIMUM DEPENDABLE CAPACITY (MWE-NET) 518.0

	<u>MONTH</u>	<u>YEAR TO DATE</u>	<u>CUMULATIVE</u>
3. NUMBER OF HOURS REACTOR WAS CRITICAL	720.0	4,297.0	230,050.1
4. NUMBER OF HOURS THE GENERATOR WAS ON LINE	720.0	4,255.4	227,021.1
5. UNIT RESERVED SHUTDOWN HOURS	0.0	0.0	302.2
6. NET ELECTRICAL ENERGY (MWH)	368,435.5	2,153,594.5	106,941,398.0

DATA REPORTED AND FACTORS CALCULATED AS REQUESTED IN NRC GENERIC LETTER 97-02 DATED MAY 15, 1997

### UNIT SHUTDOWNS

DOCKET NO. 50-301  
 UNIT NAME: Point Beach, Unit 2  
 DATE: 7/02/2003  
 COMPLETED BY: Kim M. Locke  
 TELEPHONE: 755-6420

REPORTING PERIOD: June 2003  
 (Month/Year)

NO.	DATE	TYPE	DURATION (HOURS)	REASON (1)	METHOD OF SHUTTING DOWN (2)	CAUSE/CORRECTIVE ACTIONS
		F: FORCED S: SCHEDULED				COMMENTS
N/A	N/A	N/A	N/A	N/A	N/A	N/A

**(1) Reason**

- A. Equipment Failure (Explain)
- B. Maintenance or Test
- C. Refueling
- D. Regulatory Restriction
- E. Operator Training/license Examination
- F. Administrative
- G. Operational Error (Explain)
- H. Other (Explain)

**(2) Method**

- 1 Manual
- 2 Manual Trip/Scram
- 3 Automatic Trip/Scram
- 4 Continuation
- 5. Other (Explain)

**SUMMARY:**

Unit 2 average daily power for the month of June was 511.8 MWe.  
 Fish Intrusion on 6/30, reduced power to 91%  
 There was one LER on Unit 2 in the month of June, LER 266/2003-001-00 – Degraded Grid Voltage Relays