



Tennessee Valley Authority, Post Office Box 2000, Soddy-Daisy, Tennessee 37384-2000

July 17, 2003

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D.C. 20555

Gentlemen:

In the Matter of) Docket Nos. 50-327
Tennessee Valley Authority) 50-328

**SEQUOYAH NUCLEAR PLANT (SQN) - UNITS 1 AND 2 - WITHDRAWAL OF
TECHNICAL SPECIFICATION (TS) CHANGE 03-02, "REVISION OF
ULTIMATE HEAT SINK (UHS) TEMPERATURE AND ELEVATION
REQUIREMENTS"**

Reference: TVA letter to NRC dated May 22, 2003, "Sequoyah
Nuclear Plant (SQN) - Units 1 and 2 - Technical
Specification (TS) Change 03-02, "Revision of
Ultimate Heat Sink (UHS) Temperature and
Elevation Requirements"

On May 22, 2003, (referenced letter) TVA requested a TS change
to increase the maximum UHS temperature from 84.5 degrees
Fahrenheit (F) to 87.0 degrees F and revise the minimum river
level from 670 feet to 674 feet. Based on preliminary NRC
review, it appears that the request will require more than
minimal modification to support the NRC review. Therefore,
TVA withdraws the request to make the necessary changes and
will resubmit in the near future.

If you have any questions about this change, please telephone
me at (423) 843-7170 or Jim Smith at (423) 843-6672.

Sincerely,



Pedro Salas
Manager of Licensing
and Industry Affairs

cc: See page 2

D030

U.S. Nuclear Regulatory Commission
Page 2
July 17, 2003

cc: Framatome ANP, Inc.
P. O. Box 10935
Lynchburg, Virginia 24506-0935
ATTN: Mr. Frank Masseth

Mr. Michael L. Marshall, Jr., Senior Project Manager
U.S. Nuclear Regulatory Commission
Mail Stop O-8G9A
One White Flint North
11555 Rockville Pike
Rockville, Maryland 20852-2739

Mr. Lawrence E. Nanney, Director
Division of Radiological Health
Third Floor
L&C Annex
401 Church Street
Nashville, Tennessee 37243-1532