

5.0 ADMINISTRATIVE CONTROLS

5.3 Plant Staff Qualifications

- 5.3.1 Each member of the plant staff shall meet or exceed the minimum qualifications of Regulatory Guide 1.8, Revision 1, September 1975 except for (1) personnel who perform the function of shift technical advisor shall hold an SRO license and have a bachelors degree or equivalent in a scientific or engineering discipline with specific training in plant design, and response and analysis of the plant for transients and accidents, (2) the operations manager who shall meet the requirements of ANSI N18.1-1971, except that NRC license requirements are as specified in TS 5.2.2.e, and (3) the education and experience eligibility requirements for operator license applicants, and changes thereto, shall be those previously reviewed and approved by the NRC, specifically those referenced in NMC letter dated March 19, 2003.
- 5.3.2 For the purpose of 10 CFR 55.4, a licensed senior reactor operator (SRO) and a licensed reactor operator (RO) are those individuals who, in addition to meeting the requirements of TS 5.3.1, perform the functions described in 10 CFR 50.54(m).
-