



State of New Jersey

James E. McGreevey
Governor

Department of Environmental Protection
Division of Environmental Safety and Health
Radiation Protection and Release Prevention Element
Bureau of Nuclear Engineering
P. O. Box 415
Trenton, New Jersey 08625-0415
Tel (609) 984-7700
Fax (609) 984-7513

Bradley M. Campbell
Commissioner

July 3, 2003

United States Nuclear Regulatory Commission
Document Control Desk
Washington, DC 20555

Dear Sir:

Subject: Hope Creek Generating Station
Docket No. 50-354
License Change Request H02-011
Request to Eliminate the Post Accident Sampling System
Technical Specification Requirements

PSEG Nuclear LLC submitted the proposed change to the Hope Creek Technical Specifications by letter to the NRC dated March 13, 2003. The proposed change would delete Technical Specification 6.8.4.c, "Post Accident Sampling", and thereby eliminate the requirements to have and maintain the post accident sampling system at Hope Creek.


We noted, that in Attachment I to the March 13 letter, PSEG commits to develop and maintain contingency plans for obtaining and analyzing highly radioactive samples of reactor coolant, containment sump and containment atmosphere. Based on a conversation we had with PSEG Hope Creek Chemistry Personnel on June 20, 2003, it is our understanding that PSEG will install the shielding required to allow sampling of the normal sampling points during accident conditions based on an engineering evaluation.

It is our expectation, that following an accident the radionuclide mix be characterized within a reasonable period of time, say within 24 hours, by whatever means available. This mix must be defined prior to consideration of protective action recommendations being developed for ingestion pathway issues. We believe that the federal Department of Energy with their role in post accident radiation surveys and assessment would have similar needs.

I would also recommend that the federal Department of Energy be consulted as to their expectations for sampling. If you need to discuss the subject further, please contact me at (609) 984-7700 or Elliot Rosenfeld at (609) 984-7548.

ADD1

Sincerely,

A handwritten signature in black ink, appearing to read "Kent W. Tosch", with a long horizontal flourish extending to the right.

Kent W. Tosch, Manager
Bureau of Nuclear Engineering

c: Dr. Jill Lipoti, DEP
Dennis Zannoni, DEP
Dr. Robert Bores, NRC
Richard Ennis, NRC Licensing Project Manager
Mel Gray, Sr Resident Inspector
Gabor Salamon, PSEG Nuclear LLC
Don Daigler, DOE FRMAC