



State of New Jersey

James E. McGreevey
Governor

Department of Environmental Protection
Division of Environmental Safety and Health
Radiation Protection and Release Prevention Element
Bureau of Nuclear Engineering
P. O. Box 415
Trenton, New Jersey 08625-0415
Tel (609) 984-7700
Fax (609) 984-7513

Bradley M. Campbell
Commissioner

July 18, 2003

United States Nuclear Regulatory Commission
Document Control Desk
Washington, DC 20555

Dear Sir:

Subject: Hope Creek Generating Station
Docket No. 50-354
License Change Request H03-05
Request for Change to Technical Specifications
Control Room Emergency Filtration System

PSEG Nuclear LLC submitted the proposed change to the Hope Creek Technical Specifications by letter to the NRC dated July 9, 2003. The proposed change would revise Technical Specification 3.7.2, Control Room Emergency Filtration System by changing the allowable time that one control room emergency filtration subsystem due to an inoperable chiller unit from 7 days to 30 days.

The BNE has no comments on the proposed change. If you need to discuss the subject further, please contact Elliot Rosenfeld at (609) 984-7548.

Sincerely,

Kent W. Tosch, Manager
Bureau of Nuclear Engineering

A002

Ditribution

Dr. Jill Lipoti, DEP

Dennis Zannoni, DEP

Dr. Robert Bores, NRC

Richard Ennis, NRC Licensing Project Manager

Mel Gray, Sr Resident Inspector

Gabor Salamon, PSEG Nuclear LLC