



Entergy Operations, Inc.
1448 S.R. 333
Russellville, AR 72802
Tel 501 858 5000

2CAN070301

July 18, 2003

U.S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555

SUBJECT: Supplement to Amendment Request to Extend Allowed Outage Time for Low Pressure Safety Injection System
Arkansas Nuclear One, Unit 2
Docket No. 50-368
License No. NPF-6

REFERENCES: 1. Letter dated September 19, 2002 to the NRC, License Amendment Request to Extend Allowed Outage Time for Low Pressure Safety Injection System (2CAN090201)

Dear Sir or Madam:

By letter (Reference 1), Entergy Operations, Inc. (Entergy) proposed a change to the Arkansas Nuclear One, Unit 2 (ANO-2) Technical Specifications (TSs) to extend the allowed outage time (AOT) for the Low Pressure Safety Injection (LPSI) system.

On January 23, 2003, Entergy received a request for additional information related to the proposed change. The request included six questions which were determined to need formal response. An additional question was communicated per teleconference which is also included. Entergy's response to the seven questions is contained in Attachment 1.

There are no technical changes proposed. The original no significant hazards considerations included in Reference 1 is not affected by any information contained in the supplemental letter. There are new commitments contained in this letter which are reflected in Attachment 2.

If you have any questions or require additional information, please contact Dana Millar at 601-368-5445.

A001

I declare under penalty of perjury that the foregoing is true and correct. Executed on July 18, 2003.

Sincerely,



Sherrie R. Cotton

SRC/dm

Attachments:

1. Response to Request For Additional Information
2. List of Regulatory Commitments

cc: Mr. Thomas P. Gwynn
Regional Administrator
U. S. Nuclear Regulatory Commission
Region IV
611 Ryan Plaza Drive, Suite 400
Arlington, TX 76011-8064

NRC Senior Resident Inspector
Arkansas Nuclear One
P. O. Box 310
London, AR 72847

U. S. Nuclear Regulatory Commission
Attn: Mr. Thomas W. Alexion MS O-7D1
Washington, DC 20555-0001

Mr. Bernard R. Bevill
Director Division of Radiation
Control and Emergency Management
Arkansas Department of Health
4815 West Markham Street
Little Rock, AR 72205

Attachment 1

To

2CAN070301

Response to Request for Additional Information

**Response to Request for Additional Information Related to
Extending the Allowed Outage Time for the Low Pressure Safety Injection System**

Question 1:

What is the present annual average core damage frequency (CDF)?

Response 1:

The present annual average internal events and external Core Damage Frequency (CDF) and Large Early Release Frequency (LERF) values were provided by letter dated January 8, 2003 to the NRC (Supplement to Amendment Request Extension of Emergency Diesel Generator Allowable Outage Time (2CAN010303)). This information is repeated in Table 1-1, below.

Table 1-1

Risk Metric	Internal Events (excludes ATWS, ISLOCA)	External Events (includes ATWS, ISLOCA)
Nominal CDF (with nominal test and maintenance (T&M))	8.3E-6/rx-yr [Note 1]	5.1E-6/rx-yr [Note 2]
Nominal LERF (with nominal T&M)	9.0E-7/rx-yr [Note 2]	4.2E-7/rx-yr [Note 2]

Notes: 1. based on quantitative assessment of the Arkansas Nuclear One, Unit 2 (ANO-2) Probabilistic Safety Analysis (PSA) model using a quantification truncation of 1E-9
2. based on qualitative assessment using insights from ANO-2 Individual Plant Examination (IPE) and the IPE for External Events (IPEEE)

Question 2:

What is the present annual average large early release frequency (LERF)?

Response 2:

See the response to Question 1.

Question 3:

What is the proposed delta LERF/year?

Response 3:

Table 3-1, below, provides incremental conditional core damage probability (ICCDP), annual average delta core damage frequency (Δ CDF), incremental conditional large early release probability (ICLERP), and annual average delta large early release frequency (Δ LERF) values for both internal and external events risk contributors and for both preventative and

corrective maintenance conditions associated with the proposed ANO-2 Low Pressure Safety Injection (LPSI) Allowed Outage Time (AOT) extension to 7 days.

Table 3-1

Risk Metric	Preventative Maintenance		Corrective Maintenance	
	Internal Events (excludes ATWS, ISLOCA)	External Events (Includes ATWS, ISLOCA)	Internal Events (excludes ATWS, ISLOCA)	External Events (Includes ATWS, ISLOCA)
ICCDP	3.61E-08 [Note 1]	4.7E-09 [Note 2]	2.81E-07 [Note 1]	5.6E-09 [Note 2]
Annual Average Δ CDF (/rx-yr) [Note 3]	1.08E-07 [Note 1]	1.4E-08 [Note 2]	1.85E-07 [Note 1]	3.7E-09 [Note 2]
ICLERP	3.8E-09 [Note 2]	4.6E-10 [Note 2]	2.8E-08 [Note 2]	5.5E-10 [Note 2]
Annual Average Δ LERF (/rx-yr) [Note 3]	1.1E-08 [Note 2]	1.4E-09 [Note 2]	1.9E-08 [Note 2]	3.6E-10 [Note 2]

- Notes:
1. These values were provided by letter dated September 19, 2002 (License Amendment Request to Extend Allowed Outage Time for Low Pressure Safety Injection System (2CAN090201)); they are repeated here for completeness. These values are based on quantitative assessment of the ANO-2 PSA model using a quantification truncation of 1E-9.
 2. These values are based on qualitative assessment using insights from ANO-2 IPE and the ANO-2 IPEEE.
 3. The annual average Δ CDF and annual average Δ LERF values assume 1.5 events/year/train for preventative maintenance and 0.33 events/year/train for corrective maintenance.

The bases for qualitative assessments are provided in the response to Question 6.

These results indicate that the risk impact of increasing the LPSI AOT from 72 hours to seven (7) days is not significant. When transition and shutdown risks were considered, it was expected that performing LPSI maintenance at-power, rather than during shutdown conditions, would be either risk beneficial, or at the very least, risk neutral.

Question 4:

What is the proposed incremental conditional large early release probability (ICLERP)?

Response 4:

See the response to Question 3.

Question 5:

Provide the above information in addition to the delta CDF/year and the incremental conditional core damage probability (ICCDP) for external events. (See the emergency diesel generator allowable outage time application for external events.)

Response 5:

See the response to Question 3.

Question 6:

Provide additional external events information as is presently being prepared for the emergency diesel generator allowable outage time application, as follows:

- a. Please describe the methodology used to generate the external events risk numbers, including the final numbers generated for each external event. If aspects of the external events analysis approach used in this application are substantially different from the methods described in previous recent applications (e.g., the power uprate application), please explain and justify the use of the different approach.
- b. For the fire analyses, as an alternative to justifying the use of a different approach discussed in Question 6.a above, the licensee could describe how this application would impact each of the unscreened fire quadrant analyses and results identified in the June 28, 2001, letter to the U.S. Nuclear Regulatory Commission (NRC) regarding its power uprate application. The NRC staff notes that in this letter, the licensee identified 17 unscreened fire quadrants involving 15 fire areas and provided the associated post-uprate core damage frequency for each quadrant.

Response 6:

Non-Modeled Contributors to ICCDP and Annual Average Δ CDF

The ANO-2 PSA model does not address the risk associated with the external events, including seismic events, internal fires, and other external events (i.e., high winds, external flooding, and accidents involving nearby industries, transportation, and military facilities). Nor does this model address the risk associated with several other risk contributors, namely Anticipated Transients Without Scram (ATWS) scenarios, Interfacing System Loss of Coolant Accidents (ISLOCAs), and High and Medium Energy Line Breaks (HELBs and MELBs). Qualitative analyses were performed to assess the risk impact of these non-modeled events on extending the current LPSI AOT. These analyses are considered qualitative, since they are relatively simplistic and not based on comprehensive and detailed fault tree/event tree models. The intent of these methods and results was to provide an order-of-magnitude assessment of the risk associated with these risk contributors.

This methodology is essentially the same as that used for the ANO-2 Emergency Diesel Generator (EDG) AOT extension reported to the NRC by letter dated May 22, 2003 (2CAN050303). Differences in the methodology are due to differences in the risk issues associated with extending the EDG and LPSI AOTs. Since the methodology was previously

described in the May 22, 2003 letter, the discussion below focuses on the differences in the use of this methodology for the LPSI application.

Removing a LPSI train from service does not affect the risk associated with any of the external events listed above. This conclusion is based on the following observations:

- The LPSI system has two safety functions:
 - (1) the LPSI emergency core cooling (ECC) mode provides reactor coolant system (RCS) makeup during the injection phase of a large break LOCA (LBLOCA) and
 - (2) the LPSI shutdown cooling (SDC) mode provides a means of cooling the RCS during shutdown conditions.
- None of the non-modeled events (including external events) cause or involve a LBLOCA. Thus, degradation of the LPSI emergency core cooling function due to the removal of a LPSI train from service does not affect the risk associated with any of the non-modeled risk contributors.
- The safe end state for most of the non-modeled events is the Hot Standby (HSB) condition. Thus, degradation of the LPSI emergency core cooling function due to the removal of a LPSI train from service affects only those non-modeled events which require entry into the SDC mode as a safe end state.

It should be noted that at ANO-2 the HSB condition is considered to be the safe end state for all but a few accident scenarios. The position is consistent with the NUREG-0933 Item A-31 statement that the "safe shutdown for a nuclear power plant following an accident not related to a LOCA has been typically interpreted as achieving a 'hot-standby' condition (i.e., the reactor is shut down, but system temperature and pressure are still at or near normal operating values)." The ANO-2 PSA model is consistent with this position. This position also applies to accidents not included in the ANO-2 PSA model. Thus, entry into the SDC mode is not generally required for successful mitigation of any of the non-modeled events, including external events. A review of each of the non-modeled risk contributors was performed using insights from the ANO-2 IPEEE results, where available, in order to assure that this general rule applies to each of the non-modeled risk contributors. The effect of each non-modeled event to cause either a LBLOCA or a Steam Generator Tube Rupture (SGTR) event, both of which require the use of LPSI, was considered.

A review of the external events indicates that none inherently require entry into the SDC mode for successful mitigation. All can be modeled as a special transient event that is already included in the ANO-2 PSA model. Specific observations for each of the non-modeled risk contributors follow:

- A fire event is assumed to cause a transient that involves the failure of a specific set of components. None of these failures directly cause a LBLOCA or a SGTR. The ANO-2 IPEEE fire risk analysis assumed that the HSB condition was a safe end state; thus, LPSI failures do not appear in any of the fire risk analysis cutset results for any fire initiator. Hence, the effect of removing a LPSI train from service has essentially no impact on the assessed fire risk. Given this conclusion, the need for a detailed assessment of the fire risk, requested in Question 6b, was deemed not necessary.

- A seismic event is also a special transient event. No seismic event smaller than the 0.3g Review Level Earthquake (RLE) was identified to result in a LBLOCA or SGTR. Thus, no seismic event within the scope of the ANO-2 IPEEE study is expected to require entry into SDC mode. Given that a seismic event large enough to result in a LBLOCA or SGTR would probably also disable the LPSI system or systems that support it, the effect of removing a LPSI train from service has essentially no impact on the seismic risk.
- The case is similar for internal floods and other external events (i.e., high winds, external flooding, and accidents involving nearby industries, transportation, and military facilities). None result in a LBLOCA or SGTR event and all could be modeled as a special transient event. Hence, the effect of removing a LPSI train from service has essentially no impact on the risk of the other external events.
- The case is similar for HELB and MELBs and the conclusions regarding the impact of LPSI unavailability are the same.
- The remaining risk contributors not included in the ANO-2 PSA model, the ATWS and ISLOCA events, require additional consideration. This is provided below.

ISLOCA

The ANO-2 IPE identified three ISLOCA scenarios:

- (1) LPSI system injection line failures,
- (2) SDC suction line failures, and
- (3) Reactor Coolant Pump (RCP) seal cooler failures.

The first two situations contribute to core damage significantly only if either involves the loss of reactor coolant system (RCS) inventory outside of the containment building. Without mitigation, if RCS inventory is lost outside of the containment, core damage will occur regardless of LPSI availability. For these events, if the break is isolated, the RCS repressurizes and a LPSI train is not required to mitigate either of the events. The last situation does not result in a LBLOCA and, as such, does not require the LPSI ECC mode. Since the HSB condition is a safe end state, the LPSI SDC mode is not required for this event. In conclusion, removing a LPSI train from service when at power does not significantly increase the risk associated with an ISLOCA, because the LPSI train is not needed to mitigate any of these ISLOCA events.

ATWS

A scoping level analysis of the ANO-2 ATWS event was performed as part of the ANO-2 IPE reported to the NRC by letter dated August 28, 1992 (2CAN089201). This analysis assumed that successful termination of the ATWS event required entry into the SDC mode. Thus, an insight from this analysis is that the proposed extension of the LPSI AOT will impact the plant risk due to an ATWS.

The nominal ANO-2 ATWS CDF is estimated to be 1.59E-06/rx-yr. This value is reported to the NRC by letter dated May 22, 2003 (2CAN050303).

The effect of removing a LPSI train from service on the ATWS contribution to CDF was assessed by adjusting the Long Term Cooling (LTC) event probabilities in the ATWS event tree logic. The LTC event accounts for the failure of the shutdown cooling function following an ATWS event.

The CDF impact of removing a single LPSI train from service for Preventative Maintenance (PM) and for Corrective Maintenance (CM) on the non-modeled (i.e., ATWS) risk contributors is provided in Table 6-1, below. The value reported represents the larger of the LPSI Train A or Train B CDF values for the PM and CM cases. It should be noted that basic events representing the common cause failure of LPSI pumps and injection valves were set to the values of their respective common cause beta values in the CM cases.

Table 6-1

Non-Modeled Contributor	Instantaneous CDF (/rx-yr)		
	Nominal	LPSI Train PM	LPSI Train CM
ATWS	1.59E-06	1.84E-06	1.88E-06

Since the ATWS contributor is the only non-modeled risk contributor affected by the LPSI AOT extension, the ATWS instantaneous CDF values reported in Table 6-1 represent the risk impact of the LPSI AOT extension that is not accounted for in the ANO-2 PSA model.

These results were used to generate an estimate for the non-modeled portion of the ICCDP and annual average Δ CDF associated with the LPSI AOT extension. The non-modeled portions of the ICCDP values associated with removing a single LPSI train from service for PM and for CM for a 7 day AOT were calculated as follows:

$$\begin{aligned} \text{ICCDP NonModeled PM} &= (7 \text{ days}/365 \text{ days/yr}) * (1.84\text{E} - 06/\text{yr} - 1.59\text{E} - 06/\text{yr}) \\ &= 4.7\text{E} - 09 \end{aligned}$$

$$\begin{aligned} \text{ICCDP NonModeled CM} &= (7 \text{ days}/365 \text{ days/yr}) * (1.88\text{E} - 06/\text{yr} - 1.59\text{E} - 06/\text{yr}) \\ &= 5.6\text{E} - 09 \end{aligned}$$

The non-modeled portions of the annual average Δ CDF values for preventative maintenance and for corrective maintenance on an ANO-2 LPSI pump for a 7 day AOT were calculated as follows:

$$\begin{aligned} \text{Annual Average } \Delta\text{CDF for LPSI NonModeled PM} &= (2)(1.5/\text{rx} - \text{yr})(\text{PM ICCDP}) \\ &= 1.4\text{E} - 08/\text{rx} - \text{yr} \end{aligned}$$

$$\begin{aligned} \text{Annual Average } \Delta\text{CDF for LPSI NonModeled CM} &= (2)(0.33/\text{rx} - \text{yr})(\text{CM ICCDP}) \\ &= 3.7\text{E} - 09/\text{rx} - \text{yr} \end{aligned}$$

Note that these values assume 1.5 entries per year into the 7 day AOT for PM activities on each of the LPSI trains and 0.33 entries per year into the 7 day AOT for CM activities on

each of the LPSI trains. This is consistent with the assumptions reported to the NRC by letter dated September 19, 2002 (2CAN090201).

ICLERP and Annual Average Δ LERF

The ANO-2 PSA model does not generate LERF results. The impact of the LPSI AOT extension on ICLERP and annual average Δ LERF were estimated by generating LERF/CDF factors (hereafter called "LERF factors"). Several LERF factors were generated:

- (1) a SGTR LERF factor – this factor is relatively high for SGTRs, since the fission products bypass the containment,
- (2) a Station Blackout (SBO) LERF factor – active containment mitigative functions are unavailable during SBO events increasing the ratio of LERF to CDF, and
- (3) an "Other" LERF factor representing core damage contributors except those associated with SGTRs and SBOs.

The SGTR LERF factor was estimated as the ratio of the SGTR event large release frequency (LRF) and the SGTR CDF value using results from the ANO-2 IPE. The SGTR LERF factor was calculated to be 0.500.

The SBO LERF factor was estimated as the ratio of the SBO event LRF and the SBO CDF value using results from the ANO-2 IPE. The SBO LERF factor was calculated to be 0.0974.

The "Other" LERF factor was estimated as the ratio of the LRF and CDF associated with other core damage contributors using results from the ANO-2 IPE. The "Other" LERF factor was also calculated to be 0.0650. It is smaller than either the SGTR or SBO LERF factors.

Note that use of the LRF values, rather than the LERF values, to generate the LERF factor conservatively overestimates the values of LERF factors, since the LRF value includes both the large early and large late releases.

In order to estimate the LERF values, both the modeled and the non-modeled core damage contributors were parsed into two groups: core damage events involving containment bypass scenarios (namely, SGTRs) and those involving SBOs and other core damage contributors. The LERF values were then calculated as the sum of the products of the CDF values and their respective LERF factors, i.e.,

$$\text{LERF} = (\text{SGTR LERF factor}) * (\text{SGTR CDF}) \\ + (\text{SBO LERF factor}) * (\text{SBO and Other CDF Contributors})$$

Note that this approach conservatively overestimates LERF, since the SBO LERF factor is applied to both SBO and "Other" core damage contributors and is larger than the "Other" LERF factor.

The modeled internal events PM and CM ICLERP and the annual average Δ LERF values were estimated in a similar manner, i.e. the sum of the products of the SGTR and other ICCDP and annual average Δ CDF values and their respective LERF factors. The resulting

modeled internal events ICLERP and annual average Δ LERF values are provided in the "Internal Events" columns of Table 3-1.

The above equation was also employed to calculate the LERF associated with the non-modeled risk contributors. Since the only significant non-modeled CDF contributor was the ATWS event, a special case of the above equation was used to estimate the non-modeled LERF, i.e.,

$$\text{Non - modeled LERF} = (\text{SBO LERF factor}) * (\text{ATWS CDF})$$

Note that the SBO LERF factor was assumed applicable for ATWS core damage scenarios, because active containment mitigation functions are unavailable during a SBO event and they are available in an ATWS event.

For the non-modeled events, the PM and CM ICLERP and the annual average Δ LERF values were estimated in a similar manner, i.e. the product of the ATWS ICCDP and annual average Δ CDF values and the SBO LERF factor. The resulting ICLERP and annual average Δ LERF values are provided in the "External Events" column of Table 3-1.

Question 7:

Describe how Entergy will satisfy the "at power" compensatory measures included in Section 6.4 of CE NPSD-995, Rev. 01.

Response 7:

The Equipment Out of Service (EOOS) model provides the configuration risk management program tool at ANO for compliance with 10CFR50.65, particularly with respect to paragraph (a)(4). The program provides assurance that risk significant plant equipment configurations are precluded or minimized when plant equipment is removed from service. A detailed description of the risk configuration management program was provided to the NRC by letter dated September 19, 2002, License Amendment Request to Extend Allowed Outage Time for Low Pressure Safety Injection System (2CAN090201). Entergy has not identified any high-risk configurations associated with the proposed AOT extension. However, when at power (i.e., in Mode 1) the following actions will be taken prior to taking a LPSI train out of service for maintenance purposes. These actions will not be taken unless entry into the AOT is expected to extend beyond the current 72 hour AOT.

1. All safety injection tanks (SITs) will be verified operable.
2. All emergency feedwater (EFW) sources will be verified operable.
3. Operations will perform a brief with the appropriate maintenance personnel in attendance to discuss the impact associated with unavailable components and flow paths. The brief will also include consideration of the actions that would need to be taken to return the affected LPSI train to functional use should the need arise.
4. Parts and tools will be pre-staged when appropriate to minimize outage time.

Generally, the LPSI AOT will not be entered unless these actions are satisfied. However, it should be recognized that unforeseen circumstances may arise that prohibit complying with these actions.

It is standard operational practice to verify redundant train operability along with the required support systems prior to removing any TS components regardless of the length of time a TS component is removed from service. If the redundant LPSI train is not operable, the maintenance activity will not be performed.

In all cases maintenance activities are managed and assessed as required by Entergy's risk management program and 10CFR50.64(a)(4). When practical, valves are placed in their optimum position and maintenance activities are efficiently scheduled.

Attachment 2

To

2CAN070301

List of Regulatory Commitments

List of Regulatory Commitments

The following table identifies those actions committed to by Entergy in this document. Any other statements in this submittal are provided for information purposes and are not considered to be regulatory commitments.

COMMITMENT	TYPE (Check one)		SCHEDULED COMPLETION DATE (If Required)
	ONE- TIME ACTION	CONTINUING COMPLIANCE	
<p>When at power and LPSI train maintenance activities are scheduled to extend beyond 72 hours the following actions will be taken:</p> <ol style="list-style-type: none"> 1. All safety injection tanks (SITs) will be verified operable. 2. All emergency feedwater (EFW) sources will be verified operable. 3. Operations will perform a brief with the appropriate maintenance personnel in attendance to discuss the impact associated with unavailable components and flow paths. The brief will also include consideration of the actions that would need to be taken to return the affected LPSI train to functional use should the need arise. 4. Parts and tools will be pre-staged when appropriate to minimize outage time. 		x	