



Duke Energy Corporation  
526 South Church Street  
P.O. Box 1006  
Charlotte, NC 28201-1006

RECEIVED  
JUL 31 AM 8:46

Rules and Directives

July 23, 2003

6/24/03  
68 FR 37590  
①

Chief, Rules and Directives Branch  
Division of Administrative Services  
Office of Administration, Mail Stop: T-6 D 59  
U. S. Nuclear Regulatory Commission  
Washington, DC 20555-0001

**Subject:** Comments on Notice of Opportunity To Comment on Model Safety Evaluation on Technical Specification Improvement Regarding Extension of Reactor Coolant Pump Motor Flywheel Examination for Westinghouse Plants Using the Consolidated Line Item Improvement Process, 68FR37590, dated June 24, 2003

Duke Energy Corporation offers the following comment relative to the above Federal Register notice of June 24, 2003.

The model safety evaluation, the WCAP and TSTF-421 should be expanded to include B&W-designed nuclear power plants equipped with Westinghouse reactor coolant pump motors. This would be consistent with the industry's and the NRC's first initiative to extend the frequency of inservice inspection examinations of the reactor coolant pump flywheels. This first initiative was approved by the NRC in 1996 and was based on WCAP-14535A.

Please address any questions to L. B. Jones at 704 382-4753.

Very truly yours,

*James J. Hickey*  
W. R. McCollum, Jr. *for*  
Senior Vice President  
Nuclear Support

*Template = ADM-013*

*E-RIDS = ADM-03  
Call = W. Reckley (WDR)*

U. S. Nuclear Regulatory Commission  
July 23, 2003  
Page 2

bxc:

L. E. Nicholson – ON03RC  
C. J. Thomas – MG01RC  
G. D. Gilbert – CN01RC  
J. S. Warren – EC05O  
ELL