

Monticello Nuclear Generating Plant Operated by Nuclear Management Company, LLC

July 22, 2003

L-MT-03-055 10 CFR Part 50 Section 50.55a(a)(3)

US Nuclear Regulatory Commission Attn: Document Control Desk Washington, DC 20555

MONTICELLO NUCLEAR GENERATING PLANT DOCKET 50-263 LICENSE No. DPR-22

RESPONSE TO REQUEST FOR ADDITIONAL INFORMATION REGARDING INSERVICE TESTING RELIEF REQUEST PR-06 FOR THE FOURTH 10-YEAR INTERVAL – HPC PUMP TESTING (TAC NO. MB9550)

- Reference 1: NMC Letter to NRC, "Relief Request No. PR 06 for the Fourth 10-Year Inservice Testing Interval - High Pressure Coolant Injection Pump Testing", dated May 6, 2003
- Reference 2: NRC email to NMC, "RR # PR-06 HPCI Pump Testing Draft RAI (TAC MB 9550)," dated July 15, 2003
- Reference 3: NRC email to NMC, "RR # PR-06 HPCI Pump Testing Draft RAI (TAC MB 9550) -Question #2," dated July 15, 2003

Reference 1 requested NRC authorization of an alternative testing methodology for the Monticello Nuclear Generating Plant (MNGP) High Pressure Coolant Injection (HPC) pump in accordance with 10 CFR 50.55a(a)(3)(i). The alternative testing employs a methodology that follows the guidelines of Code Case OMN-9, "Use of a Pump Curve for Testing."

References 2 and 3 requested the Nuclear Management Company, LLC (NMC) to provide additional information regarding the subject relief request.

Attachment 1 to this letter contains the NMC response to the requests for additional information.

This letter does not contain any new commitments.

4041

USNRC Page 2

If you have any questions regarding this submittal please contact John Fields, Senior Licensing Engineer at (763) 295-1663.

Jan Hillon

David L. Wilson Site Vice President Monticello Nuclear Generating Plant

cc: Regional Administrator-III, NRC NRR Project Manager, NRC Sr. NRC Resident Inspector, NRC State of Minnesota Boiler Inspector Hartford Insurance

Attachment 1 - NMC Responses To NRC Request For Additional Information

Attachment 1

¥ . . . ¥ S

## NUCLEAR MANAGEMENT COMPANY, LLC MONTICELLO NUCLEAR GENERATING PLANT DOCKET 50-263

# JULY 22, 2003

### NMC RESPONSES TO NRC REQUEST FOR ADDITIONAL INFORMATION

.

1 page follows

Attachment 1

## NMC RESPONSES TO NRC REQUEST FOR ADDITIONAL INFORMATION

### NRC Request #1:

. 1

ASME OM Code - 1995, paragraph ISTB 4.3 (e)(1) specifies, "reference values shall be established within  $\pm 20$  percent of pump design flow rate for the comprehensive test." What values within  $\pm 20$  percent of pump design flow rate did NMC analyze to establish the high-pressure coolant injection pump P-209 reference curve?

#### NMC Response:

The Monticello Nuclear Generating Plant (MNGP) high pressure coolant Injection (HPC) pump has a required flow rate of 3000 gpm. This value is the Inservice Testing (IST) pump design flow rate. Applying the +/- 20% reference value band from ISTB 4.3(e)(1) to the IST pump design flow rate yields a range of 2400 gpm to 3600 gpm. The Pump Flow Reference Point range used in Relief Request PR-06 (Reference 1, Table 2) is 2900 gpm to 3300 gpm. Therefore, the values analyzed in the Pump Flow Reference Point range are within +/-20% of the IST design flow rate for the MNGP HPC pump.

#### NRC Request #2:

In Attachment 1 under Component Identification of the May 6 submittal, NMC specifies the Item Numbers for PR-06 to be "ISTB 5.2.3(a), ISTB 5.2.3(b)."

Should the Item Numbers be "ISTB 5.2.2(a), ISTB 5.2.3(a)" because those relate to the reference point for the Group B and Comprehensive pump tests?

#### NMC Response:

The Item Numbers listed in the Component Identification Section of Relief Request PR-06 (Reference 1) were reviewed and were determined to be typographical errors. The Item Numbers line should read "ISTB 5.2.2, ISTB 5.2.3." The Code Requirements section of Reference 1, contains the correct ISTB section numbers and cites the applicable code requirements.

### References

1. NMC Letter to NRC, "Relief Request No. PR 06 for the Fourth 10-Year Inservice Testing Interval - High Pressure Coolant Injection Pump Testing", dated May 6, 2003