JUL-06-1995 11:46

RSSI

PSS: HOFTON FORE IL USA

١

09 365 1391 P.C1

. • .

63-2 West Oakton Street Morton Grove, IL: c0033-2723 708-965-1999 Fax 706-965-1991

July 6, 1995

steven N. Baggett Sealed Source Safety Section, MS T-8 F5 U.S. Nuclear Regulatory Commission 11545 Rockville Pike Rockville, MD 20852

VIX FAX 301-415-5369

RE: Temet USA Inc. Mail Control Number 021676

Dear Mr. Baggett:

This letter is in response to our June 14, 1995 telephone conversation regarding an application for registration of the Environics Sensor Unit to be distributed to persons exempt from license by Temet USA Inc.

1) Pursuant to 10 CFR 32.26(b)(8), the total quantity of byproduct material expected to be distributed in the Sensor Unit annually is 3.2 Ci.

2) The labeling shall contain the text in Section III.C. of our application dated 31 May, 1995. Please disregard the label artwork showing different text.

3) We are revising the safety analysis performed pursuant to 10 CFR 32.27. The safety analysis in Section III.L. of our application describes storage of multiple units in our stockroom which serves as the distribution center. In the analysis it was assumed that 10 units are stored at all times.

In the revised safety analysis it is now assumed that as many as 25 units may be present at all times and it is possible that a brief period may occur when up to 1,000 units are stored for up to one week. The dose to an individual from the storage of these quantities is calculated as follows:

For continuous storage of 25 units: (2,000 hours per year) (4 x 10<sup>-8</sup> rem/hour-unit) (25 units) = 2 x 10<sup>-3</sup> rem/year For one week storage of 1,000 units: (40 hours/year) (4 x 10<sup>-8</sup> rem/hour-unit) (1,000 units) = 1.6 x 10<sup>-3</sup> rem/year

When these doses are added, the total dose to an individual is  $3.6 \times 10^{-3}$  rem/year. This conservative estimate is below the

11 M. 2.V.LS

9602160145 950731 PDR RC \* PDR SSD PDR JLL-06-1995 11:40

REEL MATCH GADNE IL USA

TU: 465 1.341 - 1.12

. . .

Steven N. Baggett July 6, 1995 Page Two RSSI

0.005 limit in 10 CFR 32.28 Column I. These doses are to individuals who are working in a licensed facility. Distribution and short term storage at other sites will result in doses to any individual lower than this estimate.

Other portions of the safety analysis for storage in this fireprotected stockroom are unchanged.

4) Copies of all records of quality control tests performed by the manufacturer in Finland shall be retained by Temet USA Inc. Temet USA Inc. shall perform the following quality control tests on 100 percent of Sensor Units prior to transfer to persons exempt from license:

a) Visual inspection and external dimensional verification to confirm that Sensor Unit is as described in the registry sheet.

b) Leak test Sensor Unit inlet and outlet to confirm that leakage does not exceed 0.005 µC1.

c) Verification that labels are correct.

5) A letter dated 29 March, 1994 and previously submitted with an earlier application was inadvertently attached to the application dated 31 May, 1995. It was not intended that this letter be attached to the application and we are asking that it be separated from the application.

In response to your questions, this letter described tests performed for the Army at the Edgewood Arsenal. In these tests, Sensor Units were exposed to chemical agents to which the Sensor Unit might be exposed to in the field. Following exposure, the Units were leak tested. The only documentation available from the Edgewood Arsenal is the one page attachment to the 29 March, 1994 letter indicating that no leakage was detected equal to or above 0.005  $\mu$ Ci counted in a C-14 window on a liquid scintillation spectrometer.

If you have any further questions or require additional information, please call me at 708-965-1999.

Sincerely,

Chi cht

Eli A. Port, CHP, CIH, P.E.

JUL-06-1995 11:47

1.0

REEL MONTON GROUP ILL USA

١

#### SENSOR UNIT QUALITY CONTROL CHECKS

....

SN\_\_\_\_\_ DATE:\_\_\_\_\_'

A) Results of visual inspection and external dimensional verification for conformance with registry sheet:

(1.5 cm L x 11 cm W x 4.5 cm H)

B) Leak test results (< 0.005  $\mu$ Ci)

C) Label Verification

I. Sensor Unit label II. System Label III. Package Label

Reviewed by

Date: / /

07/13/95 15:22 2703 7396667

TEMET USA Inc.

## Temet USA. Inc.

US Nuclear Regulatory Commission Atta: Scaled Source Safety Section, MS T-8 F5 (Mr. Stave Baggett) 11545 Rockville Pike Ruckville, MD 20852 13 July 95

Re Temet USA, Inc. Mail control number 021676

Doar Mr. Baggett

This letter is in response to a recent telephone call from Mr. Michael Perkins of your office. He raised two insues in his call.

1). Mr. Eli A. Port, RSSL, our consultant is authorized to make commitments regarding license conditions and device registration for Temet USA, Inc. and should be contacted if there are questions or requests for information.

2. Mr. Perkins indicated that drawings are needed but did not specify which drawings the NRC still requires. It was my understand the drawings previously submitted in the Application for Device Registration, were sufficient. Mr. Port has informed are that he has been attempting to reach both you and Mr. Perkins regarding Mr. Perkins' request and has received no responses to his telephone messages. Please call Mr. Port to discust Mr. Perkins' request for drawings.

It was my understanding that the device review for the Sensor Unit could be completed quickly when the second set of information, Mr. Port submitted was received by your office. The need to have the Sensor Unit approved and registered is becoming critical. If you have any further questions or require additional information, pleas call Mr. Port at 708-965-1999.


Thank you in advance for any help you can render to expedite the approval.

Sincerely,

Richard C. Krabe

Program Manager Tule

RSSI, Mr. Port Environics Oy



1.

16

737 Walter Baad, Sube 1, P (1 Ber 638, Great Falls, VA 22066 U.S.A. Telephone: (783) 753-6600 Telephen: (783) 753-6667 2001

ĺ

# 45-51

## Temet USA. Inc

June 5, 1995

Steven M. Baggett Sealed Source Safety Section, MS T-8 F5 U.S. Nuclear Regulatory Commission 11545 Rockville Pike Rockville, MD 20852

#### RE: Application for Registration of Environics Oy Sensor Unit Mail Control Number 021676

Dear Mr. Baggett,

A request for the radiation safety evaluation and registration of the Environics Sensor Unit detector module is attached. This information reactivates mail control number 0211676 and supplies additional information requested by your office in conversations with Eli Port, our consultant, and myself.


This is also a request for a license pursuant to 10 CFR 30.26 to distribute the Sensor Unit to persons exempt from license pursuant to 10 CFR 30.20.

· · · 1

If you have any questions or require additional information about either application for device registration or the license to distribute to persons exempt from license please contact myself at 703-759-6000 or Eli Port at 708-965-1959

Sincerely. 1.1

Richard C. Krahe Program Manager



737 Walker Road, Suite 1, P.O. Box 439, Great Falls, VA 22066 U.S.A. Telephone: (703) 759-6000 Telefax: (703) 759-6867

### Request for Radiation Safety Evaluation and Registration

١

. . .

of the

Sensor Unit Chemical Agent Detector Module

Ternet USA Inc. 737 Walker Road Great Falls, VA 22066 (703) 759-6000

#### **II. SUMMARY DESCRIPTION**


#### A. Written Description

The Sensor Unit (Pack) is manufactured in Finland by Environics OY and will be distributed in the United States to persons exempt from license by Temet USA Inc. The Sensor Unit is a detector module that is incorporated into instrumentation systems to detect harmful and toxic gases and vapors. It has the ability to detect life and health threatening hazards and enables the taking of protective action. These hazards include common chemical warfare agents such as nerve and blister agents and on-the-job hazards such as waste anesthetic gases and products of combustion. The Sensor Unit will be used in larger portable and fixed systems and is normally not separated from the larger system except for replacement. The Sensor Unit in the larger system only moves as a component of the system.

Air is drawn through the Sensor Unit by an externally mounted sampling pump. Air is heated, flows through an ionization chamber containing a 160  $\mu$ Ci Am-241 source in a source bed and into a detector chamber adjacent to the source bed. The source bed also incorporates a heater and the sampling passages. The current in the detector chamber is affected by ion capture by particles and gases passing through the ionization chamber. The analytical system in which the Sensor Unit is incorporated includes software to perform analyses for selected gases and aerosols.

The source, ISO/ANSI classification C64646, is cut and shaped to fit in the ionization chamber in the source bed. A fiberglass/epoxy resin composite chamber cover is bolted to the source bed locking the source into position. The source bed assembly is partially shielded with 1 mm lead and fastened into the stainless steel Sensor Unit housing with stainless steel screws. The Sensor Unit is 15 cm long, 11 cm wide, and 4.8 cm high. The Sensor Unit is then t installed in a larger system with the heater and detector electrically connected to the analysis system. In a typical application, a semiconductor detector is attached to the outside of the Sensor Unit. The source in the Sensor Unit has no on-off mechanism, and radiation levels are constant during both use and storage. Radiation levels at 10 cm from the Sensor Unit surface are less than or equal to 30 mrem/hr. The only openings into the ionization chamber are 3 mm ports, too small for human access.

B. Drawing:



#### III. DETAILS OF CONSTRUCTION AND USE.

#### A. <u>Conditions of Use</u>

The Sensor Unit is typically installed in and used with a larger analytical system to detect hazardous gases and aerosols. It can be used with its analytical support equipment either as a portable survey instrument or in a fixed monitoring location. It is designed to operate in temperature ranges from -30°C to 55°C at relative humidities ranging from 0 to 95% and can withstand harsher environments than its human operator can survive.

The components of the Sensor Unit related to radiation safety including the Teflon source block, the ionization chamber cover made of fiberglass/epoxy resin composite and stainless steel fasteners and housing, are capable of resisting corrosive atmospheres. Because of the absence of moving parts in the ionization chamber, it can withstand vibrations in excess of those which are likely to be encountered in use and that can be sustained by associated support equipment.


Users of the Sensor Unit in an analytical system will include trained military and civilian personnel who will use the Sensor Unit under conditions ranging from battlefield conditions where chemical warfare agents will be monitored to surgical theaters where waste anesthetic gases will be monitored. Vibration exposures will be incidental to the handling and transportation. When used in a fixed monitoring mode, users will be near the device when setting it up and relocating it. In survey applications, the user carries the system. It is unlikely that the Sensor Unit can be


3

incorporated as a component at any product other than the analytical system with which it is used. The expected useful life of the Sensor Unit is in excess of ten years.


#### B. Details of Construction

Figure 1. gives the dimensions and final shape of the source cut from AV/IV 2 stock. Figure 2. illustrates how the source fits in the ionization chamber in the Teflon source block and how it is held in place by the fibe: glass/epoxy resin composite cover with its Teflon gasket (Figure 3). The source block also contains a heater to maintain an operating temperature of 35°C or above and air passages to route the sampling stream through the ionization, the ionization chamber and to a detector chamber outside the source bed. Figure 4: illustrates the source bed installed in the stainless steel Sensor Unit which has no openings except for gas flow and cabling. The source is constructed of americium-241 oxide in a gold/palladium matrix minimizing the potential for uptake of americium from a bare source. The source itself is an alpha/low energy gamma emitter and is paraially shielded with lead to reduce radiation levels to those described in Section III.F. Note: All dimensions are given in mitimeters





4







Figure 3 drawing of the fiberglass/epoxy resin cover Scale 2:1


Figure 4- See Attached Source bed installed in stainless steel Sensor Unit Scale 1:1

#### C. Labeling


Each Sensor Unit and associated equipment will be labeled to comply with the requirements in 10 CFR 32.29(b). Sensor Units will have durable, legible, readily visible self-adhesive Lexan film labels on their external surface containing the following:


Contains Radioactive Material Am-241, 160 µCi. This Sensor Unit is authorized for distribution to persons exempt from license by Terret USA Inc.





· · · · · ·





The external surface of the system in which the Sensor Unit is installed and its package shall contain readily visible labels with the following:

Caution, contains radioactive material. This Sensor Unit is authorized for distribution to persons exempt from license by Ternet USA Inc. pursuant to 10 CFR 32.26. The Sensor Unit installed in this device contains Am-241, 160  $\mu$ Ci. The sensor unit is authorized for distribution to persons exempt from license by Ternet USA Inc.

The detector in this system contains radioactive material and has been manufactured in compliance with USNRC safety criteria in 10 CFR 32.27. The purchasers is exempt from any regulatory requirements.

Label art work is attached.

#### D. Testing of Prototypes

The Sensor Unit installed in a military gas detector system was tested according to MIL-STD-810D for vibration and shock resistance. The testing report is attached

In the vibration test the Sensor Unit was subjected to wide band random vibrations on each of three perpendicular axes for 60 minutes per axis. Following the test the Sensor Unit functioned normally without any changes that could adversely affect radiation safety.

In the shock test, the Sensor Unit in a gas detector system was dropped from a height of 122 cm onto each face, edge and corner, on a concrete floor covered with plywood. Following the drop test, the Sensor Unit functioned normally with no changes that could affect radiation safety.

In the temperature test, the Sensor Unit in a gas detector system was temperature tested for function at the extremes of temperatures to which it might be exposed. The Sensor Unit in the system was maintained at -30°C, function tested for normal operation and then heated to 55°C for three to five hours. The Sensor Unit and system functioned normally during the test and underwent no changes that could adversely affected radiation safety.

In the humidity test, the Sensor Unit was tested at relative humidities ranging from 10 to 95% and functioned normally with no changes that would adversely affect radiation safety. Engineering analysis indicates that there would be no changes in the Sensor Unit at 0-100% relative humidity that could adversely affect radiation safety. These tests were performed primarily to test the complete system for operability at humidity extremes.

#### E. Quality Control

The manufacturer of the Sensor Unit, Environics OY, is applying for ISO 9000 certification and all production is in accordance with military standard specifications. Quality control procedures for parameters that could affect radiation safety follows:

Visual inspection is performed on all components before assembly. Measurements to verify that dimensions are within tolerances will be performed for the foil, Drawing 1, the source bed, Drawing 2, the chamber cover, Drawing 3, and the sensor unit housing, Drawing 4.

Foils will be 100% leak tested before assembly. Foils must demonstrate less than 0.005 microcuries leakage for acceptance.

Assembled components will be visually inspected for proper assembly and fit.

10 percent of assembled Sensor units will be leak-tested in the United States by Temet before transfer to persons exempt from license. Foils must demonstrate less than 0.005 microcuries leakage for acceptance

All records of these tests will be maintained at Temet in the United States. Documentation will be verified for each unit before transfer to a person exempt from license.

#### F. Radiation Profiles

Measurements of external radiation doses were performed by the Finnish Centre for Radiation and Nuclear Safety. These measurements were performed on:

1. Doses outside a typical instrumentation system in which the Sensor Unit was installed 2. Doses outside the Sensor Unit, and

3. Doses outside the source bed component in the Sensor Unit.

A copy of the Centre's report, including measurement instrumentation data, is attached.

#### K. Leak Testing

Sensor Units are leak tested following assembly by the manufacturer. Sensor Units demonstrating any detectable leakage on external surfaces in excess of 0.005  $\mu$ Ci per Sensor Unit will be rejected. Ten percent of Sensor Units distributed by Ternet USA will be leak tested. If any leakage above 0.005  $\mu$ Ci is detected on a leak tested Sensor Unit, distribution will be suspended until the cause can be identified and corrected.

١

#### L. Safety Analysis

The following safety analysis has been performed to determine compliance with the requirements in 10 CFR 32.27. External doses were calculated for several scenarios, including normal use and disposal of a Sensor Unit and the doses from distribution, servicing, and transportation.

For purposes of conservative calculations it is assumed that there is no additional shielding provided by the system in which the Sensor Unit is installed. External doses were measured at 10 cm by the Finnish Centre for Radiation and Nuclear Safety. The highest measured dose rate at 10 cm was 30 µrem per hour. The calculated doses at other distances are in the table below.

Distance (cm)	Dose Rate rem/h
5	9.3 x 10 <sup>-5</sup>
30	4 x 10⁴
100	3.9 x 10 <sup>.7</sup>
300	4 x 10*

It is assumed that during normal use of a Sensor Unit an operator will handle an instrumentation system containing the Sensor Unit for 500 hours, that the technician's hands will be 5 cm from the area of highest external dose rate, and that the major portion of the technician's trunk is 30 cm from the same area.

The dose to his hands is calculated as follows: (500 hours/year)( $9.3 \times 10^{-5}$  rem/hr) = 0.046 rem/year.

The dose to his trunk is calculated as follows:

 $(500 \text{ hours/year})(4x10^{\circ} \text{ rem/hr}) = 0.002 \text{ rem/year}.$ 

These conservative results are below the values in 10 CFR 32.38, column I.

Multiple units may be stored in the stockroom of the distribution center. It is assumed that 10 units are stored at all times in this area and that individuals are three meters away from these 10 units for 2,000 hours per year. The dose to an individual is calculated as follows:

(2,000 hours/year)(4x10\* rem/unit)(10 units) = 8x10\* rem/year.

These conservative results are below the values in 10 CFR 32.38, column !.

It is conservatively estimated that 100 instrumentation systems containing Sensor Units will require service or Sensor Unit replacement each year. Each service will require one hour during which the technician's hands will be 5 cm from the Sensor Unit surface with the highest external dose rate, and the trunk of the technician's body will be within 30 cm of the same surface.

The dose to the technician's hands is calculated as follows: (100 hours/year)( $9.3 \times 10^{-5}$  rem/hour) =  $9.3 \times 10^{-3}$  rem/year.

The dose to the trunk of the technician's body is calculated as follows: (100 hours/year)( $4x10^{4}$  rem/hour) =  $4 \times 10^{4}$  rem/year.

It is assumed that a single truck driver could deliver up to 1,000 Sensor Units to the distribution center per year and that the driver would have each Sensor Unit three meters from the cab for eight hours.

The dose to the truck driver is calculated as follows: (1,000 units)(8 hrs/unit)(4x10\* rem/hr) = 3.2 x 10\* rem/year.

These conservative results are below the values in 10 CFR 32.38, column I.

Because of the high economic value of systems containing the Sensor Unit, it is unlikely that a Sensor Unit will be casually disposed of. However, to conservatively estimate the external dose for disposal of a single Sensor Unit, it is assumed that a refuse truck picks up the Sensor Unit and that it is three meters from the driver for eight hours.

The dose to this refuse truck driver is calculated as follows: (8 hrs)( $4.0x10^{4}$  rem/hr) =  $3.2x10^{-7}$  rem.

During normal use of a single unit and in normal handling and storage of the quantities of Sensor Units likely to accumulate at any one location during distribution or servicing, it is unlikely that any significant dose commitment could result from the intake of the licensed material in Sensor Units. The analysis in NUREG/CR-1156 for disposal of larger quantities of Am-241 in similar sources in smoke detectors indicates that the probability is negligible that a person could receive a dose commitment in excess of the column I values from Sensor Units.

The Sensor Unit is a rugged stainless steel device containing no moving parts, and that could result in any significant in the effectiveness of the containment shielding or safety features under normal handling and use during the useful life of the product. Under battlefield conditions where conventional or nuclear weapons might result in damage to the Sensor Unit, the concurrent threat to individuals would be much greater than from any resulting compromise of radiation safety features of the Sensor Unit.

Fire is the most likely accident event that could affect a Ser t is conservatively assumed that ten Sensor Units are destroyed by fire in the distribution center s. n<sup>3</sup> and that 10<sup>3</sup> of the activity is released as respirable particles. Fire damage and emergency response-... ventilation will result in at least a 10<sup>2</sup> reduction in concentration during the tire-fighting period. If an emergency responder fights a fire for eight hours and has a respiration rate of 1.2 m<sup>3</sup>/hour, we can calculate the intake as follows:

 $(1.6x10^{3} \mu Ci)(10^{3})(10^{2})(1.2m^{3}/hr)(8 hrs)$ 

-----= 5.1 x 10<sup>4</sup> µCi (3 x 10<sup>2</sup> m³)

NUREG/CR-1156 reports that uptake from salvage operations are likely to be lower than from firefighting activities.

The resulting dose commitments are shown in the table below.

Organ Dose Commitment (rem)

Total body	1x10 <sup>-2</sup>
Liver	2x10-1
Bone	2x10-1
Lung	3x10 <sup>.1</sup>

The probability is negligible that in either normal use and disposal or in distribution transportation and servicing doses from the Sensor Unit would exceed the values in 10 CFR 32.28, column II or III would be exceeded. The most reasonable accident scenario would be a fire destroying ten instrument systems in a distribution center. The probability is low that even in the case of fire, the values in 10 CFR 32.28, column II will be exceeded and negligible that the column III values could be exceeded.

12

LCN CLOSERS

. .

Part of worldwide Ingersoll-Rand

LCN Closers Division Schlage Lock Co. P.O. Box 100 Princeton. Illinois 61356-0100 815-875-3311 Fax 815:875-3222

September 30, 1994

Director of Nuclear Material Safety and Safeguards U. S. Nuclear Regulatory Commission Washington, D. C. 20555

Re: Report, LCN Closers, Lic. #12-19544-02E

Gentlemen:

During the period of June 30, 1990 to June 30, 1994, LCN Closers transferred the following materials to purchasers exempt from regulatory requirements:

١

Product:	LCN Model SED-300 Integral Smoke Detector
Radionuclide:	2 ea. Americium Oxide (Am241) sealed source, 7 micro curie per detector
Total Smoke Detectors Transferred:	15,281
Total Sealed Sources Transferred:	30,562
Product:	LCN Model MED-300 Integral Smoke Detector
Radionuclide:	2 ea. Americium Oxide (Am241) sealed source, .7 micro curie per detector
Total Smoke Detectors	
Transferred:	4,570
Total Sealed Sources	
Transferred:	9,140
Grand Total Am241 7	micro curie sealed cources in smoke detectors transf

Grand Total Am241, .7 micro curie sealed sources in smoke detectors transferred to exempt purchasers: 39,702

Director of Nuclear Material Safety and Safeguards U. S. Nuclear Regulatory Commission September 30, 1994 Page - 2 -

If you require further information regarding this report, please contact me.

١

Sincerely, hum Schnarr Ray

Radiation Safety Officer

RHS:rac

cc: U.S. Nuclear Regulatory Commission
Region III Office of Inspection and Enforcement
801 Warrenville Road
Lisle, IL 60532-4351

LCN CLOSERS

~

Part of worldwide Ingersoll-Rand

LCN Closers Division

Schlage Lock Co. P.O. Box 100 Princeton, Illinois 61356 815/875-3311 Telex 72-3434 Fax 815/875-3222

March 1, 1991

Director of Nuclear Material Safety and Safeguards U. S. Nuclear Regulatory Commission Washington, D. C. 20555

١

Re: Report, LCN Closers, Lic. #12-19544-02E

Gentlemen:

During the period of June 30, 1986 to June 30, 1990, LCN Closers transferred the following materials to purchasers exempt from regulatory requirements:

PRODUCT:	LCN Model SED-300 Integral Smoke Detector
RADIONUCLIDE:	2 ea. Americium Oxide (Am241) sealed source, .7 micro curie per detector
TOTAL SMOKE DETECTORS TRANSFERRED:	23,204
TOTAL SEALED SOURCES TRANSFERRED:	46,408
PRODUCT:	LCN Model MED-300 Integral Smoke Detector
PRODUCT: RADIONUCLIDE:	LCN Model MED-300 Integral Smoke Detector 2 ea. Americium Oxide (Am241) sealed source, .7 micro curie per detector
	2 ea. Americium Oxide (Am241) sealed

GRAND TOTAT Am241, .7 micro arrie sealed sources in smoke detectors transferred to exempt purchasers: 59,498 Director of Nuclear Material Safety and Safeguards U. S. Nuclear Regulatory Commission

September 30, 1994 Page - 2 -

If you require further information regarding this report, please contact me.

١

Sincerely, Schnarr Ra

Radiation Safety Officer

RHS:rac

cc: U.S. Nuclear Regulatory Commission Region III Office of Inspection and Enforcement 801 Warrenville Road Lisle, IL 60532-4351 American Scitec, Incorporated 3505 Cadillac Avenue, Building J-5 Costa Mesa, California 92626 (714) 549-8680 FAX (714) 662-2008



10 June 1993

Director of Material Safety and Safeguards U.S. Nuclear Regulatory Commission, Washington D.C 20555

Ref: USNRC License # 04-21357-01E 10 CFR Part 32, 32.12 Material Transfer Report

PERIOD: 25 June 1988 through 10 June 1993

#### 32.12(b)(1)

Reside	ential Smoke Det	ectors
Model	168101-series=	1,658,153
Model	168102-series=	0
Model	168103-series=	0
Model	168104-series=	9,796
Model	168106-series=	184,424
Model	168108-series=	550
Model	168111-series=	94,862
Model	168112-series=	84,104

TOTAL = 2,031,889

32.12(b)(2)

Wing Wah Chong Investment Company, Ltd. 40 Lee Chung Street Chai Wan, Hong Kong 9/2/83 To 7/5/90

Greaton Industries Limited 40 Lee Cheng Street Chai Wan, Hong Kong 7/5/90 To 11/25/91

Shanghai Fenghua Radio Factory 238 Guang Xi Bei Road Shanghai, P.R. China 11/25/91 To Present Material Transfer Report', USNRC License Number 04-21357-01E 10 June 1993 Page 2

<u>32.12(b)(3)</u>

Americium-241 (Amersham Model AMM1001H Foil Source)

<u>32.12(b)(4)</u> 0.9 uCi +- .09 uCi/unit

32.12(c)(1) This report is filed five years following the preceding report on USNRC License # 04-21357-01E,

Respect **VII**Y

R.R. Ludt Uperations Manager American Scitec Inc.

cc - USNRC Region V 1450 Maria Lane, Suite 210 Walnut Creek, CA 94596

136-20122



P. O. BOX 746

SECURITY ENGINEERING, INC.

CLEMMONS N C 27012 udult / December 14. 1992

License Fee and Debt Collection Branch Division of Accounting and Finance Office of the Controller U. S. Nuclear Regulatory Commission Washington, DC 20555

Attention: Mr. Michael A. Lamastra Section Leader

> RE: License #32-16736-02E #NR-0529D-102E

Dear Mr. Lamastra:


In September, 1991 we wrote a letter to the commission that was intended to request termination of our license to distribute smoke detectors. A copy of that letter is attached.

In September, 1992 Mrs. Patricia Vacca outlined several steps necessary to complete this termination. This letter and the enclosed documents are for that purpose.

- 1. We do want license #32-16736-02E to be terminated.
- 2. Please change device registration NR-0529D-102E to inactive status.
- 3. We do desire to permanently discontinue licensed activities.
- 4. The last year that detectors were distributed was 1987. Only 900 detectors were shipped that year. We did renew our license in 1989, but have not manufactured or distributed any detectors since 1987.

If you have questions or if I may be of further assistance, please do not hesitate to call me.

FEE EXEMPT	Very truly yours,	
to Store Baggett V	RECE VED BY King June Data 12/13/12 Log Aigu 2 By Bau	
RED 250 1 8 1992	Datu Completed 12/13/44	Ĺ



DEPESTIC SHIPPENT HISTORY REPORT

\*\* YID ROLLING 12, ROLLING 12 VX, ROLLING 6 VX, ROLLING 3 VX

	JAN	FEB	MAR	1ST QTR	AFR	MAY	JUN	ZND OTR	TTD	JI	AUG	SEP	3RD QTR	TTD	ост	NOV	DEC	411	<b>DLL</b>	
FIRE SA	ses FEIT PR		-	898	***	***	***	222	842	RER		***	Rate	882	RRR	222		QTR FFR	YEAR	
\$746/D 1983	0.0	0.0	0.0	0.0	0.0	0.0	16.6	16.6	16.6	35.1	36.0									
1984 1985	29.2	37.4	35.7	102.3	22.4	21.3	84.3	128.0	230.3	40.8	43.0	31.1 64.1	102.2 147.9	118.8 378.2	26.8 123.3	32.9 98.1	67.6 172.1	127.3	246.1	
1986	62.1 33.1	93.0 59.7	70.3 77.0	225.4	33.0 37.0	38.9 20.2	70.3 47.1	142.2 104.3	367.6	111.4 58.2	67.0 58.3	118.4	296.8 206.9	664.4 481.0	40.1 70.1	51.4 34.1	44.8 60.1	136.3	800.7 645.3	
1987 1988	33.9 30.1	50.5 38.4	45.8 63.8	130.2 132.3	37.6 24.5	26.9 43.7	36.3 67.8	102.8 136.0	233.0 268.3	36.1 38.7	66.8 54.5	35.6 85.9	138.5 179.1	371.5 447.4	70.7 74.7	47.7	32.8 40.6	151.2	522.7	
1989	39.5	18.2 •33.5X	32.9 -42.8X	90.6 -47.7X	18.0	41.4	40.4	97.8	190.4	34.6	28.0	2.9	92.5	282.9	44.0	41.9	40.0	176.2 85.9	623.6 368.8	
SPK60M	0.0	0.0	0.0	0.0	1.5	10.6	16.1	28.Z	28.2	2.0	15.9	22 0	70.0		0.0	0.0	0.0	0.0	0.0	
1989	6.0	13.3	11.2	30.5	18.9	9.5	15.6	4.0	74.5	9.5	8.5	22.0 6.0	39.9 24.0	68.1 98.5	16.8 · 12.6	29.9 13.4	29.1	75.8 26.0	143.9	
SHKP	153.6		[	-53.4X											0.0	0.0	0.0	0.0	0.0	
1988 1989	0.0 0.2	0.0 -0.5	0.0	0.0 0.3	0.0 0.1	0.0 1.1	0.0	0.0 1.5	0.0 1.8	151.3	1.5 1.7	43.8 0.2	196.6 2.0	1%.6 3.8	40.6 0.5	0.4 0,4	0.0	41.0	237.6	
59K12	4.7	-98.02	·98.7X	-98.72											0.0	0.0	0.0	0.0		-
1987 1988	0.0 0.2	0.0 0.5	2.4 0.9	2.4 1.6	0.0 0.4	0.0 0.3	0.0 0.9	0.0 1.6	2.4 3.2	0.0	1.1 2.0	1.7 4.8	2.8 7.1	5.2 10.3	0.2	1.2	0.4	1.8	0.0 7.0	
1989	0.4	0.7 20.1%	0.7	1.8 -26.3X	0.5	0.7	1.2	2.4	4.2	0.6	2.9	1.9	5.4	9.6	2.6	2.5	3.8	8.5 5.1	18.8 14.7	
51418 bsolde.1989 51420 1987 socide.1988		-	1	1 (					6.9	0.0	1.5		4.1		0.0	0.0	4.0	4.0	4.0	
booke. Way	2.2 15.0	1.4 M/A	2.7 M/A	6.3 N/A	0.2	0.0	0.4	0.6	0.7	0,0	1.2	2.6	<b>•.</b> 1	11.0	0_0	0.0		0.0	11.0	
SPK20/ 1987	0.0	0,0	0.0	0.0	0.0	0.0 0.6	0.0	0.0	0.0	0.0	1.2 0.0	0.4	1.6	1.6	0.0	0.0 0.5	0.0 0.1	0.0 0.9	0.0 2.5	
societe 1988	0.0 X/A	0.1 X/A	12.8 N/A	12.9 K/A	0.0	0.6	0.0	. 0.6	13.5	0.0	0.0	0.0	0.0	13.5	0.0	0.0	0.0	0.0	13.5	
SHK25 1988	0.8	2.5	7.1	10.4	2.4	3.1	12.6	18.1	28.5	15.4	27.2	20.9	63.5	92.0	0.0 5.2	0.0 9.8	0.0 8.3	0.0 23.3	0.0 115.3	
1989	14.9 96.3	7.0 -10.0X	12.9	34.8 -52.4X	16.6	4.0	4.3	24.9	59.7	5.4	5.8	4.4	15.6	75.3	5.3	7.4		12.7	83.0	
59(30	••••					• •				0.0	2.8	37 4	30.4	10	0.0	0.0	0.0	0.0	0.0	
1987 1988 1989	0.0 5.6	0.0 0.6	0.0 12.4	0.0 18.6	0.0 -1.2	0.0 0.0	0.0 1.9	0.0	0.0 19.3	0.3	-0.3	27.6 0.0	0.0	30.4 19.3	4.1	8.2 -0.9	6.6 0.0	18.9 -0.8	49.3 18.5	
sucti/1989	-3.0 34.9	-0.4 39.0%	0.0 N/A	-3.4 N/A	6.2	0,6	24.1	30.9	27.5	1.0	5.6	0.7	7.3	34.8	0.1	0.0		0.1	34.9 INVENTORY DEPLETER	)
								ł	}											
				•	ł			L	1					1	1			J		

all observer versions en

Similie to the SIGK 25 except

you mance cosmetic dyferinces

nek N Deetic Ê

-	 -91	<b>FIRE</b>
ο-		1.565 10

.

;#1PHENT	NISTO	RY REPO	tt si	PECIALTY		,	TD ACT	UAL: MAY	91	** YTD (	ROLLING	12, RO	LLING 12	VX, ROLI	LING 6 V	K, ROLL	ING 3 V	X	
NEATERS	s <del>seres</del> JAX Preten	FEB	MAR	1ST GTR	APR	MAY	JUN	21 0 QYR	YTD	JUL	AUG	SEP	3RD QTR	YTD	OCT	NOA	DEC	4th gtr	FULL YEAR
NF200U 1986 1987 1988 1989	0.6 0.8 1.6	-0.4 2.3 0.8 N/A	0.1 -0.3 0.3 N/A	0.0 0.3 2.8 2.7 N/A	0.1 -3.1 -0.3	-1.3 0.1 0.0	0.2 1.0 0.6 0.2	0.2 -0.2 -2.4 -0.1	0.2 0.1 0.4 2.6	3.9 3.9 0.6 0.6	4.4 1.6 1.0 0.4	2.0 10.0 1.2 1.4	10.3 15.5 2.8 2.4	10.5 15.6 3.2 5.0	5.4 1.2 2.5 1.5	4.2 1.3 1.2 1.1	0.4 0.7 1.8 0.6	10.0 3.2 5.5 3.2	20.5 18.8 8.7 8.2
KF230U/G 1986 1987 1988 1989 1989 1990		2.0 0.0 0.0 -0.6 0.8	-0.5 -0.3 0.0 -3.4 0.1 -362.9%	0.0 6.7 1.1 3.0 -4.0 3.2 -145.7X	-0.2 -1.4 -1.5 -0.2 0.1	0.4 -0.1 -0.4 0.1 1.4	1.5 -2.1 0.4 0.3	0.0 1.7 -3.6 -1.5 0.2	0.0 8.4 -2.5 1.5 -3.8	0.0 3.4 1.0 1.3 3.8	8.0 12.6 13.2 3.2 10.4	9.9 7.8 7.1 9.8 5.1	17.9 23.8 21.3 14.3 19.3	17.9 32.2 18.8 15.8 15.5	1.4 3.9 22.4 24.8 4.5	3.2 7.1 4.5 10.4 9.6	2.7 2.4 7.6 0.6 4.5	7.3 13.4 34.5 35.8 18.6	25.2 45.6 53.3 51.6 34.1
TOTAL ME 1986 1987 1988 1989 1990 1991		0.0 1.6 2.3 0.8 -0.6 0.8	0.0 -0.4 -0.6 0.3 -3.4 0.1 -417.2%	0.0 7.0 3.9 5.7 -4.0 3.2	0.0 -0.1 -4.5 -1.8 -0.2 0.1	0.0 -0.9 0.0 -0.4 0.1 1.4	0.2 2.5 -1.5 0.6 0.3	0.2 1.5 -6.0 -1.6 0.2	0.2 8.5 -2.1 4.1 -3.8	3.9 7.3 1.6 1.9 3.8	12.4 14.2 14.2 3.6 10.4	11.9 17.8 8.3 11.2 5.1	28.2 39.3 24.1 16.7 19.3	28.4 47.8 22.0 20.8 15.5	6.8 5.1 24.9 26.3 4.5	7.4 8.4 5.7 11.5 9.6	3.1 3.1 9.4 1.2 4.5	17.3 16.6 40.0 39.0 18.6	45.7 64.4 62.0 59.8 34.1
FIRE SAF	FETY																		
SHK6/0 1983 1984 1985 1986 1987 1988 1987 1989 1989 1990 1991	0.0 29.2 62.1 33.1 33.9 30.1 39.5 7.8 3.0 115.0	0.0 37.4 93.0 59.7 50.5 38.4 18.2 8.2 31.6 -61.0X	0.0 35.7 70.3 77.0 45.8 63.8 32.9 14.7 24.7 -11.1X	0.0 102.3 225.4 169.8 130.2 132.3 90.6 30.7 59.3 -20.63	0.0 22.4 33.0 37.0 39.6 24.5 18.0 10.6 0.0	0.0 21.3 38.9 20.2 26.9 43.7 41.4 5.4 -0.4	16.6 84.3 70.3 47.1 36.3 67.8 40.4 8.1	16.6 128.0 142.2 104.3 102.8 136.0 99.8 24.1	16.6 230.3 367.6 274.1 233.0 268.3 190.4 54.8	35.1 40.8 111.4 58.2 36.1 38.7 34.6 2.5	36.0 43.0 67.0 58.3 66.8 54.5 28.0 5.7	31.1 64.1 118.4 90.4 35.6 85.9 29.9 9.0	102.2 147.9 296.8 206.9 138.5 179.1 92.5 17.2	118.8 378.2 664.4 481.0 371.5 447.4 282.9 72.0	26.8 123.3 40.1 70.1 70.7 74.7 44.0 7.5	32.9 98.1 51.4 34.1 47.7 60.9 41.9 14.6	67.6 172.1 44.8 60.1 32.8 40.6 29.3 8.7	127.3 393.5 136.3 164.3 151.2 176.2 115.2 30.8	246.1 771.7 800.7 645.3 522.7 623.6 398.1 102.8
547K6014 1988 1989 1990	0.0 0.0 4.6	0.0 0.0 4.5	0.0 0.0 2.0	0.0 11.1	1.5 18.9 1.0	10.6 9.5 12.5	16.1 15.6 17.5	28.2 44.0 31.0	28.2 44.0 42.1	2.0 9.5 39.0	15.9 8.5 25.0	22.0 6.0 22.4	39.9 24.0 86.4	68.1 68.0 128.5	16.8 12.6 -1.0	29.9 13.4 1.0	29.1 15.6 0.0	75.8 41.6 0.0	143.9 109.6 128.5
SHK9 1989 1989 1990	N/A 15.3 19.1 0.4 N/A	N/A 20.1 15.1 0.6 N/A	N/A 45.8 35.1 1.1 N/A	N/A 81.2 69.3 2.1 N/A	0.0 0.1 1.1	0.0 1.1 0.7	0.0 0.3 0.5	0.0 1.5 2.3	81.2 70.8 4.4	151.3 0.1 1.1	1.5 1.7 0.0	43.8 0.2 0.0	196.6 2.0 1.1	277.8 72.8 5.5	0.0 40.6 0.5 0.0	0.0 0.4 0.4 0.0	0.0 0.0 0.3 0.0	0.0 41.0 1.2 0.0	0.0 318.8 74.0 5.5

. . .

\* Same as SMK6D except for

FILE: SPECSHIP

Commetic picture on box

18-JUN-91 -----

,	JAN	FEB	MAR	1ST OTR	APR	MAY		2110 QTR	TTD	JUL	AUG	SEP	3RD QTR	<b>T</b> T	0CT 0.0	NOV 0.0	DEC 0.0	41H QTR 0.0	FULL YEAR 0.0	
SHK12/ 1987 1988 1989 1990	0.0 0.2 0.4 0.3	0.0 0.5 0.7 0.0 N/A	2.4 0.9 0.7 0.3 N/A	2.4 1.6 1.8 0.6 N/A	0.0 0.4 0.5 0.1	0.0 0.3 0.7 0.1	0.0 0.9 1.2 0.2	0.0 1.6 2.4 0.4	2.4 3.2 4.2 1.0	0.0 0.3 0.6 0.4	1.1 2.0 2.9 0.2	1.7 4.8 1.9 0.0	2.8 7.1 5.4 0.6	5.2 10.3 9.6 1.6	0.2 0.9 2.6 0.0	1.2 3.8 2.5 0.0	0.4 3.8 1.8 0.0	1.8 8.5 6.9 0.0	7.0 18.8 16.5 1.6	
1989 1989 1990	2.2 2.6 W/A	1.4 0.4 W/A	2.7 1.1 N/A	6.3 4.1 N/A	0.2 0.0	0.0 0.0	0.4 0.0	0.6 0.0	6.9 4.1	0.0 0.0	1.5 0.0	2.6 0.0	4.1 0.0	11.0 4.1	0.0 0.0 0.0	0.0 0.0 0.0	4.0 3.7 0.0	4.0 3.7 0.0	4.0 14.7 4.1	
SHK25 1987 1988	0.0 0.0 %/A	0.0 0.1 N/A	0.0 12.8 N/A	0.0 12.9 #/A	0.0 0.0	0.0 0.6	0.0 0.0	0.0 0.6	0.0 13.5	0.0 0.0	1.2 0.0	0.4 0.0	1.6 0.0	1.6 13.5	0.0 0.3 0.0	0.0 0.5 0.0	0.0 0.1 0.0	0.0 0.9 0.0	0.0 2.5 13.5	
SNK25 1988 1989 1990 1991	0.8 14.9 2.7 0.5 41.1	2.5 7.0 1.8 2.3 -13.6X	7.1 12.9 2.9 2.4 -34.4x	10.4 34.8 7.4 5.2 -15.72	2.4 16.6 0.6 1.7	3.1 4.0 1.6 0.2	12.6 4.3 2.5	18.1 24.9 4.7	28.5 59.7 12.1	15.4 5.4 2.1	27.2 5.8 3.3	20.9 4.4 2.9	63.5 15.6 8.3	92.0 75.3 20.4	0.0 5.2 5.3 2.4	0.0 9.8 7.4 18.0	0.0 8.3 5.5 2.8	0.0 23.3 18.2 23.2	0.0 115.3 93.5 43.6	
SHK30 1987 1988 1989 1990	0.0 5.6 -3.0 0.0 N/A	0.0 0.6 -0.4 0.0 #/A	0.0 12.4 0.0 0.0 #/A	0.0 18.6 -3.4 0.0 N/A	0.0 -1.2 6.2 0.0	0.0 0.0 0.6 0.0	0.0 1.9 24.1 0.0	0.0 0.7 30.9 0.0	0.0 19.3 27.5 0.0	0.0 0.3 1.0 0.0	2.8 -0.3 5.6 0.0	27.6 0.0 0.7 0.0	30.4 0.0 7.3 0.0	30.4 19.3 34.8 0.0	0.0 4.1 0.1 0.1 0.0	0.0 8.2 -0.9 0.0 0.0	0.0 6.6 0.0 -0.2 0.0	0.0 18.9 -0.8 -0.1 0.0	0.0 49.3 18.5 34.7 0.0	- INVENTORY DE
SHK100 1989 1990 1991	4.2 14.8 225.7	12.6 9.0 289.8%	7.6 19.0	24.4 42.8 200.6%	0.5 21.6	7.5 6.3	7.1	15.1	39.5	5.9	43.0	29.2	78.1	117.6	29.5	15.1	25.5 25.2	25.5 69.8	25.5 187.4	
5HX200 1990 1991	0.0 -0.9 18.0	0.0 0.9 1284.6X	1.1 1.3 484.6%	1.1 3.1 292.3X	0.1 3.6	0.1 0.2	2.7	2.9	4.0	0.6	0.4	5.6	6.6	10.6	0.8	0.3	0.7	1.8	12.4	
5MK300 1989 1990 1991	3.2 0.2 6.5	1.3 0.5 -96.3%	0.8 0.2 -86.8X	5.3 0.9 -40.0X	0.1 0.3	0.6 0.4	0.9	1.6	6.9	0.4	0.4	19.4 0.6	19.4 1.4	19.4 8.3	79.5 0.5	48.8 0.3	19.8 1.8	148.1 2.6	167.5 10.9	
SHK400 1990 1991	0.0 0.1 21.1	0.7 -0.2	3.9 0.2	4.6 0.1 -127.7X	0.3 -0.1	0.5 -1.4	3.7	4,5	9.1	1.1	2.6	8.8	12.5	21.6	4.0	2.0	0.3	6.3	27.9	


PAGE 5

•

\* Not covered by this license. These are manufactured by Seatt Corp. and distributed under their license 12-1553702E.

FILE: SPECSNIP

### **DICON SYSTEMS LIMITED**



719 CLAYSON RD., TORONTO (WESTON), CANADA M9M 2H4 (416) 745-6044 TLX 06-969667 FAX (416) 745-6938

May 11, 1990

United States Nuclear Regulatory Commission Washington, D.C.

Attention: Mr. J. Bruce Carrico Medical, Academic and Commercial Use Satety Branch Division of Industrial and Medical Nuclear Safety, NMSS

Dear Mr. Carrico

Based on our records the following represents the ionization smoke alarms shipped through Sonwill:

	<u>1983</u>	1984	<u>1985</u>	1986	1987	1988	
300B	38,000	49,000	30,000	80,000	80,000	74,000	
SA4	6,000	8,000	13,000	40,000	40,000	37,000	
330L	2,000	2,000	6,000	8,000	8,000	8,000	
TOTAL	46,000	59,000	49,000	128,000	128,000	119,000	THC

Yours very truly DICON SYSTEMS LIMITED

John Mallory Am-241 EAch Diem smoke extreter was awthoused for not The mont than Dismissioners, Therefore the above The table in activity translates as follows: Am-241 34.200 39690 1000 12000 72000 6600 5400 7200 11700 36000 36000 3320 1800 1800 5400 7206 7200 7200 41,400 53,100 44,100 115,200 115,200 107100 - Williames mCi