

1. LaSalle Emergency Action Level Guidelines, EP-AA-1005, Revision 14, pages LS 3-6 through -13 (Abnormal Rad Levels/Effluents; Fission Product Barrier Degradation; Fission Product Barrier Matrix including Support Tables and Graphs; System Malfunctions; Hazards and Other Conditions);
2. LaSalle Technical Specification (TS) 3.1.3 Control Rod Operability, Amendment No. 147/133, pages 3.1.3-1 through -5;
3. LaSalle TS 3.1.4 Control Rod Scram Times, Amendment No. 147/133, pages 3.1.4-1 through -3;
4. LaSalle TS 3.2.2 Minimum Critical Power Ratio, Amendment No. 147/133, pages 3.2.2-1 through -2;
5. LaSalle TS 3.4.3 Jet Pumps, Amendment No. 147/133, pages 3.4.3-1 through -2;
6. LaSalle TS 3.9.8 Refueling Operations, Residual Heat Removal-High Water Level, Amendment No. 147/133, pages 3.9.8-1 through -3;
7. Reportability Reference Manual, LS-AA-1110, Revision 1, Reportable Event SAF 1.4: Degraded or Unanalyzed Condition, pages 11-13 of 134;
8. Reportability Reference Manual, LS-AA-1110, Revision 1, Reportable Event SAF 1.5: ECCS Injection/Actuation, pages 15-17 of 134;
9. Reportability Reference Manual, LS-AA-1110, Revision 1, Reportable Event SAF 1.6: RPS Actuation, pages 19-21 of 134;
10. Reportability Reference Manual, LS-AA-1110, Revision 1, Reportable Event SAF 1.7: System Actuation Not Including RPS, pages 23-27 of 134;
11. Guidance on Event-Driven Reporting Requirements, Revision 7, Reportable Event SAF 1.12, definition of "valid actuation" and "invalid actuation," page 5 of 13;
12. LAP-820-11TG, Revision 22, Attachment 1G, Max Normal and Max Safe U1 Reactor Building Vent & Area Radiation Limits (mr/hr), Water Level Limits (inches above floor) and Temperature Limits (degrees F), page 142 of 155;
13. LOS-DG-M2, Revision 54, Diesel Generator Load Limit Table (KW, KVAR, Amps, time rating) page 8 of 21;
14. Fire Protection (FP) System, LGA-FP-01, Revision 8, Max Jockey, Intermediate, and Fire Pump Flows, and FP Reactor Pressure Vessel (RPV) Injection Flow at Various RPV Pressures, pages 11-12 of 51;
15. Electrical Schematics for Main Steam Isolation Valves (1E-1-4203AB, -4203AC, -4203AD, -4203AE, -4203AF) and Moisture Separator Reheater First Stage Blanketing Steam Vent and Feed Valves (1E-1-4203AU);

16. LGA flowcharts with entry conditions and significant numbers removed (LGA-001 through 006, and LGA-009 through 011).