

August 11, 2003

U. S. Nuclear Regulatory Commission  
Attn: Document Control Desk  
Mail Stop P1-137  
Washington, DC 20555-0001



ULNRC04886

Ladies & Gentlemen:

**DOCKET NUMBER 50-483  
UNION ELECTRIC CO.  
CALLAWAY PLANT UNIT 1  
FACILITY OPERATING LICENSE NPF-30  
MONTHLY OPERATING REPORT  
JULY/2003**

The enclosed Monthly Operating Report for July/2003 is submitted pursuant to Section 5.6.4 of the Callaway Unit 1 Technical Specifications.

*Warren A. Witt*  
Warren A. Witt  
Manager, Callaway Plant

WAW/JER/slk

Enclosure

TE24

ULNRC04886  
August 11, 2003  
Page 2

cc: Mr. Thomas P. Gwynn  
Acting Regional Administrator  
U.S. Nuclear Regulatory Commission  
Region IV  
611 Ryan Plaza Drive, Suite 400  
Arlington, TX 76011-4005

Senior Resident Inspector  
Callaway Resident Office  
U.S. Nuclear Regulatory Commission  
8201 NRC Road  
Steedman, MO 65077

Mr. Jack Donohew (2 copies)  
Licensing Project Manager, Callaway Plant  
Office of Nuclear Reactor Regulation  
U. S. Nuclear Regulatory Commission  
Mail Stop 7E1  
Washington, DC 20555-2738

Manager, Electric Department  
Missouri Public Service Commission  
PO Box 360  
Jefferson City, MO 65102

Enclosure  
ULNRC04886  
August 11, 2003

DOCKET NO.: 50-483  
UNIT NAME: CALLAWAY UNIT 1  
COMPLETED BY: J. E. Ready  
TELEPHONE: 573/676-8617  
FAX: 573/676-4202

REPORTING PERIOD: JULY/2003  
1. DESIGN ELECTRICAL RATING (MWe-Net): 1171  
2. MAX. DEPEND. CAPACITY (MWe-Net): 1125

	<u>THIS MONTH</u>	<u>YR TO DATE</u>	<u>CUMULATIVE</u>
3. NUMBER OF HOURS REACTOR WAS CRITICAL	744	4821.5	146338.5
4. HOURS GENERATOR ON-LINE	744	4806.5	144402.5
5. REACTOR RESERVE SHUTDOWN HOURS	0.0	0.0	0.0
6. NET ELECTRICAL ENERGY GENERATED (MWH)	851080	5562013	159106109

Enclosure  
ULNRC004886  
August 11, 2003

**UNIT SHUTDOWNS**

DOCKET NO.: 50-483  
UNIT NAME: CALLAWAY UNIT 1  
COMPLETED BY: J. E. Ready  
TELEPHONE: 573/676-8617  
FAX: 573/676-4202

**REPORT: July/2003**

<u>NO.</u>	<u>DATE</u>	<u>TYPE</u> F: FORCED S: SCHEDULED	<u>DURATION</u> (HOURS)	<u>REASON</u>	<u>METHOD OF</u> <u>SHUTTING DOWN</u> <u>THE REACTOR</u>	<u>CORRECTIVE</u> <u>ACTIONS/</u> <u>COMMENTS</u>
------------	-------------	--	----------------------------	---------------	--	---

**SUMMARY The Callaway Plant operated at approximately 100% power, for the month of July.**

<u>REASON</u>	<u>METHOD</u>
A: EQUIPMENT FAILURE (EXPLAIN)	1: MANUAL
B: MAINT. OR TEST	2: MANUAL SCRAM
C: REFUELING	3: AUTOMATIC SCRAM
D: REGULATORY RESTRICTION	4: CONTINUATION
E: OPERATOR TRAINING / LICENSE EXAMINATION	5: OTHER (EXPLAIN)
F: ADMINISTRATIVE	
G: OPERATIONAL ERROR (EXPLAIN)	
H: OTHER (EXPLAIN)	