

AUG 1 2 2003

LR-N03-0357



U. S. Nuclear Regulatory Commission
Document Control Desk
Washington, DC 20555

Gentlemen:

**MONTHLY OPERATING REPORT
HOPE CREEK GENERATING STATION
DOCKET NO. 50-354**

In compliance with Section 6.9, Reporting Requirements for the Hope Creek Technical Specifications, the operating statistics for **July 2003** are being forwarded.

Sincerely,

A handwritten signature in black ink, appearing to read "Lon Waldinger", written over a large, stylized circular flourish.

Lon Waldinger
Operations Director

Attachments

C Distribution

IE24

DOCKET NO.: 50-354
 UNIT: Hope Creek
 DATE: 8/8/03
 COMPLETED BY: F. Todd
 TELEPHONE: (856) 339-1316

Reporting Period July 2003

OPERATING DATA REPORT

Design Electrical Rating (MWe-Net)
Maximum Dependable Capacity (MWe-Net)

No. of hours reactor was critical
No. of hours generator was on line (service hours)
Unit reserve shutdown hours
Net Electrical Energy (MWH)

1083		
1049		
Month	Year-to-date	Cumulative
744	4241	125357
744	4108	122926
0	0	0
785188	4190953	124669644

UNIT SHUTDOWNS

NO.	DATE	TYPE F=FORCED S=SCHEDULED	DURATION (HOURS)	REASON (1)	METHOD OF SHUTTING DOWN THE REACTOR (2)	CORRECTIVE ACTION/ COMMENT

(1) Reason

- A - Equipment Failure (Explain)
- B - Maintenance or Test
- C - Refueling
- D - Regulatory Restriction
- E - Operator Training/License Examination
- F - Administrative
- G - Operational Error (Explain)
- H - Other

(2) Method

- 1 - Manual
- 2 - Manual Trip/Scram
- 3 - Automatic Trip/Scram
- 4 - Continuation
- 5 - Other (Explain)

DOCKET NO.: 50-354
UNIT: Hope Creek
DATE: 8/8/03
COMPLETED BY: R. Ritzman
TELEPHONE: (856) 339-1445

Summary Of Monthly Operating Experience

- The unit entered the month at approximately 100% reactor power and remained there throughout the month.
- At the end of the month, Hope Creek completed 78 days of continuous on-line operation.