

September 3, 2003

Mr. Michael M. Corletti  
Passive Plant Projects & Development  
AP600 & AP1000 Projects  
Westinghouse Electric Company  
Post Office Box 355  
Pittsburgh, Pennsylvania 15230-0355

SUBJECT: NEW OPEN ITEMS - AP1000 DESIGN CERTIFICATION REVIEW (TAC NOS.  
MB9693 AND MB9695)

Dear Mr. Corletti:

By letter dated March 28, 2002, Westinghouse Electric Company (Westinghouse) submitted its application for final design approval and standard design certification for the AP1000 advanced plant design. On June 16, 2003, the Nuclear Regulatory Commission (NRC) staff issued the draft safety evaluation report (DSER) for the AP1000 design. The DSER identified 174 open items that needed resolution prior to issuance of the final safety evaluation report (FSER) for the AP1000 design. The NRC staff is continuing a detailed review of your design certification application to ensure that the information is sufficiently complete to enable the NRC staff to reach a final conclusion on all safety questions associated with the design before the certification is granted.

The NRC staff has determined that additional information is necessary to continue the review. Four additional open items are included in the enclosure to this letter. The topics covered in these open items focus on materials issues. Specifically, the issues are associated with DSER Sections 4.5.2, Reactor Internal and Core Support Materials; 5.2.3, Reactor Coolant Pressure Boundary Materials; and 6.1, Engineered Safety Features Materials. These open items were sent to you via electronic mail on August 21, 2003. Please note that in the version sent via electronic mail, Open Item 4.5.2-1 referred to the VGN-5 core barrel, the attachment to this letter has been revised to refer to the core shroud.

Please contact one of the following members of the AP1000 project management team if you have any questions or comments concerning this matter: Mr. John Segala (Lead Project Manager) at (301) 415-1858, [jps1@nrc.gov](mailto:jps1@nrc.gov); Mr. Joseph Colaccino at (301) 415-2753, [jxc1@nrc.gov](mailto:jxc1@nrc.gov); or Ms. Joelle Starefos at (301) 415-8488, [jls1@nrc.gov](mailto:jls1@nrc.gov).

Sincerely,

/RA/

Joelle L. Starefos, Project Manager  
New Reactors Section  
New, Research and Test Reactors Program  
Division of Regulatory Improvement Programs  
Office of Nuclear Reactor Regulation

Docket No. 52-006

Enclosure: New Open Items Associated with AP1000 DSER Sections 4.5.2, 5.2.3, and 6.1

M. Corletti

cc: See next page

September 3, 2003

Mr. Michael M. Corletti  
Passive Plant Projects & Development  
AP600 & AP1000 Projects  
Westinghouse Electric Company  
Post Office Box 355  
Pittsburgh, Pennsylvania 15230-0355

SUBJECT: NEW OPEN ITEMS - AP1000 DESIGN CERTIFICATION REVIEW (TAC NOS.  
MB9693 AND MB9695)

Dear Mr. Corletti:

By letter dated March 28, 2002, Westinghouse Electric Company (Westinghouse) submitted its application for final design approval and standard design certification for the AP1000 advanced plant design. On June 16, 2003, the Nuclear Regulatory Commission (NRC) staff issued the draft safety evaluation report (DSER) for the AP1000 design. The DSER identified 174 open items that needed resolution prior to issuance of the final safety evaluation report (FSER) for the AP1000 design. The NRC staff is continuing a detailed review of your design certification application to ensure that the information is sufficiently complete to enable the NRC staff to reach a final conclusion on all safety questions associated with the design before the certification is granted.

The NRC staff has determined that additional information is necessary to continue the review. Four additional open items are included in the enclosure to this letter. The topics covered in these open items focus on materials issues. Specifically, the issues are associated with DSER Sections 4.5.2, Reactor Internal and Core Support Materials; 5.2.3, Reactor Coolant Pressure Boundary Materials; and 6.1, Engineered Safety Features Materials. These open items were sent to you via electronic mail on August 21, 2003. Please note that in the version sent via electronic mail, Open Item 4.5.2-1 referred to the VGN-5 core barrel, the attachment to this letter has been revised to refer to the core shroud.

Please contact one of the following members of the AP1000 project management team if you have any questions or comments concerning this matter: Mr. John Segala (Lead Project Manager) at (301) 415-1858, jps1@nrc.gov; Mr. Joseph Colaccino at (301) 415-2753, jxc1@nrc.gov; or Ms. Joelle Starefos at (301) 415-8488, jls1@nrc.gov.

Sincerely,

/RA/

Joelle L. Starefos, Project Manager  
New Reactors Section  
New, Research and Test Reactors Program  
Division of Regulatory Improvement Programs  
Office of Nuclear Reactor Regulation

Docket No. 52-006

Enclosure: New Open Items Associated with AP1000 DSER Sections 4.5.2, 5.2.3, and 6.1

cc: See next page

**ADAMS ACCESSION NO. ML032330275**

OFFICE	RNRP:PM	EMCB:BC	RNRP:SC
NAME	JStarefos	WBateman	LDudes
DATE	8/28/03	8/28/03	8/29/03

**OFFICIAL RECORD COPY**

Distribution for Open Item Letter for AP1000 Dated September 3, 2003

Hard Copy

PUBLIC	JSegala
RNRP R/F	JColaccino
JLyons	JStarefos
LDudes	

E-Mail

ACRS  
OGC  
WBateman  
ESullivan  
BElliot  
AKeim  
CLauron  
CAder  
SBajorek  
JFlack  
SRubin

**New Open Items Associated with AP1000 Draft Safety Evaluation Report  
(DSER) Sections 4.5.2, Reactor Internal and Core Support Materials; 5.2.3, Reactor  
Coolant Pressure Boundary Materials; and 6.1, Engineered Safety Features Materials**

**Open Item 4.5.2-1**

The core shroud is a welded assembly using cold worked 316L stainless steel. Given the increasing amount of light water reactor experience, will this component be immune to stress corrosion cracking, especially since the fast neutron flux will be increased over current designs? Discuss the impact of this potential aging effect on the integrity of the reactor core shroud, including the effect under accident scenarios. What inspections, if any, in addition to those required by the American Society of Mechanical Engineers (ASME) Code, will be performed by AP1000 combined license (COL) holders to detect these aging effects?

**Open Item 6.1-1**

The design of the shear section of the automatic depressurization system - stage 4 (ADS-4) squib valve may be creating a situation where there is a severe design notch in 316L stainless steel that is exposed to primary side coolant, and that this thin membrane is supporting the full system pressure. Discuss the possibility that stress corrosion cracking may occur in this region and give rise to premature activation of this valve. How was this possibility accounted for in the design?

**Open Item 5.2.3-2**

Alloy 52/152 materials are known to be difficult to weld. Address what examinations have been given to the adequacy of the quality assurance (QA) criteria for the Alloy 52/152 weldments that will be used to connect stainless steel piping to the ferritic pressure vessel? Address whether the QA criteria are commensurate with the risk associated with weldment failure?

**Open Item 5.2.3-3**

The high-chromium nickel-base alloys (e.g. Alloys 690/52/152, as well as 82 /182) may be susceptible to a significantly lowered fracture toughness if they have been exposed to high temperature hydrogenated water and then stressed at lower temperatures (e.g. <120C). This is a known phenomenon and may be of significance during a thermal shock event (i.e. during an accident scenario when there is ingress of large amounts of cold water into the primary system). Address whether this phenomenon could result in the failure of the nozzles between the pressure vessel and main recirculation or direct vessel injection (DVI) piping. If such a failure occurred, what are the consequences?

AP 1000

cc:

Mr. W. Edward Cummins  
AP600 and AP1000 Projects  
Westinghouse Electric Company  
P.O. Box 355  
Pittsburgh, PA 15230-0355

Mr. H. A. Sepp  
Westinghouse Electric Company  
P.O. Box 355  
Pittsburgh, PA 15230

Lynn Connor  
Doc-Search Associates  
2211 SW 1<sup>ST</sup> Ave - #1502  
Portland, OR 97201

Barton Z. Cowan, Esq.  
Eckert Seamans Cherin & Mellott, LLC  
600 Grant Street 44<sup>th</sup> Floor  
Pittsburgh, PA 15219

Mr. Ed Rodwell, Manager  
Advanced Nuclear Plants' Systems  
Electric Power Research Institute  
3412 Hillview Avenue  
Palo Alto, CA 94304-1395

Charles Brinkman, Director  
Washington Operations  
Westinghouse Electric Company  
12300 Twinbrook Parkway, Suite 330  
Rockville, MD 20852

Mr. R. Simard  
Nuclear Energy Institute  
1776 I Street NW  
Suite 400  
Washington, DC 20006

Mr. Thomas P. Miller  
U.S. Department of Energy  
Headquarters - Germantown  
19901 Germantown Road  
Germantown, MD 20874-1290

Mr. David Lochbaum  
Nuclear Safety Engineer  
Union of Concerned Scientists  
1707 H Street NW, Suite 600  
Washington, DC 20006-3919

Mr. Paul Gunter  
Nuclear Information & Resource Service  
1424 16th Street, NW., Suite 404  
Washington, DC 20036

Mr. Tom Clements  
6703 Guide Avenue  
Takoma Park, MD 20912

Mr. James Riccio  
Greenpeace  
702 H Street, NW, Suite 300  
Washington, DC 20001

Mr. James F. Mallay, Director  
Regulatory Affairs  
FRAMATOME, ANP  
3315 Old Forest Road  
Lynchburg, VA 24501

Mr. Ed Wallace, General Manager  
Projects  
PBMR Pty LTD  
PO Box 9396  
Centurion 0046  
Republic of South Africa

Mr. Vince Langman  
Licensing Manager  
Atomic Energy of Canada Limited  
2251 Speakman Drive  
Mississauga, Ontario  
Canada L5K 1B2

Mr. Gary Wright, Manager  
Office of Nuclear Facility Safety  
Illinois Department of Nuclear Safety  
1035 Outer Park Drive  
Springfield, IL 62704

Dr. Gail H. Marcus  
U.S. Department of Energy  
Room 5A-143  
1000 Independence Ave., SW  
Washington, DC 20585

Mr. Paul Leventhal  
Nuclear Control Institute  
1000 Connecticut Avenue, NW  
Suite 410  
Washington, DC 20036

Mr. Jack W. Roe  
SCIENTECH, INC.  
910 Clopper Road  
Gaithersburg, MD 20878

Patricia Campbell  
Winston & Strawn  
1400 L Street, NW  
Washington, DC 20005

Mr. David Ritter  
Research Associate on Nuclear Energy  
Public Citizens Critical Mass Energy  
and Environmental Program  
215 Pennsylvania Avenue, SE  
Washington, DC 20003

Mr. Michael M. Corletti  
Passive Plant Projects & Development  
AP600 & AP1000 Projects  
Westinghouse Electric Company  
P. O. Box 355  
Pittsburgh, PA 15230-0355