

August 21, 2003

LICENSEE: STP Nuclear Operating Company

FACILITY: South Texas Project, Unit 1

SUBJECT: SUMMARY OF U. S. NUCLEAR REGULATORY COMMISSION HEADQUARTERS AND REGION IV STAFF AND STP NUCLEAR OPERATING COMPANY STAFF TELEPHONE CONFERENCE ON JUNE 12, 2003, REGARDING SOUTH TEXAS PROJECT, UNIT 1, BOTTOM-MOUNTED INSTRUMENTATION PENETRATION LEAKAGE ISSUE; STATUS OF ACTIVITIES (TAC NO. MB8435)

On June 12, 2003, the U. S. Nuclear Regulatory Commission (NRC) Headquarters and Region IV staff held a telephone conference with STP Nuclear Operating Company staff, the licensee for South Texas Project, Unit 1. The conference call was a continuation of the ongoing discussions and was a follow up of the licensee's activities following the discovery of an apparent leakage at the interface of reactor vessel bottom-mounted instrumentation (BMI) penetrations 1 and 46. Enclosure 1 is a list of participants. Enclosure 2 is the telephone conference agenda.

At this phone call, the licensee summarized its activities related to Helium pressure tests, boat sample collection, and American Society of Mechanical Engineers (ASME) Boiler and Pressure Vessel Code (Code) relief requests pending NRC staff reviews. The licensee stated that Dominion Engineering was the contractor performing its fatigue analyses for planned new welds, old J-groove welds, and residual stresses.

Helium Pressure Tests

Helium pressure tests were performed on leaking BMI penetrations 1 and 46. Tests at a pressure of 100 psig did not show any leakage bubbles. When the pressure was increased to 150 psig, bubbles were seen escaping from penetration 1 at a rate of about 1 bubble per second at the J-groove adjacent to the tube wall and 1/4-inch from a grinding mark.

Boat Samples

The licensee discussed the structural integrity considerations of excavation of the boat samples obtained at other plant sites. At North Anna a penetration from the upper head was repaired after removal of a boat sample. At Oconee, a boat sample was taken from the remnant of the tube. D. C. Cook is a precedent, where a boat sample was removed and the tube was left unrepaired. The licensee will continue with its structural integrity analysis and, depending upon the results, may limit the size of the boat samples that can be left unrepaired.

Status of Code Relief Requests

The licensee will request a Code relief pursuant to Section 50.55a(a)(3)(i) of Title 10 of the *Code of Federal Regulations*, to permit removal of boat samples using electrical discharge machining in accordance with ASME Code Section XI, 1998 Edition through 2000 Addenda, which will demonstrate that removal of 1/16-inch material from a thermally processed area as specified in Code Section XI, 1989 Edition, no Addenda, is not necessary. The licensee stated that it will have a draft ready today.

Status of Repair Activities

The licensee has installed guide structures in the vessel, installed scaffolding, installed mechanical plugs, drained guide tubes, and will cut guide tubes from penetrations 1 and 46.

Schedular Items

A public meeting is scheduled for July 28, 2003. A reverse confirmatory action letter (CAL) followup letter will describe what the licensee did, and will include an assessment of why it is okay to restart. The root cause report will follow the reverse CAL followup.

/RA/

Mohan C. Thadani, Senior Project Manager, Section 1
Project Directorate IV
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket No. 50-498

Enclosures: As stated

cc w/enclosures: See next page

Status of Code Relief Requests

The licensee will request a Code relief pursuant to Section 50.55a(a)(3)(i) of Title 10 of the *Code of Federal Regulations*, to permit removal of boat samples using electrical discharge machining in accordance with ASME Code Section XI, 1998 Edition through 2000 Addenda, which will demonstrate that removal of 1/16-inch material from a thermally processed area as specified in Code Section XI, 1989 Edition, no Addenda, is not necessary. The licensee stated that it will have a draft ready today.

Status of Repair Activities

The licensee has installed guide structures in the vessel, installed scaffolding, installed mechanical plugs, drained guide tubes, and will cut guide tubes from penetrations 1 and 46.

Schedular Items

A public meeting is scheduled for July 28, 2003. A reverse confirmatory action letter (CAL) followup letter will describe what the licensee did, and will include an assessment of why it is okay to restart. The root cause report will follow the reverse CAL followup.

/RA/

Mohan C. Thadani, Senior Project Manager, Section 1
Project Directorate IV
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket No. 50-498

Enclosures: As stated

cc w/enclosures: See next page

DISTRIBUTION:

PUBLIC	RidsNrrPMMThadani	CMoyer
PDIV-1 Reading	RidsNrrPMWReckley	WCullen
RidsNrrLAMMcAllister	RidsNrrPMSBloom	JFoster
RidsNrrAdpt (BSheron/MKotzalas)	RidsNrrDeEmcb (SCoffin/MMitchell)	TMensah
RidsNrrDlpm (LMarsh/ELeeds)	RidsNrrDeEmeb (MHartzman)	JClark, EDO
RidsNrrDlpmLpdiv (HBerkow)	RidsRgn4MailCenter (AHowell/WJohnson)	
RidsNrrDlpmLpdiv1 (RGramm)	RidsNrrDe (RBarrett)	
RidsOgcRp	RidsAcrsAcnwMailCenter	

*See previous concurrences

ADAMS Accession No.: ML032330494

**via e-mail

NRR-106

OFFICE	PDIV-1/PM	PDIV-1/LA	RIV*	PDIV-1/SC*
NAME	MThadani:sab	MMcAllister	WJohnson**	Rgramm
DATE	8/21/03	8/21/03	08/21/03	08/20/03

LIST OF PARTICIPANTS

June 12, 2003

Licensee's Participants

Ed Halpin	Plant Manager
Louis Peter	Manager, Operations Support
Steve Thomas	Manager, Plant Design
Mark McBurnett	Manager of Quality and Licensing
Alex Kent	Manager, Testing/Programs
Harry Murray	BMI Project Manager
Scott Query	Project Manager
Wayne Harrison	Licensing Engineer
Ed Conway	Public Information
Alan Mikes	Public Information

NRC Participants

Headquarters

Robert Gramm
Mohan Thadani
Carol Moyer
Mark Hartzman
William Reckley
Steve Bloom
Jack Foster
Matthew Mitchell

Region IV

Dwight Chamberlain
William Johnson
Michael Runyan
Gail Good

TELEPHONE CONFERENCE AGENDA

June 12, 2003

- | | | |
|----|--|-----------|
| 1. | Desired outcomes & agenda | McBurnett |
| 2. | Overall status of Unit 1 | Peter |
| 3. | Deliverables | Gramm |
| 4. | Results of additional testing | Thomas |
| 5. | Status of repair activities | Murray |
| 6. | Schedule for next call or other communications
and feedback on call | McBurnett |

South Texas Project, Unit 1

cc:

Mr. Cornelius F. O'Keefe
Senior Resident Inspector
U.S. Nuclear Regulatory Commission
P. O. Box 910
Bay City, TX 77414

A. Ramirez/C. M. Canady
City of Austin
Electric Utility Department
721 Barton Springs Road
Austin, TX 78704

Mr. L. K. Blaylock
Mr. W. C. Gunst
City Public Service Board
P. O. Box 1771
San Antonio, TX 78296

Mr. C. A. Johnson/A. C. Bakken
AEP Texas Central Company
P. O. Box 289
Mail Code: N5022
Wadsworth, TX 77483

INPO
Records Center
700 Galleria Parkway
Atlanta, GA 30339-3064

Regional Administrator, Region IV
U.S. Nuclear Regulatory Commission
611 Ryan Plaza Drive, Suite 400
Arlington, TX 76011

D. G. Tees/R. L. Balcom
Texas Genco, LP
P. O. Box 1700
Houston, TX 77251

Judge, Matagorda County
Matagorda County Courthouse
1700 Seventh Street
Bay City, TX 77414

A. H. Gutterman, Esq.
Morgan, Lewis & Bockius
1111 Pennsylvania Avenue, NW
Washington, DC 20004

Mr. T. J. Jordan, Vice President
Engineering & Technical Services
STP Nuclear Operating Company
P. O. Box 289
Wadsworth, TX 77483

S. M. Head, Manager, Licensing
Nuclear Quality & Licensing Department
STP Nuclear Operating Company
P. O. Box 289, Mail Code: N5014
Wadsworth, TX 77483

Environmental and Natural Resources
Policy Director
P. O. Box 12428
Austin, TX 78711-3189

Jon C. Wood
Matthews & Branscomb
112 East Pecan, Suite 1100
San Antonio, TX 78205

Arthur C. Tate, Director
Division of Compliance & Inspection
Bureau of Radiation Control
Texas Department of Health
1100 West 49th Street
Austin, TX 78756

Brian Almon
Public Utility Commission
William B. Travis Building
P. O. Box 13326
1701 North Congress Avenue
Austin, TX 78701-3326

South Texas Project, Unit 1

-2-

cc:

Susan M. Jablonski
Office of Permitting, Remediation
and Registration
Texas Commission on
Environmental Quality
MC-122
P.O. Box 13087
Austin, TX 78711-3087

Mr. Terry Parks, Chief Inspector
Texas Department of Licensing
and Regulation
Boiler Division
P. O. Box 12157
Austin, TX 78711

Mr. Ted Enos
4200 South Hulen
Suite 630
Ft. Worth, Texas 76109

Mr. James J. Sheppard
President and Chief Executive Officer
STP Nuclear Operating Company
South Texas Project Electric
Generating Station
P. O. Box 289
Wadsworth, TX 77483