

September 11, 2003

MEMORANDUM TO: Laura Dudes, Section Chief
New Reactors Section
New, Research and Test Reactors Program
Division of Regulatory Improvement Programs, NRR

FROM: Joseph Colaccino, Senior Project Manager */RA/*
New Reactors Section
New, Research and Test Reactors Program
Division of Regulatory Improvement Programs, NRR

SUBJECT: AUGUST 14, 2003, AP1000 TELEPHONE CONFERENCE CALL
SUMMARY

On Thursday, August 14, 2003, a telephone conference call was held with Westinghouse Electric Company (Westinghouse) representatives and Nuclear Regulatory Commission (NRC) staff to discuss AP1000 draft safety evaluation report open item (DSER OIs) 3.7.2.3-1 and 3.7.2.3-2. The call participants are listed in Attachment 1. A summary of the conference call is included below.

The NRC staff discussed three issues after reviewing the Westinghouse response to DSER OI 3.7.2.3-1 provided to the NRC in a letter dated June 24, 2003 (ADAMS Accession Number ML031770042). Specifically, the NRC staff stated that Westinghouse has not addressed the concerns discussed in the DSER of the combined effect of the basemat uplift due to seismic excitation of the nuclear island and the effect of reduction of stiffness of shear walls. The NRC staff also stated that Westinghouse did not consider impact of the basemat in their analysis, which the NRC staff believes could be significant. In addition, with regard to shear wall cracking, the NRC staff stated that it could not draw a conclusion on the effect of the floor response spectra where member forces had increased by 10 percent because Westinghouse did not provide a comparison with the previous floor response spectra.

Westinghouse stated that they did not believe that the basemat uplift effected the floor response spectra. They stated that they would consider performing one analysis with reduced stiffness. After additional discussion, Westinghouse stated they wanted to consider the staff's concerns further and discuss these issues in a future call and/or meeting.

With regard to the response to OI 3.7.2.3-2 provided to the NRC in a letter dated June 24, 2003 (ADAMS Accession Number ML031760598), the NRC staff stated that they could not understand the results of the seismic amplification and seismic response analyses for the containment. Westinghouse stated that they would discuss their approach during a future NRC audit.

Docket No. 52-006

Attachment: As stated

cc w/att: See next page

September 11, 2003

MEMORANDUM TO: Laura Dudes, Section Chief
New Reactors Section
New, Research and Test Reactors Program
Division of Regulatory Improvement Programs, NRR

FROM: Joseph Colaccino, Senior Project Manager */RA/*
New Reactors Section
New, Research and Test Reactors Program
Division of Regulatory Improvement Programs, NRR

SUBJECT: AUGUST 14, 2003, AP1000 TELEPHONE CONFERENCE CALL
SUMMARY

On Thursday, August 14, 2003, a telephone conference call was held with Westinghouse Electric Company (Westinghouse) representatives and Nuclear Regulatory Commission (NRC) staff to discuss AP1000 draft safety evaluation report open item (DSER OIs) 3.7.2.3-1 and 3.7.2.3-2. The call participants are listed in Attachment 1. A summary of the conference call is included below.

The NRC staff discussed three issues after reviewing the Westinghouse response to DSER OI 3.7.2.3-1 provided to the NRC in a letter dated June 24, 2003 (ADAMS Accession Number ML031770042). Specifically, the NRC staff stated that Westinghouse has not addressed the concerns discussed in the DSER of the combined effect of the basemat uplift due to seismic excitation of the nuclear island and the effect of reduction of stiffness of shear walls. The NRC staff also stated that Westinghouse did not consider impact of the basemat in their analysis, which the NRC staff believes could be significant. In addition, with regard to shear wall cracking, the NRC staff stated that it could not draw a conclusion on the effect of the floor response spectra where member forces had increased by 10 percent because Westinghouse did not provide a comparison with the previous floor response spectra.

Westinghouse stated that they did not believe that the basemat uplift effected the floor response spectra. They stated that they would consider performing one analysis with reduced stiffness. After additional discussion, Westinghouse stated they wanted to consider the staff's concerns further and discuss these issues in a future call and/or meeting.

With regard to the response to OI 3.7.2.3-2 provided to the NRC in a letter dated June 24, 2003 (ADAMS Accession Number ML031760598), the NRC staff stated that they could not understand the results of the seismic amplification and seismic response analyses for the containment. Westinghouse stated that they would discuss their approach during a future NRC audit.

Docket No. 52-006

Attachment: As stated

cc w/att: See next page

ACCESSION NUMBER: ML032340029

OFFICE	RNRP/PM	EMEB	RNRP/SC
NAME	JColaccino	TCheng	LDudes
DATE	9/3/03	9/3/03	9/11/03

OFFICIAL RECORD COPY

Distribution for Call Summary dated September 11, 2003

Hard Copy

RNRP R/F

JLyons

JSegala

JStarefos

E-mail

PUBLIC

DMatthews

JMoore, OGC

RWeisman, OGC

TCheng

GBagchi

KManoly

AUGUST 14, 2003
TELEPHONE CONFERENCE CALLS SUMMARY
LIST OF PARTICIPANTS

Nuclear Regulatory Commission

J. Colaccino
T. Cheng

Westinghouse

R. Orr

AP 1000

cc:

Mr. W. Edward Cummins
AP600 and AP1000 Projects
Westinghouse Electric Company
P.O. Box 355
Pittsburgh, PA 15230-0355

Mr. H. A. Sepp
Westinghouse Electric Company
P.O. Box 355
Pittsburgh, PA 15230

Lynn Connor
Doc-Search Associates
2211 SW 1ST Ave - #1502
Portland, OR 97201

Barton Z. Cowan, Esq.
Eckert Seamans Cherin & Mellott, LLC
600 Grant Street 44th Floor
Pittsburgh, PA 15219

Mr. Ed Rodwell, Manager
Advanced Nuclear Plants' Systems
Electric Power Research Institute
3412 Hillview Avenue
Palo Alto, CA 94304-1395

Charles Brinkman, Director
Washington Operations
Westinghouse Electric Company
12300 Twinbrook Parkway, Suite 330
Rockville, MD 20852

Mr. R. Simard
Nuclear Energy Institute
1776 I Street NW
Suite 400
Washington, DC 20006

Mr. Thomas P. Miller
U.S. Department of Energy
Headquarters - Germantown
19901 Germantown Road
Germantown, MD 20874-1290

Mr. David Lochbaum
Nuclear Safety Engineer
Union of Concerned Scientists
1707 H Street NW, Suite 600
Washington, DC 20006-3919

Mr. Paul Gunter
Nuclear Information & Resource Service
1424 16th Street, NW., Suite 404
Washington, DC 20036

Mr. Tom Clements
6703 Guide Avenue
Takoma Park, MD 20912

Mr. James Riccio
Greenpeace
702 H Street, NW, Suite 300
Washington, DC 20001

Mr. James F. Mallay, Director
Regulatory Affairs
FRAMATOME, ANP
3315 Old Forest Road
Lynchburg, VA 24501

Mr. Ed Wallace, General Manager
Projects
PBMR Pty LTD
PO Box 9396
Centurion 0046
Republic of South Africa

Mr. Vince Langman
Licensing Manager
Atomic Energy of Canada Limited
2251 Speakman Drive
Mississauga, Ontario
Canada L5K 1B2

Mr. Gary Wright, Manager
Office of Nuclear Facility Safety
Illinois Department of Nuclear Safety
1035 Outer Park Drive
Springfield, IL 62704

Dr. Gail H. Marcus
U.S. Department of Energy
Room 5A-143
1000 Independence Ave., SW
Washington, DC 20585

Mr. Paul Leventhal
Nuclear Control Institute
1000 Connecticut Avenue, NW
Suite 410
Washington, DC 20036

Mr. Jack W. Roe
SCIENTECH, INC.
910 Clopper Road
Gaithersburg, MD 20878

Patricia Campbell
Winston & Strawn
1400 L Street, NW
Washington, DC 20005

Mr. David Ritter
Research Associate on Nuclear Energy
Public Citizens Critical Mass Energy
and Environmental Program
215 Pennsylvania Avenue, SE
Washington, DC 20003

Mr. Michael M. Corletti
Passive Plant Projects & Development
AP600 & AP1000 Projects
Westinghouse Electric Company
P. O. Box 355
Pittsburgh, PA 15230-0355