Final Submittal MCGUIRE JUNE 2003 EXAM 50-369/2003-301 AND 50-370/2003-301

JUNE 16 - 30, 2003

1. Combined RO/SRO[®] Written Exam with KAs,

Answers, References, and Analysis

1 Pt.	Whi sign	ch one of the following selec als to their limiting accident?	tions correctly matches the reactor trip
		Reactor Trip Signal	Limiting Accident/Protection
	А.	OP∆T OT∆T Pzr High Level Pzr Low Pressure	DNB Excessive fuel centerline temperature DNB NC system integrity
	В.	OP∆T OT∆T Pzr High Level Pzr Low Pressure	Excessive fuel centerline temperature DNB DNB NC system integrity
	C.	OP∆T OT∆T Pzr High Level Pzr Low Pressure	DNB Excessive fuel centerline temperature NC system integrity DNB
	D.	OP∆T OT∆T Pzr High Level Pzr Low Pressure	Excessive fuel centerline temperature DNB NC system integrity DNB
	Dist	racter Analysis:	
	А.	Plausible: PZR low press	∆ Fare reversed. sure and high level are correct.
	В.	Incorrect: All are incorrect	ct.
	C.	Incorrect : OPAT and OT	∆T are reversed.
	D.	Plausible: PZR low press Correct:	sure and high level are correct.
		Level: RO	
		KA: SYS 012 K5.01(3.3/3	.8)
		Lesson Plan Objective: O	P-MC-IC-IPE Obj. 2
		Source: Bank	
		Level of knowledge: Mem	ory
		References:	

...

		Bank Question:	50.1	Answer: D			
1 Pt	Given	the following condi	tions:				
	• • •	Unit 1 has experienced a large break LOCA 30 minutes have elapsed since the LOCA FWST Lo Lo level annunciator has just alarmed					
	Which the cor	Which one (1) of the following describes the operator actions for the alignment of the containment spray system after a LOCA?					
	А.	Reset Containment Spray and Phase 'B' and stop NS pumps within 45 seconds and manually swap the pump alignment to take suction on the containment sump.					
	В.	Reset Containme over to take a su reaches 33".	ent Spray a ction on the	nd the NS pumps will automatically swap e containment sump when FWST level			
	C.	Reset Containme within 45 second containment spr	ent Spray a Is when FW ay flow fror	nd Phase 'B" and stop the NS pumps VST level reaches 33" and initiate m the ND system.			
	D.	Reset Containme when FWST leve alignment to take	ent Spray a I reaches 3 e suction of	and stop the NS pumps within 45 seconds 3" and manually swap the pump n the containment sump.			
MISCINFO:		RO					
SOURCE:		BANK					
LEVEL OF M	NOWLD	EGE: Memory					
REFERENC	ES:	OP-MC-ECC-NS EP1/A/5000/FR-Z EP/1/A/5000/ES-1	3.2 page 31 .1 4,d,2 pag 1.3	1 ge 5			
LESSON:		OP-MC-ECC-NS					
OBJECTIVE	: 6,8						
K/A: 026000 K401 G 2.4.50 (3.3/		(3.1/3.6) 3.3)					

50.1 doc

1 Pt.	A large FR-Z.1 conditi	e break LOCA is in progress and the operators are responding in (<i>Response to High Containment Pressure</i>). Given the following ons:			
	• •	ND pump 1A is tagged out of service for maintenance. Containment pressure is 14 psig. FWST level reaches the swap-over setpoint.			
	When valve 1 operat	shifting to cold leg recirc using ES-1.3 (Transfer to Cold Leg Recirc), INI-184B (RB Sump to Train 1B ND & NS) fails to open. The ors implement ECA-1.1 (Loss of Emergency Coolant Recirculation).			
	FR-Z.1 (Response to High Containment Pressure) requires <u>both NS pumps</u> to be in operation. ECA-1.1 limits the operators to only <u>one NS pump</u> in step 6. Which of these two procedures takes priority under these conditions and what is the basis for this requirement?				
	А.	FR-Z.1 takes priority because a total loss of ND causes the NS system to become relatively more important to reduce containment pressure.			
	В.	FR-Z.1 takes priority because it was implemented in response to a red path and FRPs always have priority over ECA procedures.			
	C.	ECA-1.1 takes priority because it conserves FWST water level as long as possible for injection while providing sufficient NS flow to mitigate containment pressure.			
	D.	ECA-1.1 takes priority because ECA procedures always have priority over FRPs.			
	Distra A.	cter Analysis: Incorrect: ECA-1.1 takes priority over FR-Z.1 Plausible: Although a loss of ND and containment sump recirc causes a loss of the containment heat sink, the supply for NS comes from the FWST which will be drawn down until containment			
	В,	Incorrect: ECA-1.1 takes priority over FR-Z.1			
	C. D.	Correct answer Incorrect: ECAs do not always have priority over FRPs. Plausible: Some ECAs take priority e.g. ECA-0.0 has priority over FRPs in that F-0 is not applicable until transition out of ECA-0.0.			
Ques_051.1.doc	2				

Bank Question: 51.1

Answer: C

-

....

j,

	Banl	k Question: 60.1	Answer: A
1 Pt.	Unit the a been	2 was operating at 100 uxiliary building cable s implemented.	% power when an electrical fire started inside spreading room. AP/0/A/5500/45 Plant Fire has
	Whic actua perso	ch one of the following o ated inside the cable sp onnel if they enter this r	describes how the of fire suppression system is reading area and what are the hazards to oom?
	А.	An NLO is dispatch electrical shock ha combat an electrica	ned to open a manual deluge valve. An zard exists due to the use of water to al fire.
	В.	An NLO is dispatch actuation. An elect water to combat an	ned to verify automatic sprinkler system trical shock hazard exists due to the use of a electrical fire.
	C.	An NLO is dispatch actuation. An asph of Halon gas.	ned to verify automatic Halon system nyxiation hazard exists due to the presence
	D.	An NLO is dispatch asphyxiation hazar dioxide gas.	ned to actuate a manual Cardox system. An d exists due to the presence of carbon
	Distr	acter Analysis:	
	А. В.	Correct Answer: incorrect: A manua Plausible: an electr	l deluge Mulsifyre system is installed ical shock hazard exists
	C.	Incorrect: A manual Plausible: Halon gas fires are the predomi hazard	deluge Mulsifyre system is installed s is generally used in areas in which electrical inant risk because it does not create a shock
	D.	Incorrect: A manual Plausible: Cardox g CARDOX systems h switches still say CA generators)	deluge Mulsifyre system is installed gas is a personnel hazard – although all the ave been replaced with HALON, the pull RDOX in some areas (like the diesel
	LEVI	EL: RO	
	LEVI	EL OF KNOWLEDGE:	Memory
	sou	RCE: BANK	

KA: 000067 AK3.02 (2.5/3.3)

Ques_060.2.doc

•

;*

Lesson Plan: OP-MC-SS-RFY OBJECTIVE: OP-MC-SS-RFY Obj. 11 REFERENCE: OP-MC-SS-RFY pages 37, 49, 51, 53

Ques_060.2.doc

:

Ų.

Bank Question: 63.1 Answer: D

1 Pt Unit 1 is at 12% power with 4 NCPs running during a plant startup when an electrical transient occurs on the 6.9KV busses.

Given the following transient conditions:

		Electri	ical Bus	
Parameter	TA	TB	TC	TD
Frequency (Hz)	55	60	55	60
Voltage (Volts AC)	6800	6900	6800	6900

Offsite bus-line 1A is supplying TA and TC Offsite bus-line 1B is supplying TB and TD

Which one of the following describes the immediate plant response to this transient?

- A. No NCP pumps trip and the reactor does NOT trip
- B. The 1' A 'and 1 'C' NCPs trip and the reactor trips
- C. All four NCPs trip but the reactor does NOT trip
- D. All four NCPs trip and the reactor trips
- Level: RO
- SOURCE: BANK

Level of Knowledge: Analysis

- REFERENCES: OP-MC-PS-NCP pages 29 & 31 OP-MC-IC-IPE pages 47 & 81 OP-MC-EL-EP pages 41 & 43
- LESSON: OP-MC-PS-NCP OP-MC-IC-IPE OP-MC-EL-EP
- OBJECTIVE: OP-MC-PS-NCP Obj. 15 OP-MC-IC-IPE Obj. 10 OP-MC-EL-EP Objs. 23 & 24
- **K/A:** EPE 007 EA1.04 (4.2/4.1)

Ques_63.1.doc

Unit 1 has experienced an ATWS and the operators are performing the immediate 1 Pt action steps of FR-S.1 (Response to Nuclear Power Generation/ATWS). Given the following malfunctions: The reactor is manually tripped 1) The turbine fails to trip automatically and manually. 2) Which one of the following describes the operator's response in FR-S.1 to respond to failure of the turbine to trip? Place turbine in EMERGENCY MANUAL and close governor valves in Α. fast action and close all MSIVs Place turbine in MANUAL and close governor valves in fast action and Β. close all MSIVs Place turbine in MANUAL and close governor valves in fast action and C. if turbine will not runback then close all MSIVs and MSIV bypass valves Place turbine in EMERGENCY MANUAL and close governor valves in D. fast action and if turbine will not runback then close all MSIVs and **MSIV** bypass valves RO **MISCINFO: BANK - Modified** SOURCE: EP/1/A/5000/FR-S.1 page 2 **REFERENCES: OP-MC-EP-FRS** page 25 OBJECTIVE: 1) OP-MC-EO-FRS.Obj 4 K/A: 00012 K3.02 (3.2*/3.3) LEVEL OF KNOWLEDGE:: COMPRHENSION

1

ſ

.r.' 5

1 Pt Given the following plant conditions:

- Unit 1 in Mode 6.
- Reactor Missile Shield removed.
- "Norm-Refuel" Selector Switch in the REFUEL position.
- Fan Mode Selector Switch in the 100% position.
- 1EMF-38 trip 2 alarm.

Which one of the following selections describes the COMPLETE system response by the Containment Purge System?

Α.	Supply Fan (1B) will STOP. Supply Damper will CLOSE. Exhaust Fan (1B) will STOP. Exhaust Damper will CLOSE. Upper Containment Inside Isolation Valves will CLOSE. Upper Containment Outside Isolation Valves will CLOSE. Lower Containment Inside Isolation Valves will CLOSE. Lower Containment Outside Isolation Valves will CLOSE.
В.	Supply Fans (1A & 1B) will STOP. Exhaust Fan (1A & 1B) will STOP. Upper Containment Inside Isolation Valves will CLOSE. Upper Containment Outside Isolation Valves will CLOSE.
C.	Supply Fan (1B) will STOP. Exhaust Fan (1B) will STOP. Lower Containment Inside Isolation Valves will CLOSE. Lower Containment Outside Isolation Valves will CLOSE.
D.	Supply Fans (1A & 1B) will STOP. Supply Damper will CLOSE. Exhaust Fan (1A & 1B) will STOP. Exhaust Damper will CLOSE. Upper Containment Inside Isolation Valves will CLOSE. Upper Containment Outside Isolation Valves will CLOSE. Lower Containment Inside Isolation Valves will CLOSE. Lower Containment Outside Isolation Valves will CLOSE.
Di	stracter Analysis:
A.	Incorrect: Plausible:

- B. Incorrect:
- Plausible:
- C. Incorrect:

Ques_131.1.doc

Plausible:

D. Correct answer Plausible:

Level: RO

. .-

đ

Source: BANK

Level of Knowledge: Memory

Lesson: OP-MC-CNT-VP

Objective: OP-MC-CNT VP Obj. 3

KA: 029 K4.03 (3.2/3.5)

Ques_131.1.doc

Bank Question:	162.1	Answer: C
----------------	-------	-----------

- 1 Pt Which ONE (1) of the following Containment Radiation Monitors will initiate containment ventilation isolation as indicated by the corresponding sequence of actions?
 - A. EMF-38(H) trip-1 will secure VP and VQ, and shutoff containment sump pumps and incore sump pumps.
 - B. EMF-39(L) trip-1 will sound the containment evacuation alarm, and secures VP and VQ.
 - C. EMF-40 trip-2 will secure VP and VQ, and shutoff containment sump pumps and incore sump pumps.
 - D. EMF-41 trip-2 will secure VP and VQ, and shutoff containment sump pumps and incore sump pumps.
- LEVEL: RO
- SOURCE: BANK

REFERENCES: OP-MC-WE-EMF page 25

LESSON: OP-MC-WE-EMF

OBJECTIVE: OP-MC-WE-EMF Obj. 3

KA: SYS 103 A301 (3.9/4.2)

Ques 162.1.doc

1 Pt Unit 1 was operating at 100% when a pipe break occurred on the 1D S/G steam header. The operators are responding in E-2 (*Faulted Steam Generator Isolation*). The following sequence of events occurred:

- Isolation of the 1D S/G
- PZR level dropped to 0% and was restored to 20%
- NCS pressure is 1900 psig
- Safety Injection has not been reset

What are the correct panel actions for the restoration of power to pressurizer back-up heater bank D?

A. Reset safety injection on 1MC-6. Ensure AUTO is selected on the heater mode switch on 1MC-10 Select CLOSED on the heater breaker switch on 1MC-5 (vertical board)

- B. Ensure AUTO is selected on the heater mode switch on 1MC-5 Select CLOSED on the heater breaker switch on 1MC-10 Select ON for the heater control switch on 1MC-5
- C. Select MANUAL on the heater mode switch on 1MC-10 Select CLOSED on the heater breaker switch on 1MC-5 Select ON for the heater control switch on 1MC-10
- D. Reset safety injection on 1MC-6 Select MANUAL on the heater mode switch on 1MC-5 Select CLOSED on the heater breaker switch on 1MC-10 Select ON for the heater control switch on 1MC-5

Distracter Analysis: The B/U heater breakers will not close unless the mode selector switch is in MANUAL.

A. Incorrect: insufficient action, SI reset is unnecessary, and mode switch to MANUAL.
 Plausible; if the candidate is not familiar with the interlocks on the

Plausible: If the candidate is not familiar with the interfocks on the PZR heater circuit, the locations are correct.

- B. Incorrect: must turn the heater mode switch to MANUAL, and the locations are incorrect.
 Plausible: if the candidate reverses the panel locations and knows that SI reset is unnecessary, it would appear that this is the best answer.
- C. Correct answer: Bank D does not require SI reset
- **D. Incorrect**: Not necessary to reset safety injection and wrong locations for SI reset and heater controls.

Plausible: If the candidate does not know the panel locations, this is the right method for Banks A&B (and would work for D) and was correct in the prior version of the question.

Level: RO

÷

÷

KA: SYS 010 G2.1.31 (4.2/3.9)

Lesson Plan Objective: OP-MC-PS-ILE Obj. 11

Source: BANK

Level of knowledge: comprehension

References: 1. OP-MC-PS-IPE page 19 1 Pt After a loss of all AC power (station blackout), ES 0.2 (*Natural Circulation Cooldown*) is implemented after AC power has been restored.

Given the following conditions:

- 1) NC pumps cannot be restarted.
- 2) Power has been restored to all station AC busses.
- 3) A natural circulation cooldown is in progress.

Step 18 of ES 0.2 requires that the operators maintain subcooling greater than 50 degrees if all CRD fans are running and greater than 100 degrees if less than all CRD fans are running using core exit thermocouples.

What is the EOP basis for these limits?

- A. To prevent degradation of reactor coolant pump seals due to steam.
- B. To prevent possible void formation in the upper head.
- C. To collapse any voids formed in the CRD housings.
- D. To ensure adequate subcooling due to possible degradation of core exit T/Cs accuracy.
- LEVEL: RO

SOURCE: BANK

LEVEL OF KNOWLEDGE: Comprehension

REFERENCES: EP/1/A/5000/ES0.2 step 18 OP-MC-EP-E0 6.4.18 page 147

LESSON: OP-MC-EP-E0

OBJECTIVE: OP-MC-EP-E0 Obj. 6

K/A: W/E09 EK2.1 (3.2/3.4)

Ques_47.1

Pt Unit 1 was operating at 100% power when a total loss of feedwater occurred. The operators reached Step 7 of FR-H.1 (*Response to Loss of Secondary Heat Sink*), which attempts to establish CA flow to at least one S/G. Sub-step 7.k states:

Maintain feed flow rate less than or equal to 100 GPM until S/G WR level is greater than 12% (17% ACC).

Given the following conditions:

	Loop A	Loop B	Loop C	<u>Loop D</u>
S/G (WR) [%]	0	15	9	10
NC T _{Hot} [°F]	150	555	530	545

- Containment pressure is 3.4 psig
- The TD CA pump is available to feed the S/Gs

Which one of the following statements correctly describes the bases for the restrictions for restoring feedwater flow following feed and bleed in FR-H.1?

- A. Restore flow to the 'A' S/G because loop 'A' T-hot is the lowest of the loops and this will reduce the chance of thermal shocking the S/G. Flow should not be restored to the 'B' and 'C' S/Gs because they will be reserved for use later to provide a steam supply for the TD CA pump.
- B. Restore flow to the 'B' S/G because 'B' S/G level is the highest and this will reduce the chance of thermal shocking the S/G. Flow should be preferentially restored to the 'B' or 'C' S/G to maintain the TD CA pump steam supply.
- C. Restore flow to the 'C' S/G because loop 'C' T-hot is less than loop 'B' T-hot and this will reduce the chance of thermal shocking the S/G. Flow should be preferentially restored to the 'B' or 'C' S/G to maintain the TD CA pump steam supply.
- D. Restore flow to the 'D' S/G because the 'D'S/G is higher than 'A' S/G level, which will reduce the risk of thermal shock. Flow should not be restored to the 'B' and 'C' S/Gs because they will be reserved for use later to provide a steam supply for the TD CA pump.

Distracter Analysis: The guidance is to select the S/G that has the

highest apparent level and to preferentially select the B or C S/G.

1 Pt

÷

Ques_191.3.doc

- A. Incorrect: T-hot should not be used to determine which S/G should receive flow. It is not a reliable means of determining S/G shell temp in a dry stagnant loop.
 Plausible: The apparent temp of the A loop is the lowest and it may appear that the chance of thermal shock is lessened.
- **B. Correct answer**: feed the S/G that has the highest level and preferentially feed B & C S/Gs to maintain steam supply to the TD CA pump.
- C. Incorrect: C S/G has a lower S/G level than B S/G Plausible: C S/G has a lower T-hot than B S/G
- D. Incorrect: No basis for reserving the B & C S/Gs for restoring flow Plausible: There is a high probability that restoring feed to a dry S/G could rupture the tube sheet due to thermal stress. It makes sense to select a S/G that is NOT used to supply steam to the TD CA pump for the initial restoration of the heat sink.

Level: RO

KA: W/E05 2.4.18 (2.7/3.6)

Level of Knowledge: Analysis

Lesson Plan Objective: OP-MC-EP-FRH, Obj.4

Source: BANK

References: 1. EP/FR-H.1, Step 7.k (NOTE prior)

Ques_191.3.doc

2

- 1 Pt Unit 1 was conducting a plant start up. At 1% power, an instrument malfunction caused an inadvertent reactor trip. Given the following indications:
 - Two rod bottom lights are NOT lit
 - Reactor trip and bypass breakers are open
 - IR amps = 2x10⁻⁸
 - IR SUR = -0.3 DPM

Which one of the following response actions is required?

- A. Implement AP/14, (*Control Rod Misalignment*) and respond to the stuck rods.
- B. Implement E-0, (*Reactor Trip or Safety Injection*), and immediately transition to FR-S.2, (*Response to Loss of Core Shutdown*).
- C. Implement E-0, (*Reactor Trip or Safety Injection*) and immediately transition to FR-S.1, (*Response to Nuclear Power Generation/ATWS*).
- D. Implement E-0, (*Reactor Trip or Safety Injection*), and then transition to ES-0.1, (*Reactor Trip Response*).

Distracter Analysis: The RNO will evaluate the need to transition to FR-S.1 based on indications of reactor criticality. Transition is not appropriate unless reactor power is > 5% and not decreasing.

- A. Incorrect: If above P-11 (1955 psig) must use E-0.
 Plausible: This would be the correct answer for a reactor trip below P-11.
- **B. Incorrect**: There is no yellow path because SUR < -0.2dpm. In addition, F-0 is not in effect at this point in the procedure **Plausible**: This would be the correct response if SUR > -0.2 dpm.
- C. Incorrect: inappropriate to enter FR-S.1 because the reactor is subcritical and F-0 is not in effect
 Plausible: If the candidate makes a literal reading of E-0 without knowledge of the ERG background positions on what constitutes a tripped reactor. Some plants enter FR-S.1 for two rods stuck out.
- D. Correct:

Level: RO

KA: W/E 01 EK1.2 (3.4/4.0)

Lesson Plan Objective: EP-EO Obj. 10

Source: BANK

. 1

Level of knowledge: Memory

References:

1. OP-MC-IC-IRE page 35 2. OP-MC-EP-FRS page 15, 17 3. OP-MC-EP-E0 pages 19, 27

4. F-0 page 1

5. E-0 page 3 6. AP-14 page 2

Ba	ank Quest	tion: 228.1 Answer: B
1 Pt	Unit ONE suspe	1 is in mode 6 and in the process of unlatching control rods. Which (1) of the following limiting conditions requires immediately ending all CORE ALTERATIONS in the Reactor Building?
	А.	Loss of one channel of SR NIs with both Gamma Metric SDMs in operation.
	В.	Loss of direct communications between the control room and the refueling bridge (refueling station).
	C.	Loss of the Fuel Handling Ventilation System.
,,,	D.	Time since entering mode 2 is 102 hours.
LEVEL:	RO	

SOURCE: BANK

LEVEL OF KNOWLEDGE: Memory

REFERENCES: SLC 16.9.18 OP-MC-FH-FC pages 11, 27, 33 Tech Spec 3.9.3

LESSON: OP-MC-FH-FC

OBJECTIVE: OP-MC-FH-FC Objs. 1 & 7

KA: G 2.2.27 (2.6/3.5)

1 Pt Unit 1 is operating at 50% power. Given the following conditions: Pressurizer pressure is 2235 psig Pressurizer Relief Tank (PRT) pressure is 20 psig ۰ PRT temperature is 125 °F PRT level is 81% The PRT is being cooled by spraying from the RMWST A pressurizer code safety valve is suspected of leaking by its seat What temperature would be indicated on the associated safety valve discharge RTD if the code safety were leaking by? **REFERENCES PROVIDED: Steam Tables** Α. 258-262 °F B. 227-231 °F C. 161-165 °F D. 123 -127°F **Distracter Analysis:** Α. **Correct** answer В. Incorrect: Temp is too low - the correct temp is 260 °F Plausible: If the candidate makes the mistake of not correcting for atmospheric pressure by failing to adding 14.6 psi to the PRT pressure and uses 20 psia. C. Incorrect: Temp is too low - the correct temp is 260 °F Plausible: If the candidate reverses the correction for atmospheric pressure by subtracting 14.6 psi from PRT pressure of 20 psig to get 5 psia. D. Incorrect: Temp is too low - the correct temp is 260 °F Plausible: If the candidate thinks that the discharge temperature will be at the same temperature as the PRT fluid. Level: RO KA: SYS 010 K5.02 (2.6/3.0*) Source: BANK Level of Knowledge: Analysis Objective: OP-MC-THF-EB Obj. 8

Reference: OP-MC-THF-EB pages 23-26

Ques_311.2.doc

1 Pt In E-3 (Steam Generator Tube Rupture) Enclosure 5 (NC Pressure and Makeup Control to Minimize Leakage) the operators are directed to energize pressurizer heaters if the ruptured S/G level is decreasing and pressurizer level is greater than 25%. What is the purpose for this action? Α. Maintain pressurizer saturation temperature corresponding to ruptured S/G pressure to minimize S/G leakage into the NC system. Β. Maintain pressurizer saturation temperature corresponding to intact S/G pressure to minimize primary leakage into the S/G. Maintain pressurizer saturation temperature above the C. corresponding ruptured S/G pressure to ensure S/G water does not flow into the NC system. Maintain pressurizer saturation temperature corresponding to D. intact S/G pressure to minimize NC pressure transients. Distracter Analysis: The purpose of this question is to determine if the candidate understands that thermal hydraulic equilibrium (temp/press/leak rate) needs to be established between the NCS and the ruptured S/G. No references are provided because the candidate should be able to answer the question by simply comprehending the pressures and reasons for this equilibrium. Α. **Correct Answer: Incorrect**: required to maintain NCS pressure equal to ruptured Β. S/G pressure, not the intact S/G - Intact S/G pressure < ruptured S/G pressure would not reduce NCS to S/G leakage Plausible: if the candidate is confused over the thermal hydraulics Incorrect: required to maintain NCS pressure equal to ruptured C. S/G pressure Plausible: partially correct - do not want leakage from S/G to NCS or NCS to S/G D. Incorrect: required to maintain NCS pressure equal to ruptured S/G pressure, not the intact S/G Plausible: this would be a reasonable basis for monitoring intact S/G pressure if that were the correct answer. Level: RO

KA: EPE 038 EK1.02(3.2/3.5)

Lesson Plan Objective: OP-MC-EP-EP3 Obj 4

Source: Bank

~

Level of knowledge: comprehension

References:

1. OP-MC-EP-EP3 pages 19, 101, 119 2. EP/1/A/5000/E-3 pages 56, 57

Ques_321.1.doc

Bank	Question:	330.1
------	-----------	-------

Answer: B

During a cold startup, the NCPs are limited to 3 consecutive starts in any 2-1 Pt hour period. There is an additional requirement of a minimum idle period of 60 minutes between restarts. What is the reason for these limitations? This restriction assures that the NCP oil temperature will Α. decrease to design specifications between restart attempts. This restriction prevents overheating the motor windings due В. to high starting currents. This restriction allows the NCP seals to fully reseat between C. NCP oil lift pump cycles. This restriction ensures adequate Number 1 Seal Leakoff flow. D. للمراجع للمرجع والمجموع في ووجع من المرجع المرجع المرجع المرجع المرجع المرجع المرجع المرجع المرجع الم **Distracter Analysis:** Incorrect: The reason is stator-winding temperatures А. Plausible: if the candidate remembers this as a high temperature concern - another adverse consequence of multiple starts on motors **Correct Answer:** Β. Incorrect: The reason is stator-winding temperatures C. Plausible: NCP seal seating is the basis for a different cold start precaution - seal leakoff limit after seal replacement Incorrect: The reason is stator-winding temperatures Ď. Plausible: if the candidate is confused regarding the basis for the precaution. Level: RO Source: BANK Level of Knowledge: Memory KA: G2.1.32 (3.4/3.8) **References:** 1. OP-MC-PS-NCP page 35

	Bank Question: 359.3 Answer: D
1 Pt	Unit 1 is responding to a small break LOCA using E-1 (Loss of Reactor or Secondary Coolant). Given the following events and conditions:
	 FWST Level = 340 inches Containment pressure = 1.5 psig Containment Sump Level = 1.05 ft EMF-41 (AUX BLDG VENTILATION) = trip 2 Aux Building area radiation monitors are in alarm EMF-51A and B (CONTAINMENT TRN A & B) = 25 R/Hr Hydrogen Analyzer = 0.7% in containment NLO's report significant leakage at the seals of the 1A ND pump
	Which one of the following procedures should the operator transition into from E-1?
	A. FR-Z.3 (Response to High Containment Radiation Level)
	B. ECA-1.1 (Loss of Emergency Coolant Recirculation)
	C. FR-Z.4 (Response to High Containment Hydrogen)
	D. ECA-1.2 (LOCA Outside Containment)
	Distracter Analysis: The initial conditions provide a LOCA into containment and a leakage path outside of containment. The question is which of the problems take priority? The purpose is not to memorize procedure steps but to answer this from a broader perspective.
	 A. Incorrect: Cont RAD levels < 35 R/hr and this would be a YELLOW path that does NOT require priority action. Plausible: If the candidate thinks that the abnormal radiation level requires priority action.
	 B. Incorrect: Still in injection phase of SI – have failed to isolate leak outside containment. Plausible: if candidate is not familiar with the entry conditions for ECA 1.1 (after failure to isolate leak outside containment).
	 C. Incorrect: Cont H2 > 0.5 %, but this is a YELLOW path not requiring priority action. Plausible: If the candidate fails to recognize the leak in the auxiliary bldg and/or the fact that E-1 takes care of the cont H2 problem.
	D. Correct:
	Level: RO
	KA: WE 04EK3.2 (3.4 /4.0)

Ques_359.3.doc

_--

л

* ` Lesson Plan Objective: OP-MC-EP-E1 Obj 2

Source: BANK

•

ý.

Level of knowledge: comprehension

References:

- 1. OP-MC-EP-E1 page 45 2. EP/1/A/5000/E-1 pages 12-14
- 3. EP/1/A/5000/F-0 page 9

Answer: D

1 Pt Unit 2 was at 10% during a plant startup when a loss of condenser vacuum occurred. Given the following conditions:

- The reactor was tripped
- The steam dump select switch was in steam pressure mode
- Condenser vacuum dropped to 18 inches
- No component or instrument failures occurred
- No operator action taken

Which one of the following sequences best describes the actuation of the steam dumps to this event?

	Condenser dump valves	Atmospheric dump valves
А.	open	open
В.	open	shut
C.	shut	open
D.	shut	shut

Distracter Analysis:

- A. Incorrect: the condenser dumps will not open due to the C9 arming signal not present caused by a low vacuum condition (20 in) The atmospheric dumps will not open because they do not actuate when the steam dump selector switch is in steam pressure mode Plausible: this would occur if the transition had not yet been made to steam pressure mode and C9 had actuated a normal plant response during a startup < 10% power.</p>
- B. Incorrect: the condenser dumps will not open due to the C9 arming signal not present caused by a low vacuum condition
 Plausible: this sequence would occur if there was not a loss of condenser vacuum or if the candidate does not recognize the interaction between condenser pressure and the C9 arming signal.
- C. Incorrect: the atmospheric dumps will not open because they do not actuate when the steam dump selector switch is in steam pressure mode

Plausible: - this sequence would occur if the plant was in Tave mode above ~55% - the transition from Tave to steam pressure mode occurs by procedure at 10% power

D. Correct answer

Level: RO

KA: APE 051 AK.3.01 (2.8*/3.1*)

Ques_373.1.doc

Lesson Plan Objective: STM-IDE LPSO 5, 6, 9

Source: Bank

~

÷

Level of Knowledge: comprehension

References: 1.OP-MC-STM-IDE pages 17-35 (odd only)

Ques_373.1.doc

 1 Pt
 Unit 1 has initiated a liquid radioactive waste release from the Ventilation Unit Condensate Drain Tank (VUCDT) through the RC system. All lineups and authorizations have been properly made in accordance with OP/1/A/6500/001 A using the <u>normal</u> path. Two RC pumps are the minimum required under the LWR document.
 Given the following initial conditions:

 3 RC pumps are running
 1EMF-44 (CONT VENT DRN TANK OUT) correctly set for trip 1 and

- 1EMF-44 (CONT VENT DRN TANK OUT) correctly set for trip 1 and trip 2 activity limits
- No other releases are in progress

If the release automatically terminates 40 seconds after initiation, which one of the following conditions could have terminated the release?

- A. 1WM-46 (LIQUID WASTE DISCH VALVE) closing automatically if 2 RC pumps trip
- B. 1WM-46 closing automatically if 1EMF-44 reached the trip 2 setpoint
- C. 1WP-35 (WMT & VUCDT TO RC CNTRL) closing automatically if 1 RC pump tripped
- D. 1WP-35 closing automatically if 1EMF-44 reached the trip 2 setpoint

Distracter Analysis:

- A. Incorrect: RC pump interlock will not actuate set at 2 pumps (minimum required on LWR document). WM-46 is isolated and not used anymore as a release path.
 Plausible: - this was formerly the normal release path
- **B.** Incorrect: WM-46 receives a closing signal from EMF-44 but this is not the normal path for a release. WM-46 is isolated and not used anymore.

Plausible: - this was formerly the normal release path

- C. Incorrect: RC pump interlock will not actuate set at 2 pumps (minimum required on LWR document). Plausible: - if the candidate misunderstands the RC pump
 - interlock--this was the correct answer on a prior NRC exam -
- D. Correct answer

Levei: RO

KA: G 2.3.11 (2.7/3.2)

Lesson Plan Objective: OP-MC-WE-WL Obj. 3

Source: Bank

÷

Level of knowledge: Comprehension

References:

1. OP-MC-WE-WL pages 21, 23, 27, 59

2. OP-MC-WE-EMF page 31

3. OP-MC-WE-RLR page 11 and 13

	Bank Question: 432.3	Answer: A		
1 Pt	Unit 1 has just entered Mode 5 in preparation for refueling. Given the following conditions and events:			
	 A lower containment entry is planned for the next shift. The SRO directs the RO to purge the containment in preparation for the containment entry. Currently the VP system is secured with all fans off and containment purge and exhaust valves closed Which one of the following describes the proper alignment of the containment purge system? 			
		B. The NORMAL-REFU "NORM" position and Containment).	EL SELECTOR switch is placed in the dratio of supply air is 4/1 (Upper/Lower	
	C. The NORMAL-REFUL "REFUEL" position a Containment).	EL SELECTOR switch is placed in the Ind ratio of supply air is 2/1 (Upper/Lower		
	D. The <i>NORMAL-REFUL</i> " <i>REFUEL</i> " position a Containment).	<i>EL SELECTOR</i> switch is placed in the Ind ratio of supply air is 4/1 (Upper/Lower		
	Distracter Analysis:			
	 A. Correct: - this is the p B. Incorrect: Air ratio is Plausible: - 	proper position for this operation. 2/1 not 4/1		
	C. Incorrect : - this will of D. Incorrect: - this will ov Plausible: .	ver-pressurize the upper containment /er-pressurize the upper containment.		
	Level: RO			
	KA: G 2.3.9 (2.5/3.4)			
	Lesson Plan Objective	: CNT-VP Obj. 2		
	Source: BANK			
	Level of knowledge: Comprehension			

Ques_432.3.doc

. ___

`,

ţ

References: 1. OP-MC-CNT-VP pages 19, 21, 23

Ques_432.3.doc

;

•

____.

•

\$

1 Pt	Unit 1 is shutdown in a refueling outage. Given the following events and conditions:				
	 The VI system was in a normal lineup. The VS system was in a normal lineup. A VI header rupture occurs. The VI system completely depressurizes. 				
	What effect does a total loss of the VI system have on the VS system?				
	A.	VI-820 will auto-close as VI header pressure decreases below 82 psig and the VS air compressor will start automatically to maintain VS header pressure.			
	В.	VI-820 will auto-close as VI header pressure decreases below 90 psig and the VS air compressor must be manually started to maintain VS header pressure.			
	C.	Check valves in the VI - VS cross-connect line will close to isolate VS system pressure before it drops below 90 psig.			
	D.	VS pressure in the Fire Protection Pressurizer Tank will be lost until a VS air compressor can be started.			
	Distracter Analysis:				
	A.	Incorrect: - the VS air compressor does not automatically start to maintain pressure Plausible: - The VI system is safety significant, VI-820 used to close 82 psig but the setpoint was recently changed from 82 psig to 90 psig. There is a separate VS air compressor, which has an automatic startup feature – but is normally in "off" and requires operator action to start.			
	В. С.	Correct answer Incorrect: - there are no check valves in this line Plausible: - this is another possible method to prevent depressurizing the VS header at some plants			
	D.	Incorrect: - the RF system tank is pressurized with VS air - but is maintained isolated from the VI header Plausible: - if the candidate does not know that the RF system air tank is isolated from the VS header.			
		Level: RO			
		KA: SYS 078 K4.01 (2.7/2.9)			
		Lesson Plan Objective: SS-MC-SS-VI Obj. 7			

Ques_451.1.doc

Source: Bank

*

Level of Knowledge: comprehension

References: 1. OP-MC-SS-VI page 115

Ques_451.1.doc

Bank Question:	531.1	Answer: C
----------------	-------	-----------

Unit 2 is operating at 75% power when a load rejection occurs. Which one of the following statements correctly describes the response of 2CM-420 (Load Rej Byp) to this transient?

- A. 2CM-420 closes to prevent condensate water from being diverted to the suction of the hotwell pumps from the condensate booster pumps to assure minimum flow to the CF pumps.
- B. 2CM-420 closes to prevent diversion of water from the "C" heater drain tank back to the UST thereby ensuring sufficient CF pump suction pressure.
- C. 2CM-420 opens to divert condensate flow directly to the condensate booster pump suction to ensure that CF pumps have sufficient suction pressure.
- D. 2CM-420 opens to divert condensate flow, bypassing around the condensate booster pumps, directly to the CF pumps to assure minimum flow requirements.

گاههه عند گروه به من ۲ و به من ۲ و به من ۲ و و بر من ۲ و و و بر من ۲ و و و به من ۲ و و و به من ۲ و و و منظور و

Distracter Analysis:

- A. Incorrect: CM-420 opens does not close. Does not prevent water from being recirculated around the hotwell pumps.
 Plausible: this function is performed by CM-407 which opens to assure minimum flow around the hotwell pumps to prevent water hammer on the CM system during startup.
- B. Incorrect: CM-420 opens does not close. Does not prevent a loss of water to the condensate booster pump suction.
 Plausible: CM-227 opens to recirc condensate from the C feedwater heater to the USTs to assure minimum recirc flow on the CBPs
- C. Correct answer
- **D.** Incorrect: CM-420 does not provide a flow path around the condensate booster pumps directly to the CF pumps to meet minimum flow requirements
 Plausible: CM-420 opens to provide bypass flow but directly to the CBPs not the CF pumps

Level: RO

Level of Knowledge: Memory

Source: BANK

Ques_531.1.doc

1 Pt

K&A: 056 A2.04 (2.6/2.8*)

.,

è

Lesson Plan: OP-MC-CF-CM Obj. 11

References: OP-MC-CF-CM page 33 & 67

Ques_531.1.doc
	Bank	Question: 547.2 Answer: C					
1 Pt	Unit from and c	1 was operating at 100% power when main condenser vacuum drops 25 inches vacuum to 23 inches vacuum. Given the following events conditions:					
	• A • B • T	 All 3 condenser steam air ejectors (CSAEs) are in service Both primary and secondary jets are operating The system lineup is in the normal configuration 					
	Whic probl	h one of the following statements correctly describes the cause of this em?					
	А.	Loss of YM supply to the condenser boot seals					
	В.	Loss of Main Steam to the CSAEs					
	C.	CM flow to all CSAE inter-coolers has been obstructed					
	D.	A CSAE drain was left open					
	Distr	Distracter Analysis:					
	Α.	Incorrect : A recent change no longer runs seals water to the condenser boot seals. Plausible: Seal water to the boot seals was originally designed to					
	B.	prevent condenser leakage Incorrect : Main steam does not supply the CSAEs Plausible : There are physical connections for main steam to be the back up supply for aux steam – but these connections are not used					
	C.	Correct answer - reduces effectiveness of steam jets and causes					
	D.	Incorrect: CSAE drains are normally open to allow condensate to drain out of the air ejectors. Plausible : If the drain is left closed, the condensate will build up and flood out the CSAE, which could cause a loss of vacuum. This is the reverse of the distracter.					
		Level: RO					
		KA: SYS 055K3.01 (2.5 / 2.7)					
		Lesson Plan Objective: MT-ZM SEQ 4, 5, 9					
		Source: Bank					
		Level of knowledge: comprehension					

_.___

.

References: 1. OP-MC-MT-ZM pages 11, 13, 15, 23, 27

Ques_547.2.doc

بر

;

	Bank	Question: 548.1	Answer: A		
1 Pt	Unit 1 outage events	was operating in Mode 3 du . If a safety injection signal will occur to protect the vita	ring a plant shut down for a refueling is received, which one of the following I AC busses from overload?		
	А.	Only non-LOCA loads wi will sequence remaining bus voltage.	II be shed. The accelerated sequence loads on after checking for adequate		
	В.	A complete load shed wi will sequence LOCA load voltage and DG speed.	ll occur. The accelerated sequence Is on after checking for adequate bus		
	C.	A complete load shed wi will sequence LOCA load voltage.	ll occur. The accelerated sequence Is on after checking for adequate bus		
	D.	Only non-LOCA loads wi will sequence remaining bus voltage and DG spee	II be shed. The accelerated sequence loads on after checking for adequate ed.		
	Distracter Analysis:				
	А. В. С. D.	Correct answer Incorrect: only non-LOCA sequence does not check? Plausible: DG speed is ch during a blackout signal Incorrect: only non-LOCA Plausible: the remaining p Incorrect: the accelerated during a LOCA Plausible: DG speed is ch during a blackout signal	loads are shed, the accelerated for DG speed during a LOCA ecked when the sequencer is actuated loads are shed part of the answer is correct sequence does not check for DG speed necked when the sequencer is actuated		
		Level: RO			
		KA: SYS 013 K4.11(3.2/3.3	3)		
		Lesson Plan Objective: DG	-EQB Obj 6		
		Source: Bank;			
		Level of knowledge: Memo	ry		
		References:			

.....

e de la companya de l

/,

1. OP-MC-DG-EQB page 25

Ques_548.1.doc

2

22

	Bank	Question: 593.1	Answer: B
1 Pt	Unit 2 Giver	was operating at 99% p the following events and	ower when a steamline break occurred. I conditions:
	0200 0200 0201 0202 0203	The operators enter All The operators start rec The operators start a s NLOs start investigatin <i>P/R OVER POWER R</i> power is now going do	2/01 (Steam Leak) ucing turbine load to match T _{ave} and T _{ref} econd NV pump and isolate letdown g for the location of the steam leak OD STOP alarms – the RO reports that wn.
	0204	The turbine building op atmospheric dump valv	erator reports that the line to the ves has a steam leak and cannot be isolated
	lf no s which	safety injection has occur one of the following ope	red and pressurizer pressure is maintained, rator responses is correct?
	А.	Manually trip the read	tor at 0203
	в.	Manually trip the read	tor at 0204
	C.	Manually trip the read	tor at 0205
	D.	Commence a rapid de <i>Downpower</i>) at 0205	own power using AP/04 (<i>Rapid</i>
	Distra	acter Analysis:	,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,
	A.	Incorrect: no requirem has turned and is decre automatic reactor trip a Plausible : shows a por 103% on 1 of 4 PR cha Abnormal and Emerge when an automatic saf avoid challenging the a	ent to trip the reactor because reactor power easing. Not approaching the overpower t 109% in 2 of 4 channels. wer mismatch reactor power reaches annels to cause C-2. OMP 4-3 (<i>Use of</i> <i>ncy Procedures</i>) requires the operator to trip eguards action setpoint is approached to automatic safeguards function.
	В.	Correct answer require procedures) if you can our	ed to trip under AP/01 (and many other not maintain pressurizer level with 2 NV
	C.	Incorrect: required to the Plausible: if the candid because the steam lead	rip when PZR level cannot be maintained late thinks that a reactor trip is required k was not isolated.
	D.	Incorrect : required to the Plausible : this would be 0204.	rip when PZR level cannot be maintained the correct answer if not required to trip at

-

Level: RO

÷

Ŷ

KA: W/E12 EA1.03(3.4/3.9)

Lesson Plan Objective: AP-1 Obj. 4

Source: Bank;

Level of knowledge: comprehension

References:

1. AP/1/A/5500/01 page 3

2. OP-MC-IC-IPE page 45 3. OMP 4-3, page 8

Ques_593.1.doc

Bank Question: 617.2 Answer: A

1

ŝ.

1 Pt Unit 2 was operating at 90% power after a start-up from a refueling outage. A pressurizer PORV is found to be leaking and the associated PORV block valve was shut. The PRT was cooled down to the following PRT conditions:

- PRT Level 65%
- PRT Pressure 9 psig
- PRT Temperature 100°F
- Lower Containment Temperature 118 °F

What actions are required to restore and maintain normal operating conditions to the PRT for the long term?

- A. Vent the PRT to the waste gas system.
- B. Vent the PRT to containment.
- C. Cool the PRT by pressurizing with nitrogen and initiating spray flow from the NCDT.
- D. Cool the PRT by initiating spray flow through the sparger line from the RWST

Distracter Analysis: With PRT pressure > 8 psig and temperature < containment temp, cooling the PRT will only result in the PRT heating back up again.

- A. Correct:
- B. Incorrect: cannot be performed at power as the vent valve is inside containment and is inaccessible at power
 Plausible: venting to containment would accomplish the required action
- **C. Incorrect**: Lower Containment temp is 118 °F. Cooling the tank further would only delay the time when it would heat back up again and require further cooling. The PRT can be cooled by pressurizing the PRT with nitrogen but then spray flow must be initiated from the RMWST not the NCDT.

Plausible: Cooling will reduce pressure temporarily but will not allow the PRT to reheat to its normal limit of 114°F without getting a high-pressure condition (containment temp is 118°F). In addition, recirculating through the NCDT using the NCDT pumps cools the PRT and pressure would be reduced – temporarily.

D. Incorrect: Cannot cool the PRT through the sparger line Plausible: can cool the PRT by recircing through the RWST – must pressurize with N2 and recirculate RWST water through the spray and drain connections.

Ques_617.2.doc

Level: RO

KA: SYS 007 A2.02 (2.6/3.2)

Lesson Plan Objective: PS-NC Obj. 20

Source: BANK

Level of knowledge: memory

References: 1. OP-MC-PS-NC pages 41, 43

Bank Question: 891.2	Answer: A
----------------------	-----------

Unit 1 has experienced a rupture of the RN piping inside containment. Emergency procedures prescribe successful response mechanisms if containment water level remains between 3.5 and 10.5 feet.

Why is safe plant recovery not assured for a design basis large break LOCA when containment water level exceeds 10.5 feet?

- A. Operation of critical ECCS components needed for safe recovery is endangered by submersion.
- B. Operation of the NS pumps is endangered by excess debris fouling the containment suction strainers.
- C. Operation of the hydrogen purge system is compromised by loss of direct access to the containment atmosphere.
- D. Operation of the ND system is compromised by high suction pressure

Distracter Analysis:

- A. **Correct**: The containment flood plane reference is at 10.5 ft. Submersion beyond this level will expose unqualified components to a hostile environment that they are not qualified for.
- B. Incorrect: Submergence beyond the referenc flood plane will not cause excess debris nor will it transport debris to the suction strainers, which are at the very bottom of the containment sump. Debris is generated by impingement of high energy releases against containment SSCs the design basis will prevent excess debris if containment is maintained free of foreign material.
 Plausible: Clogged suction strainers could occur if submergence of components was a mechanism, which could lift debris. This is a reason to keep foreign material out of containment.
- C. Incorrect: The hydrogen purge system is far above the 10.5 ft flood plane and would not be compromised.
 Plausible: If the hydrogen purge system was submerged, it would fail to operate.
- D. Incorrect: 10.5 feet of water will not lift the ND suction relief, or if it did the relief returns to the PRT.
 Plausible: High containment level increases ND suction pressure.

Level: RO

KA: EPE W/E 15 G2.1.7 (3.7/4.4)

Lesson Plan Objective: EP-MC-EP-

1 Pt

FRZ Obj. 4

4

25

Source: BANK

Level of knowledge: Memory

References: 1. OP-MC-EP-FRZ page 47

Ques_891.2.doc

1 Pt Unit 1 is operating at 100% power. The battery charger 1EDGA for the 1A emergency diesel generator battery has failed and will not provide a DC output.

Which one of the following statements correctly describes the effect on the 1A emergency diesel generator?

- A. The 1A emergency diesel generator will start but not continue to run for its design basis committed time period without the battery charger in service.
- B. The 1A emergency diesel generator will not start without the battery charger in service.
- C. The 1A emergency diesel generator will start and run because the battery charger has a vital DC backup power supply, and will automatically supply the vital loads after starting.
- D. The 1A emergency diesel generator will start and run because all safety grade auxiliary loads are supplied from the 600VAC motor control center supplied from 1ELXA.

Distracter Analysis:

- A. Correct: The D/G will start because the D/G battery will supply all starting loads. However, without the charger, the battery will expire and power will be lost to the governor, voltage regulator and other vital DC loads.
- B. Incorrect: The D/G will start without the charger power will be supplied from the D/G battery.
 Plausible: if the candidate does not know that removing the inverter does not remove the battery from service. This would be true if the D/G control power breaker was opened.
- C. Incorrect: DG is inoperable without the battery charger. Plausible: Some batteries have this feature.
- Incorrect: DG is inoperable without the battery charger.
 Plausible: The battery will provide power to DG auxiliaries for some period of time some vital D/G auxiliaries are supplied from the 600 VAC control center.

Level: RO

KA: APE 058 AK1.01 (2.8/3.1*)

Lesson Plan Objective: OP-MC-DG-EPQ Objs. 3, 4, 5, 6, 7

Source: BANK/Modified

Ques_895.1.doc

Level of knowledge: comprehension

References: 1. OP-MC-DG-EPQ pages 15-19 & 25 odd pages only

Ques_895.1.doc

4

Ĵ

	Banl	k Question: 906.1 Answer: C			
1 Pt	A sta char the fo (amp	ation emergency battery is supplying DC bus loads without a ger online. If the load on the DC bus does not change, whic ollowing statements correctly describes a vital battery's discl os) as the battery is expended?	battery h one of harge rate		
	А.	The discharge rate will be fairly constant until the de- battery capacity (amp-hours) is exhausted and then v decrease.	sign will rapidly		
	В.	The discharge rate will decrease at a faster rate until design battery capacity is exhausted.	the		
	C.	The discharge rate will increase at a faster rate until t battery capacity is exhausted.	the design		
	D.	The discharge rate will initially decrease until approx 50% design capacity had been expended and then in until the battery has been exhausted.	imately crease		
	Distracter Analysis:				
	А.	Incorrect : The discharge rate increases. Plausible : This is a typical response for many design system the candidate does not recall that V= IxR.	stems - If		
	В.	Incorrect: The discharge rate increases. Plausible: If the candidate reverses the effect of decreases voltage on discharge rate.	sing		
	С. D.	Correct: Incorrect: The discharge rate increases. Plausible: If the candidate does not understand battery t	heory.		
	Leve	N: RO			
	KA: 8	SYS 063 A1.01 (2.5/3.3)			
	Less	on Plan Objective: EL-EPL SEQ 12/20			
	Source: Bank				
	Level of knowledge: memory				
	References: 1. OP-MC-EP-EPL pages 65-67				

____ ·

Ques_906.1.doc

Bank	Question: 911.2 Answer: B
The c basec °F. To both p	rew has verified natural circulation in ES-0.1 (<i>Reactor Trip Response</i>) I on decreasing core exit thermocouple readings and subcooling > 0 en minutes later, the operator notes that the thermocouple input to plasma displays is malfunctioning.
Which circula	n one of the following correctly describes a <u>valid</u> indication that natural ation is continuing?
А.	S/G saturation temperatures are decreasing and REACTOR VESSEL UR LEVEL indication is greater than 100 %.
B.	S/G pressures are decreasing and T _{cold} is at S/G saturation temperature.
C.	S/G pressures are decreasing and <i>REACTOR VESSEL D/P</i> indication is greater than 100%.
D.	S/G pressures are decreasing and Thot is at S/G saturation temperature.
Distra	acter Analysis:
А.	Incorrect : There is no indication of coupling between primary and secondary. Plausible : These are important indications during natural circulation.

- Β. Correct:
- Incorrect: dp range is unavailable during natural circulation. C. Plausible: S/G pressure decreases during natural circulation and RVLIS is one of the other plasma display indications.

Incorrect: dp range is unavailable during natural circulation. D. Plausible: S/G pressure will remain close to saturation for Tcold during natural circulation and RVLIS is one of the other plasma display indications.

Level: RO

KA: 0017 A3.01 (3.6*/3.8*)

Lesson Plan Objective: EP-E0 Obj. 6

Source: BANK

Level of knowledge: Memory

References:

1 Pt

1. OP-MC-EP-E0 pages 117, 123 2. ES-0.1 page 15 3. ES-0.1 Enclosure 2 page 31

2

~

Ques_911.2.doc

1 Pt Unit 2 was operating at 100% when a complete loss of offsite power (LOOP) occurred. All systems were operable and in a normal alignment.

Which one of the following containment ventilation systems will have all operating fans/air handling units stopped after 5 minutes without any offsite power?

- A. VU ventilation units
- B. Pressurizer booster fans
- C. Pipe tunnel booster fans
- D. Steam generator booster fans

Distracter Analysis:

- A. Incorrect: VU AHUs and return air fans will start on a LOOP/blackout – they have an emergency power supply.
 Plausible: They will not start in a safety injection signal
- B. Incorrect: Pressurizer booster fans will start on a LOOP from the B/O sequencer they have an emergency power supply.
 Plausible: If the candidate confuses the emergency power supply for the pressurizer booster fans with the steam generator booster fans
- C. Incorrect: Pipe tunnel booster fans will start on a LOOP from the B/O sequencer they have an emergency power supply. Plausible: They will not start in a safety injection signal
- D. Correct: Steam generator booster fans do not restart on a LOOP -B/O signal – they do not have an emergency power supply

Level: RO

KA: SYS 022 K2.01 (3.0*/3.1)

Lesson Plan Objective: CNT-VUL LPRO 5

Source: Bank

Level of Knowledge: memory

References: 1. OP-MC-CNT-VUL pages 35, 39

	Ban	k Question: 963.1 Answer: D				
1 Pt	Unit Give	2 was at 75% R.T.P. when a loss of condenser vacuum occurred. In the following conditions:				
	 F T C N 	 Rods are in automatic The steam dump select switch is selected to 'Tave' mode Condenser vacuum is slowly decreasing No component or instrument failures occurred No operator action taken 				
	Whic contr	ch one of the following sequences best describes the actuation of the rol rods to this event?				
	А.	Control rods move in due to decreased condenser back pressure				
	В.	Control rods move out due to decreased condenser back pressure				
	C.	Control rods move in due to increased condenser back pressure				
	D.	Control rods move out due to increased condenser back pressure				
	Distı A.	racter Analysis: Incorrect: Plausible:				
	В.	Incorrect: - Plausible:				
	С.	Incorrect: Plausible: -				
	D.	Correct				
		Level: RO				
		KA: APE 000051 AA1.04 (2.5*/2.5*)				
		Lesson Plan Objective: OP-MC-STM-IDE Obj. 9				
		Source: Bank				
		Level of Knowledge: Comprehension				
		References: 1.OP-MC-STM-IDE pages 17-33 (odd only)				

Bank	Question:	975.1
------	-----------	-------

,

ē

- 1 Pt Unit 1 is responding to a LOCA from a trip at full power. Given the following events and conditions:
 - A safety injection occurred at 0200.
 - FWST level reaches 33 in. at 0246.
 - S/I, Sequencers, and Containment Spray have been reset for both trains.
 - The 1B NS pump has been successfully swapped to the containment sump.
 - 1NS-18A (A NS Pump Suct From Cont Sump) will not open.

Which one of the following is the reason 1NS-18A will not open?

- A. 1NS-43A (A ND to NS Containment Outside Isol) is CLOSED
- B. "NS SYS CPCS TRAIN A INHIBIT" light LIT
- C. 1NI-185A (RB Sump to Train A ND & NS) is CLOSED
- D. 1NS-43A (A ND to NS Containment Outside Isol) is OPEN

Distracter Analysis:

- A. Incorrect:.
- B. Incorrect
- Plausible:
- C. Correct:. Plausible:.
- D. incorrect: Plausible:

Level: RO

Source: BANK

KA: SYS 026 K4.07(3.8*/4.1*)

Lesson Plan Objective: OP-MC-ECC-NI Obj. 8 ,

Source: BANK

Level of knowledge: comprehension

References: 1. OP-MC-ECC-NS page 17

Ques_975.1.doc

2. EP/1A/5000/ES-1.3 page 8 3. OP-MC-ECC-NI page 21

Ques_975.1.doc

۲

5

Bank Question: 976.1	Answer: B
----------------------	-----------

1 Pt Unit 2 is in an outage. All the fuel is in the spent fuel pool. A fuel shuffle is in progress in the spent fuel pool. During the shuffle a fuel assembly is accidentally damaged and 2EMF-42 (Fuel Building Ventilation Radiation Monitor) goes into Trip 2.

Which one of the following describes the effect on spent fuel pool ventilation system as a result of 2EMF-42 in Trip 2?

- A. The VF supply and exhaust fans trip and the filter is placed in the FILTRATION MODE.
- B. No effect on VF system alignment.
- C. The VF system is automatically placed in BYPASS MODE and the discharge dampers open and supply dampers close
- D. The VF system is automatically placed in the FUEL HANDLING MODE OF OPERATION and the supply fans trip.

Distracter Analysis: When fuel handling is in progress the VF system is placed in Filter Mode as a result no system changes will occur.

- A. Incorrect:.
 - Plausible:.
- B. Correct:
- C. Incorrect: Plausible:
- D. Incorrect:
- Plausible:

Level: RO

KA: SYS 072 A3.01 (2.9*/3.1)

Lesson Plan Objective: OP-MC-FH-VF Obj 8 & 9

Source: BANK

Level of knowledge: Comprehension

References: 1. OP-MC-FH-VF page 17

	Bank Question: 977.1 Answer: C					
1 Pt	Unit 1 is at 100% power when indications are received of a "1B' Reactor Coolant Pump seal malfunction. AP/1/A/5500/08 (<i>Malfunction of NC Pump</i>) is implemented.					
	Which one of the following conditions describes a number two seal failure?					
	A. #1 Seal Leak off flow – GOING DOWN NC Pump number 2 Seal Standpipe low level alarm – LIT NCDT input – STABLE, OR GOING DOWN					
	B. #1 Seal Leak off flow – GOING UP NC Pump number 2 Seal Standpipe high level alarm – LIT NCDT input – STABLE, OR GOING DOWN					
	C. # 1 Seal Leak off flow – GOING DOWN NC Pump number 2 Seal Standpipe high level alarm – LIT NCDT input – GOING UP					
	D. #1 Seal Leak off flow – GOING UP NC Pump number 2 Seal Standpipe low level alarm – LIT NCDT input – GOING UP					
	Distracter Analysis:					
	A. Incorrect: Plausible: #1 Seal L/O WILL go down B. Incorrect:					
	 Plausible: High Standpipe level alarm WILL lite. C. Correct: D. Incorrect: Plausible: NCDT input WILL go up 					
	Level: RO					
	KA: SYS 003 A3.03 (3.2/3.1)					
	Lesson Plan Objective: OP-MC-PS-NCP, Obj. 12					
	Source: Bank					
	Level of knowledge: Comprehension					

, , ,

_

2

References:

ŝ

;

1. OP-MC-PS-NCP pages 25-29 2. AP/1/A/5500/08 Malfunction of NC Pump

Ques_977.1.doc

	Ban	nk Question: 984.1 Answer: A		
1 Pt	Which one of the following pre-planned activities that has been evaluated and approved in advance by Operations can take place during shift turnover?			
	А.	Dilution to ECB		
	В.	ZPPT		
	C.	Drain to Mid-Loop		
	D.	Reactor Startup		
	Dist	tracter Analysis:	944 2 2 7 = 4 3 6 7 4 2 2	
	А. В.	Correct: Incorrect: Should not be scheduled during turnove Plausible:	er	
	C.	Incorrect:Should not be scheduled during turnove	r	
	D.	Plausible Incorrect: Should not be scheduled during turnove Plausible:.	er	
	Leve	el: RO		
	KA:	G2.1.3 (3.0/3.4)		
	Less	son Plan Objective:		
	Sour	rce: Bank		
	Leve	el of knowledge: memory		
	Refe 1. Ol	erences: MP 2-2 page 31		

1 Pt. Unit 1 is responding to a small break LOCA inside and outside containment. Given the following events and conditions:

- FWST Level indicates 340 inches
- Containment pressure indicates 1.5 psig
- Containment Sump Level indicates 1.05 ft
- 1EMF-41 (AUX BLDG VENTILATION) is in Trip 2 alarm
- Aux Building area radiation monitors are in alarm
- 1EMF-51A and B (CONTAINMENT TRN A & B) indicates 25 R/Hr
- Hydrogen Analyzer indicates 0.7% in containment
- NLO's report significant leakage at the seals of the "1A" ND pump

Which one of the following actions reduces excessive levels of radiation and guard against personnel exposure?

- A. Monitor 1EMF-41 (AUX BLDG VENTILATION)
- B. Dispatch NLO to energize Hydrogen Recombiners
- C. Secure VA (Aux. Bldg. Ventilation System) to limit airborne contamination.
- D. Identify and isolate the break

Distracter Analysis: The initial conditions provide a LOCA into containment and a leakage path outside of containment. The question is which of the problems take priority? The purpose is not to memorize procedure steps but to answer this from a broader perspective.

- A. Incorrect: Monitoring of rad levels does not minimize exposure. Plausible: If the candidate thinks that the abnormal radiation level requires priority action.
- B. Incorrect: Energizing the Hydrogen Recombiners does not limit rad exposure in the Aux. Bldg.
 Plausible: Small Hydrogen Concentration inside containment exists).
- C. Incorrect: This is needed to limit personnel exposure..
- Plausible: If the candidate thinks there is an airborne problem.D. Correct;

Level: RO

KA: G3.10 (2.9/3.3)

Lesson Plan Objective: EP-E1 OBJ 3

Ques_1012.1.doc

Source: BANK

.

· ____ 4 -Ξ.

Level of knowledge: comprehension

References:

1. OP-MC-EP-E1 page 231, 233, 235 2. EP/1/A/5000/ECA-1.2

Ques_1012.1.doc

		Bank Question: 1022	Answer: D		
1 Pt.	Unit 1 is in mode 5 with the operators preparing for a plant startup by drawing a bubble in the pressurizer.				
	Given t	he following conditions:			
	1) 2) 3) 4)	LTOPs is in service Pressurizer pressure is 325 psig Pressurizer level is 25% T _{ave} = 175 °F			
	lf press inputs f	sure increases to 400 psig, which one of for a PORV to actuate in LTOP mode?	of the following describes the correct		
	А.	'D' loop Hot leg WR temperature < 3 loop >380 psig will actuate PORV N	320 degrees and WR pressure 'D' IC-34A		
	В.	'C' loop Cold Leg temperature < 32 loop > 380 psig will actuate PORV N	0 degrees and NR pressure 'A' NC-32B		
	C.	'C' loop Cold Leg temperature < 320 loop > 380 psig will actuate PORV N	0 degrees and WR pressure 'A' NC-32B		
	D.	'D' loop Hot Leg WR temperature < loop > 380 psig will actuate PORV N	320 degrees and NR pressure 'D' NC-34A		
MISCINFO:		RO			
SOURCE:		NEW			
Level of Know	vledge:	Memory			
Author: CWS		;			
REFERENCES	S:	OP-MC-PS-NC pages 45 & 49			
LESSON:	OP-MC	C-PS-NC			
OBJECTIVE:	OP-MC	C-PS-NC Obj. 21			
K/A: APE 00)8 AA20	06 (3.3/3.6)			

_

1 Pt. Initial Conditions:

2

- Unit 1 is at 100% power
- "A" train essential components are in service

OAC alarms indicate an increase in reactor coolant pump motor winding temperatures.

Which of the following describes the reason for the increase in temperatures?

- A. 1RN-40A (Train A to Non Essential Hdr Isol) has closed
- B. 1KC-338B (NCP Supply)has closed
- C. 1RN-43A (Train 1B to Non Ess Hdr Isol) has closed
- D. 1KC-228B (RB HDR supply) has closed

Distracter Analysis:

- A. Correct
- B. KC system has no effect on motor stator temperatures
- C. Closure of this valve will have no effect on stator temperatures
- D. KC system has no effect on motor stator temperatures

Level: RO

KA: APE 015 AA2.01 (3.0/3.5)

Lesson Plan Objective: OP-MC-PS-NCP Obj 7 OPO-MC-PSS-RN Obj 10

Source: New

Author: CWS

Level of knowledge: memory

References: 1. OP-MC-PS-NCP page 5, 13 & 17 2. OP-MC-PSS-RN page 31 & 75

Ques_1023.doc

Date: 3/06/2003

Ĵ

Ques_1023.doc

Dalik Question, 1024 Answer, O	Bank	Question:	1024	Answer: C	•
--------------------------------	------	-----------	------	-----------	---

1 Pt.	Unit 2 was operating at 100% power with the Pressurizer Pressure Control
	Switch in the '1-2' position and NC pressure in the normal operating band.
	Given the following plant conditions and events:

• NC pressure increases

2

- PORVs 1NC 32B and NC 36B open at 2335 psig
- Pressure modulates between 2315 psig and 2335 psig.

Which one of the following instrument failures would cause this plant response and what is the correct operator action perAP/11 (*Pressurizer Pressure Anomalies*)?

^	DZD pressure shapped I fails high	
А.	PZR pressure channel I fails high	
	Immediately swap controlling channels	

- B. PZR pressure channel II fails low Place Pressurizer Pressure Master in Manual
- C. PZR pressure channel I fails low Place Pressurizer Pressure Master in Manual
- D. PZR pressure channel II fails high Immediately swap controlling channels.

Distracter Analysis:

- A. Incorrect: channel I failing high causes pressure to decrease Plausible: -
- **B. Incorrect answer** If a channel II fails low you immediately swap controlling channels.
- C. Correct:
- D. Incorrect: -Plausible: -

Level: RO Only

KA: APE 027 AK3.03 (3.7/4.1)

Lesson Plan Objective: PS-IPE Obj. 12

Source: NEW

Author: CWS

Level of knowledge: comprehension

References: 1. OP-MC-PS-IPE page 35

Ques_1024.doc

.

5

. •

	Bank	Question: 1025	Answer: B			
1 Pt.	Unit 1 is operating at 100% power when a small break LOCA occurs.					
	Given the following					
	a) b) c) d) e) f) g)	Reactor Trip and Safety Injection Actuated E-0 (<i>Reactor Trip or Safety Injection</i>) completed Crew has exited E-0 to E-1 (<i>Loss of Reactor or Secondary Coolant</i>) Both trains of ECCS equipment are functioning normally Subcooling is 0 degrees Pressurizer level is 2% Containment pressure is 2.5 psig				
	Which one of the following should be the status of the reactor coolant pumps?					
	А.	The reactor coolant pumps forced cooling through the	should still be running to provide core.			
	В.	The reactor coolant pumps excessive depletion of the	should be stopped to prevent NC system water inventory.			
	C.	The reactor coolant pumps pressurizer in order to term	should still be running to refill the ninate Safety Injection flow.			
	D.	The reactor coolant pumps pump damage due to loss o	should be stopped to prevent of pump support systems.			
	Distracter Analysis:					
	А.	Incorrect – NCP should be	stopped on loss of subcooling			
	в.	Correct.				
	C.	incorrect				
	D. conta	port systems on 2.5 # in				
		Level: RO				
		KA: APE 009 EK3.13 (3.4/3.7	7)			
		Lesson Plan Objective: OP-N	MC-EP-ECA-0 Obj. 4			
		Source: New				

Ques_1025.doc

÷

.

Level of knowledge: Comprehensive

Author: CWS

~

Ê

References: 1. OP-MC-EP-E1 page 53

Ques_1025.doc

\$

1 Pt. Unit 2 is operating at 100% power when the following occurs:

- Loss of offsite power
- Neither Diesel Generator starts
- ECA-0.0 (Loss of All AC Power) is in effect
- Standby Makeup pump for unit 2 tagged for maintenance
- Reactor Coolant Pump seal injection valves have been closed

Twenty minutes later power is restored to Unit 2 ETA from Unit 1, and the crew enters ECA-0.1 (*Loss of All AC Power Recovery Without S/I Required*).

Which of the following best describes the proper method for restoring NCP seal flows in ECA-0.1?

- A. Slowly restore seal injection cooling limiting the cooldown rate to 1 degree per minute
- B Do not restore seal injection cooling due to potential damage to the KC thermal barrier heat exchanger.
- C Restore seal injection cooling as rapidly as possible to minimize the potential for seal degradation.
- D. Do not restore seal injection cooling due to potential damage of thermal shock to the reactor coolant pump seals.

Distracter Analysis:

A. Incorrect – old procedure guidance

B. Incorrect do not restore seal cooling after needle valves closed.

C. Incorrect do not restore seal cooling after need le vavles closed

D. Correct

Level: RO

KA: APE 022 AK1.01 (2.8/3.2)

Lesson Plan Objective: OP-MC-EP-ECA-0 Obj. 3

Ques_1026.doc

Source: New

...

Level of knowledge: Comprehension

Author: CWS

References: 1. OP-MC-EP-ECA-0 page 79

Ques_1026.doc

	Banl	c Question:	1027	Answer: C		
1 Pt.	Unit	1 has experi	enced a la	arge break LOCA.		
	Given the following conditions:					
	 E-0 (<i>Reactor Trip or Safety Injection</i>) is complete ES 1.3 (<i>Transfer to Cold Leg Recirc</i>) is complete Six hours have elapsed since the LOCA and ES 1.4 (<i>Hot Leg Recirc</i>) is being implemented. 1NI-121A (Train 'A' NI to B & C Hot Leg) will not open due to mechanical binding. ND Train 'A' has been aligned for Hot Leg Recirc. ND Train 'B' is aligned for Auxiliary Containment Spray. 					
	Whic 'A' N	h of the follo D pump trips	wing best	describes the effects on the ND system if the		
	A. F	low is lost t	to the 'A'	and 'B' hot legs		
	B. Flow is lost to the 'A', 'B', 'C' and 'D' hot legs					
	C. F	C. Flow is lost to the 'B' and 'C' hot legs				
	D. Flow is lost to 'A' and 'D' hot Legs Distracter Analysis:					
	В.	Incorrect	t all legs a	are not aligned for hot leg recirc		
	C.	Correct				
	D.	Incorrect	t flow is n	ot go aligned to "A" and "D" hot legs		
		Level: R	0			
		KA: APE	025 AK2.	02 (3.2*/3.2)		
		Lesson P	'lan Objec	tive: OP-MC-PS-ND Obj. 8		
		Source: N	New			
		Level of k	knowledge	e: memory		

~ ~

... ¥ Author: CWS

÷

References: 1. OP-MC-PS-ND pages 51 & 73

Ques_1027.doc
	Bank	Question: 1028	Answer: D		
1 Pt.	Unit 1 is operating at 100% power when the 'A' Main steam line ruptures outside containment and depressurizes the 'A' S/G.				
	Which of the following describes the logic and coincidence needed to actuate a Main Steam Isolation signal?				
	A. 1/4 on 1/4 steamlines				
	B. 2/	3 on 2/4 steamlines			
	C. 1/	4 on 2/4 steamlines			
	D. 2/	3 on 1/4 steamlines			
	Distra	acter Analysis:			
	А.	Incorrect –			
	В.	Incorrect			
	C.	Incorrect			
	D.	Correct			
		Level: RO			
		KA: APE 040 AK3.01 (4.2/4.5	5)		
		Lesson Plan Objective: OP-I	MC-ECC-ISE Obj. 13		
		Source: New			
		Level of knowledge: memory			
		Author: CWS			
		References: 1. OP-MC-ECC-ISE page 65	;		

_

	Bank Question: 1029 Answer: D			
1 Pt.	Given the following Unit 1 initial conditions			
	 100% power with Tave = Tref 			
	NC System Boron Concentration 953 ppm			
	Control Bank 'D' rods are at 217 steps			
	 Control Bank 'D' Rod H-8 drops fully into the core 			
	 AP/1A/5500/14 Rod Control Malfunction is entered and immediate actions are completed 			
	Thirty minutes after the rod drops			
	 Load has been reduced to 95% power with Tave = Tref 			
	NC System Boron Concentration 953 ppm			
	 Control Bank 'D' rods are at 217 steps 			
	Rod H-8 has not been retrieved			
	Which one of the following describes the effect of the event on Rod Insertion Limits and Shutdown Margin?			
	A. Rod insertion limit is unchanged and shutdown margin is increased.			
	B. Rod insertion limit is decreased and shutdown margin is unchanged.			
	C. Rod insertion limit is unchanged and shutdown margin is decreased.			
	D. Rod insertion limit is decreased and shutdown margin is decreased.			
	Analysis: A. Incorrect: Plausible:			
	B. Incorrect:			
	Plausible:			
	D. Correct:			
	Plausible: .			
	Level: RO			
	KA: 000003.AK1.07 (3.1/3.9)			

Ques_1029.doc

2 horas T

Lesson Plan Objective:

Source: New

_

فيرتبي . ا

Author: CWS

Level of knowledge: comprehensive

References:

- McGuire 1 Cycle 16 COLR pages 9,11 & 12
 REACT (Reactor Engineering Analysis & Computer Tools) Shutdown Margin-Unit at Power, Modes 1 & 2 Calculations

	Ban	k Question: 1030	Answer:	<u>с</u>			
1 Pt.	Unit perf Cor	Unit 1 is in Mode 3 at normal operating temperature and pressure. While performing trouble shooting activities 1NV-94AC (NC Pump Seal Return Containment Isolation Valve) closes.					
	Whic Pum	Which of the following best describes the effect on the Reactor Coolant Pumps seal return flow?					
	A. S	A. Seal return flow continues and is routed to the NCDT.					
	B. S	B. Seal return flow continues through 1NV-95B to VCT.					
	C. S	Seal return flow continues	s and is routed	to the PRT.			
	D, S ar	Seal return flow continues Yound 1NV-94AC.	s to the VCT thi	ough a bypass line			
	Dist	racter Analysis:					
	Α.	Incorrect – seal return	flow goes to P	RT			
	₿.	Incorrect 1NV-94 and 1 the valves are in para	INV-95 are in s Ilel.	eries Student may think			
	C.	Correct					
	D.	incorrect – check valve	e prevents this	flow path			
		Level: RO					
		KA: SYS 003 K6.04 (2.8	3/3.1)				
		Lesson Plan Objective:	OP-MC-PS-NV	Obj. 5			
		Source: New					
		Level of knowledge: Me	mory				
		Author: CWS					
		References: 1. OP-MC-PS-NV page	s 39, 41 & 115				

	Bank	Question: 1031 Answer: B				
1 Pt.	Unit 2 obse	2 was operating at 49% power when the following indications were erved:				
	•	 Steam Generator level in the 2A S/G is 84% on 2/3 level indications Feedwater flows decreasing Feedwater Isolation Signal actuated 				
	Whic	h of the following describes the plant response to the above condition?				
	A. F	eedwater pump 'A' only has tripped.				
	B. B tr	oth feedwater pumps have tripped, the turbine and reactor have ipped.				
	C. F	eedwater pump 'A' and the turbine only have tripped.				
	D. B tri	oth feedwater pumps and turbine have tripped, the reactor did not p.				
	Distr	Distracter Analysis:				
	Α.	Incorrect: – both FWPTs trip, turbine and reactor trips because above P-8 – 48%				
	В.	Correct				
	C.	Incorrect: - see A above				
	D.	Incorrect: reactor trips above P-8 48%				
		Level: RO				
		KA: SYS 059 K4.01 (3.3/3/5)				
		Lesson Plan Objective: OP-MC-CF-CF Obj. 14 OP-MC-IC-IPE Obj. 10 & 11				
		Source: New				
		Level of knowledge: Comprehensive				
		Author: CWS				

Ques_1031.doc

1. OP-MC-CF-CF page 35 2. OP-MC-IC-IPE pages 79, 81 & 83

Ques_1031.doc

	Dd///		
Pt.	Giver	n the following conditions:	
	• • •	Unit 1 is at 100% No annunciators are in ala TD CA pump is being start change) RO places the #1 TD CA F The TD CA pump starts bu	rm ed for post maintenance testing (oil Pump to 'START' ut does not achieve rated speed.
	Which of the following describes the potential reason the TD CA pump failed to reach rated speed? A. The TD CA pump stop valve is not fully open.		
	B 1SA-48ABC (1C S/G SM Supply to unit 1 TD CA Pump Turb Isol) failed to OPEN.		
	C TI	he Control Room/Local swi	itch at local panel is in Local control.
	D. Ti las	he Woodward Governor sp st PT.	eed setting was not cycled after the
	Distracter Analysis:		
	Distr	acter Analysis:	
	Distr A.	acter Analysis: Incorrect – would have a open.	n annunciator if the valve is not fully
	Distr A. B.	acter Analysis: Incorrect – would have a open. Incorrect SA 48 and SA 4	n annunciator if the valve is not fully 49 are in parallel no effect.
	Distr A. B. C. statu	acter Analysis: Incorrect – would have a open. Incorrect SA 48 and SA Incorrect TD CA pump w Is light that would be lit if th	n annunciator if the valve is not fully 49 are in parallel no effect. vould not start if in local. There is a nis switch were in local.
	Distr A. B. C. statu D.	racter Analysis: Incorrect – would have a open. Incorrect SA 48 and SA Incorrect TD CA pump w Is light that would be lit if th Correct	n annunciator if the valve is not fully 49 are in parallel no effect. vould not start if in local. There is a his switch were in local.
	Distr A. B. C. statu D. Level	acter Analysis: Incorrect – would have a open. Incorrect SA 48 and SA Incorrect TD CA pump w Is light that would be lit if th Correct	n annunciator if the valve is not fully 49 are in parallel no effect. vould not start if in local. There is a his switch were in local.
	Distr A. B. C. statu D. Level Sourc	acter Analysis: Incorrect – would have a open. Incorrect SA 48 and SA Incorrect TD CA pump w Is light that would be lit if th Correct I: RO	n annunciator if the valve is not fully 49 are in parallel no effect. vould not start if in local. There is a his switch were in local.
	Distr A. B. C. statu D. Level Sourc KA: S	acter Analysis: Incorrect – would have a open. Incorrect SA 48 and SA 4 Incorrect TD CA pump w Is light that would be lit if th Correct I: RO ce: NEW SYS 039 A4.04 (3.8/3.9)	n annunciator if the valve is not fully 49 are in parallel no effect. vould not start if in local. There is a his switch were in local.
	Distr A. B. C. statu D. Level Sourc KA: S Lesso	acter Analysis: Incorrect – would have a open. Incorrect SA 48 and SA 4 Incorrect TD CA pump w Ight that would be lit if th Correct I: RO ce: NEW SYS 039 A4.04 (3.8/3.9) on Plan: OP-MC-CF-CA	n annunciator if the valve is not fully 49 are in parallel no effect. vould not start if in local. There is a his switch were in local.
	Distr A. B. C. statu D. Level Sourc KA: S Lesso	acter Analysis: Incorrect – would have a open. Incorrect SA 48 and SA 4 Incorrect TD CA pump w Is light that would be lit if th Correct RO ce: NEW SYS 039 A4.04 (3.8/3.9) on Plan: OP-MC-CF-CA on Plan Objective: OP-MC-C	n annunciator if the valve is not fully 49 are in parallel no effect. vould not start if in local. There is a his switch were in local.

.

ç Ç

•

Author: CWS

v

References: OP-MC-CF-CA pages 15, 23, 25 & 27

Ques_1032.doc

	Ban	k Question: 1034	Answer: A			
1 Pt.	Durin truck OTS INTA close AP/1 Units	During the delivery of chlorine gas cylinders on site, a cylinder fell from the truck and ruptured. All control room VC intakes closed except 1VC-9A (VC OTSD AIR INTAKE ISOL FROM UNIT 2) and 1VC-11B (VC OTSD AIR INTAKE ISOL FROM UNIT 2) which were mechanically bound and failed to close completely. Chlorine gas has entered the control room. AP/1/A/5500/17 (<i>Loss of Control Room</i>) has been implemented on both Units.				
	Whic desc	Which one of the following describes S/G pressure control for the condition described above?				
	А.	All S/G PORV's are co psig.	ntrolling between 1092 psig and 1125			
	В.	'A' and 'B' S/G PORV' less than 1170 psig.	s are controlled manually to maintain			
	C.	'C' and 'D' S/G PORV' less than 1170 psig	s are controlled manually to maintain			
	D.	Only 'A' and 'D S/G Pe and 1125 psig.	ORV's are controlling between 1092 psig			
	Dist	racter Analysis: Manual S/G pressure is greate lifting. Only the 'A' ar available.	control of S/G pressure if only taken if er than 1170 psig and the S/G safeties are d 'D' S/G have local manual control			
	Α.	Correct:. Plausible:				
	В.	Incorrect: Can not con Plausible:	trol 'B' S/G manually			
	С. D.	Incorrect: Can not con Incorrect: All S/G's w	irol 'C' S/G manually. ould be functioning normally			
	Leve	Level: RO				
	KA: /	KA: APE 000068 (3.7/4.0)				
	Less	Lesson Plan Objective: OP-MC-AP-17 Obj. 2				
	Sour	Source: New				
	Leve	l of Knowledge: Compreh	ension			
	Refe 1. (2. /	References: 1. OP-MC-AP-17 Obj. 2 2. AP/1/A/5500/17 page 10 and Enclosure 7				

Ques_1034.doc

3. AP/1/A/5500/17 Background document page 14

Ques_1034.doc

- · ·

÷

· ____

÷

		Answer: A		
Pt.	Given the following conditions on Unit 1:			
	 Blackout on ETB The 1B D/G started in a An Operator has been of Pushbutton". 	utomatic mode and tripped due to overspeed dispatched to depress "Emergency Stop Reset		
	Which one (1) of the following describes why the diesel generator restarted once the Emergency Stop Reset Pushbutton was depressed?			
	A. The engine oversp condition was still	eed trip resets, and the undervoltage present.		
	B. The sequencer was reset to its ground state and the accelerated sequence relay timed out.			
	C. The sequencer was reset and placed it in priority mode and the undervoltage condition was still present.			
	D. The engine oversp sequence relay tin	eed trip resets, and the accelerated ned out.		
	automatia start an			
	automatic start and	e listed in 'A' above.		
	A. Correct:	e listed in 'A' above.		
	A. Correct: Plausible: B. Incorrect: Plausible:	e listed in 'A' above.		
	A. Correct: Plausible: B. Incorrect: Plausible: C. Incorrect: Plausible:	e listed in 'A' above.		
	 A. Correct: Plausible: B. Incorrect: Plausible: C. Incorrect: Plausible: D. Incorrect Plausible: 	e listed in 'A' above.		
	A. Correct: Plausible: B. Incorrect: Plausible: C. Incorrect: Plausible: D. Incorrect Plausible: LEVEL: RO	e listed in 'A' above.		
	A. Correct: Plausible: B. Incorrect: Plausible: C. Incorrect: Plausible: D. Incorrect Plausible: LEVEL: RO KA: 00051 EA1.02 (4.3/4.4)		
	A. Correct: Plausible: B. Incorrect: Plausible: C. Incorrect: Plausible: D. Incorrect Plausible: LEVEL: RO KA: 00051 EA1.02 (4.3/4.4 SOURCE: NEW	a listed in 'A′ above. ⊧)		
	A. Correct: Plausible: B. Incorrect: Plausible: C. Incorrect: Plausible: D. Incorrect Plausible: LEVEL: RO KA: 00051 EA1.02 (4.3/4.4 SOURCE: NEW LEVEL OF KNOWLEDGE:	listed in 'A' above. !)		
	A. Correct: Plausible: B. Incorrect: Plausible: C. Incorrect: Plausible: D. Incorrect Plausible: LEVEL: RO KA: 00051 EA1.02 (4.3/4.4 SOURCE: NEW LEVEL OF KNOWLEDGE: AUTHOR: CWS	e listed in 'A' above. !)		

:

LESSON: OP-MC-DG-DG OBJECTIVES: OP-MC-DG-DG Obj 10 REFERENCES: OP-MC-DG-DG pages 23

Ques_1036.doc

ي مىر

	Bank Question: 1038 Answer: C				
1 Pt	Given the following conditions:				
	 Unit 1 is operating at 25% power All electrical systems are in normal alignment The normal incoming breaker to 1EMXA trips because of a therm overload. 				
	Which one of the following describes the effect on 125 VDC Distribution Center EVDA?				
	A. No effect; alternate power to Charger Connection box ECB-1 will swap within 8 cycles and maintain power to EVDA.				
	B. No effect; battery EVCC will continue to power EVDA.				
	C. No effect; battery EVCA will continue to power EVDA.				
	D. EVDA will be de-energized until cross tied with EVDD.				
	Distracter Analysis:.				
	A. Incorrect: Charger connection box is Kirk-keyed				
	B. Incorrect: No automatic function for EVCC to power EVCA				
	C. Correct:				
	D. Incorrect Can't crosstie EVDA and EVDD Plausible:				
	LEVEL: RO				
	KA : 00062 K1.03 (3.5/4.0)				
	SOURCE: NEW				
	LEVEL OF KNOWLEDGE: Memory				
	AUTHOR: CWS				
	LESSON: OP-MC-EP-EPL				
	OBJECTIVES: OP-MC-EP-EPL Obj 9				

Ques_1038.doc

..

.4

REFERENCES: OP-MC-EP-EPL pages 21 & 69

Ques_1038.doc

÷

-

\$45	Bank	Question: 1039	Answer: B		
1 Pt	Unit 2 was operating at 100% when a Floor Cooling Glycol High Temperature annunciator is received. A review of the RTD panel reveals that several ice condenser floor slabs have high temperature indications. An operator determines that 2NF-848 (<i>NF Floor Cooling Slab Temp Control</i>) has failed closed. An inspection of the lower ice condenser reveals that eight (8) ice condenser bays have experienced buckling.				
	Whic conta	Which one of the following statements describes the effect on peak containment pressure and time to reach peak containment pressure?			
	А.	Design containment pro The time to reach peak	essure of 15 psig will not be exceeded. containment pressure is 50 minutes.		
	В.	Design containment pro The time to reach peak	essure of 15 psig could be exceeded. containment pressure is 1.75 hours.		
	C.	Design containment pro The time to reach peak	essure of 60 psig will not be exceeded. containment pressure is 50 minutes.		
	D.	Design containment pro The time to reach peak	essure of 60 psig could be exceeded. containment pressure is 1.75 hours.		
	Distr	acter Analysis: There are With 8 bays having exp incapable of opening 1/ condenser is now bloc	24 ice condenser bays in containment. erienced buckling and the doors 3 of the total flowpath into the ice ked.		
	Α.	Incorrect: peak contain Plausible: peak contain	ment pressure is reached in 1.75 hours ment pressure is correct.		
	В.	Correct.			
	C.	Incorrect Answer: peak short	pressure to high, time to reach is too		
	D.	Incorrect: peak pressure Plausible: 20 psig is app plants	e to high. ropriate for some non-ice condenser		
		Level: RO			
		KA: SYS 025K3.01(3.8*/	3.8*)		
		Lesson Plan Objective: C	P-MC-CNT-NF Obj. 20		
		Source: NEW			
		Level of knowledge: Com	iprehension		

Ques_1039.doc

<u>.</u>

References: 1. OP-MC-CNT-NF pages 69 & 17 2. OP-MC-CNT-CNT pages 17 & 21

Ques_1039.doc

-***** * *

	Bank Question: 1040	Answer: B		
1 Pt	Which one of the following are the power supplies for the Unit 1 MG sets?			
	A. 1LXE and 1LXF			
	B. 1LXF and 1LXG			
	C. 1SLXF and 1SLXG			
	D. 1SLXG and 1SLXH			
	Distracter Analysis:.			
	A. Incorrect: 1LXE is not co	prrect		
	B. Correct:			
	C. Incorrect: Power does n	ot come from shared load centers		
	Plausible: D. Incorrect Power does not Plausible:	come from shared load centers		
	LEVEL: RO			
	KA : 00001 K2.05 (3.1*/3.5)			
	SOURCE: NEW			
	LEVEL OF KNOWLEDGE: Memory			
	AUTHOR: CWS			
	LESSON: OP-MC-IC-RTB			
	OBJECTIVES: OP-MC-IC-RTB Obj 11			
	REFERENCES: OP-MC-IC-RTE	page 19		

	Bank Question: 1041	Answer: D			
1 Pt	Which one of the following is the power supply for the 2B Hydrogen Recombiner?				
	A. 2TA				
	B. 2ETA				
	C. 2EMXC				
	D. 2EMXD				
	Distracter Analysis:.	** <i>***********************************</i>			
	A. Incorrect:				
	B. Incorrect:				
	C, Incorrect:				
	Plausible: D Correct				
;	Plausible:				
	LEVEL: RO				
	KA: 0028 K2.01 (2.5*/2.8*)				
	SOURCE: NEW				
	LEVEL OF KNOWLEDGE: Memory				
	AUTHOR: CWS				
	LESSON: OP-MC-CNT-VX				
	OBJECTIVES:				
	REFERENCES: OP-MC-CNT-VX page	49			

	Bank	Question: 1043	Answer B:	
1 Pt	Given the following conditions on Unit 2:			
	•	75% power Annunciator "Subc	ooling Margin Alert" comes into alarm	
	Which one of the following describes the origin of the alarm?			
		Refere Ste	nce Provided am Tables	
	A. Wide Range Pressure Loop 'C' fails to '0' psig			
	В.	Wide Range Press	sure Loop 'D' fails to '0' psig	
	C.	One safety related	thermocouple fails to 725 degrees	
	D.	Wide Range T hot	'B' loop failing high to 650 degrees	
	Distracter Analysis:. The alarm 'Subcooling Margin Alert' is actuated due to 'A' train inputs only			
	А.	Incorrect : Input to	'B' train	
	в.	Correct:		
	C.	vitin 2 degrees of 6	+750 = 3225 / 5 = 645 degrees which is not 50 where the alarm would come in	
	D.	Plausible: Average Incorrect Input to 'I Plausible:	B' train	
	LEVEL: RO			
	SOURCE: NEW			
	LEVEL OF KNOWLEDGE: Comphrension			
	KA: SYS 002 K6.06 (2.5/2.8)			
	AUTHOR: CWS			
	LESSON: OP-MC-IC-ICM			
Ques_1043.doc	2			

.`

OBJECTIVES: OP-MC-IC-ICM Obj 9 REFERENCES: OP-MC-IC-ICM page 33

~

Ţ

Ques_1043.doc

	Banl	CQuestion: 1044	Answer: D		
1 Pt	Unit 1 was at 100% power when the 'A' FWPT trips. Rods fail to insert as required. The RO places the control rod mode select to manual. The combined power mismatch signal is +4. The operator drives rod in.				
	Whic syste	h one of the following des m?	cribes the response of the rod control		
	А.	Rods will insert at 72	steps per minute.		
	в.	Rods will insert at 64	steps per minute.		
	C.	Rods will insert at 40	steps per minute.		
	D.	Rods will insert at 48	steps per minute.		
	Distr	acter Analysis:.			
	А.	Incorrect: this speed i	s for auto mode only at a 5 degree mismatch		
	В.	Incorrect: this speed is	s for shutdown banks only		
	C.	Incorrect: this speed i degree error	s correct for auto rod movement at a 4		
	D.	Plausible: Correct Plausible:			
	LEVI	EL: RO			
	KA:	014 A4.02 (3.4/3.3)			
	SOURCE: NEW				
	LEVI	EL OF KNOWLEDGE: M	emory		
	AUTI	HOR: CWS			
	LES	SON: OP-MC-IC-IRX			
	OBJ	ECTIVES: OP-MC-IC-IR)	K Obj 8		
	REFI	ERENCES: OP-MC-IC-IR	X pages 21, 23, 25		

	Bank	Question: 1045	Answer: D
1 Pt	A fire to sm (<i>Loss</i>	on the McGuire site has renote in the control room. B of <i>Control Room</i>).	endered the control room uninhabitable due oth units have entered the AP/1/A/5500/17
	Whic AP/1/	h one of the following desc /A/5500/17 Loss of Control	ribes the RO actions described in <i>Room</i> ?
	Α.	Go to Aux Shutdown P	anel.
	B.	Go to main turbine from	nt standard.
	C.	Go to Unit 1 CF pumps	
	D.	Go to "REACTOR PUM if dilution in progress.	P WATER MAKEUP CONTROL PANEL"
	Distr	acter Analysis:.	
	Α.	Incorrect: this is an SR	O function
	В,	Incorrect: this is an NLC) function
	C.	Incorrect: this is an NL Plausible:	O function
	D.	Plausible: Plausible:	
	LEVE	EL: RO	
	KA:	G 2.4.34 (3.8/3.6)	
	SOU	RCE: NEW	
	LEVE	EL OF KNOWLEDGE: Me	mory
	AUTH	IOR: CWS	
	LESS	SON: OP-MC-AP-17	
	OBJE	E CTIVES : OP-MC-AP-17	Dbj. 2
	REFE	ERENCES: AP 17 Backgro AP/1/A/5500	ound document pages 4-6 /17 page 3

Ques_1045.doc

	Bank	Question: 1046	Answer: B		
1 Pt	While shifting to cold leg recirc during a LOCA, 1ND 58A (NV/ NI pump Train A Isolation) will not open.				
	Which	one of the following is a	possible cause of this problem?		
	A.	1NI-115B (A NI Pump I	<i>liniflow</i>) must first be closed.		
	В.	1NI-185A (<i>TRAIN A ND</i>	TO NV & NI PUMPS) must first be open.		
	c.	1ND-19A (A ND Pump	Suction From FWST or NC) must first be open.		
	D.	1NI-144B (<i>B NI Pump i</i>	/iniflow) must first be closed.		
LEVEL: RO					
SOURCE: N	EW				
LEVEL OF K	NOWLE	DGE: MEMORY			
LESSON: O	P-MC-E	CC-NI			
OBJECTIVE:	OP-M	C-ECC-NI Obj. 8			
REFERENCE	S:	OP-MC-ECC-NI page 2	1		
K/A : 006 K3.	01 (4.1/	4.2)			
AUTHOR: C	ws				

......

Ques_1046.doc

	Bank	Question: 1047	Answer: D
1 Pt	Given	the following conditions	on Unit 1:
	• • •	Unit 1 is in Mode 5 aft 'B' Train of ND is in R! In the process of swap An NLO is stationed of excessive vibration. After the swap has be a. EMF 1 and EMF 4 b. NC level decreasing c. ND flow increasing	er an outage. HR mode oping to 'A' train ND utside the 'A" ND HX room to listen for en completed the following is noticed 1 in alarm ng and temperature increasing
	Which	n one (1) of the following	is the cause of the above failure?
	Α.	Relief valve 1ND-56 PRT	(<i>Discharge Relief Valve</i>) has failed open to
	В.	1ND-34 (A & B ND H	(Bypass) fails OPEN
	C.	Relief valve 1ND-56 (NCDT.	<i>Discharge Relief Valve</i>) has failed open to
	D.	Flange leak on 'A' RI	IR heat exchanger.
	Distra	acter Analysis:. The pr operator sent to the McGuire has experie the flange of the RHI	ocedure for swapping ND trains has an HX room to listen for excessive vibration. nced an event where a leak developed on R HX as a result of a water hammer.
	Α.	Incorrect: would not Plausible:	have auxiliary building EMFs in alarm
	В.	Incorrect: This would Plausible:	account for the temperature increasing
	C.	Incorrect: Relief goe Plausible:	s to PRT
	D.	Correct Plausible:	
	LEVE	L: RO	
	KA : 0	005 K6.03 (2.5/2.6)	
	SOUF	RCE: NEW	
	LEVE	L OF KNOWLEDGE: N	lemory

_

. . .

Ques_1047.doc

AUTHOR: CWS LESSON: OP-MC-PS-ND OBJECTIVES: OP-MC-PS-ND Obj. 6 REFERENCES: OP-MC-PS-ND pages 21 and 61

Ques_1047.doc

	Bank Question: 1048 Answer:D				
1 Pt	Given the following conditions on Unit 1:				
	 Unit 1 ETB normal breaker has opened '1B' Diesel Generator has started and has loaded 	the bus			
	Which one (1) of the following will trip the diesel generate	r?			
	A. Lube Oil Temperature 195 degrees				
	B. Jacket Water Temperature 205 degrees				
	C. Turning Gear Engaged				
	D. Overspeed 113%				
	Distracter Analysis:.				
	A. Incorrect: Manual mode only				
	B. Incorrect: Manual mode only				
	Plausible: C. Incorrect: Manual mode only				
	Plausible: D Correct				
	Plausible:				
	LEVEL: RO				
	KA : 064 K4.02 (3.9/4.2)				
	SOURCE: NEW				
	LEVEL OF KNOWLEDGE: Memory				
	AUTHOR: CWS				
	LESSON: OP-MC-DG-DG				
	OBJECTIVES: OP-MC-DG-DG Obj. 5 & 6				
	REFERENCES: OP-MC-DG-DG pages 39-43 odd page	s only			

.

Diesel generator '1B' has been started per OP/1/A/6350/002 (Diesel Generator) from the control room. The diesel has been carrying the load separated from the grid. It is time in the procedure to transfer load back to the grid and shutdown the diesel.

Which one (1) of the following describes the actions in proper sequence necessary to remove load from the diesel?

- A. Match D/G voltage with line voltage Place '1B D/G Sync Switch' to 'ON' Adjust diesel speed to move slowly in the Fast direction using '1B D/G Gov Control' pushbutton Close normal breaker when 3 minutes before 12 o'clock Raise D/G output to 800 to 1000 KW Adjust Power factor to .90 to .92
- B. Place '1B Sync Switch' to 'ON' Adjust diesel speed to move slowly in the Fast direction using Voltage Adjust pushbutton Transfer load from '1B' D/G to 1ATD by obtaining zero amps on 1ATD meter Close normal breaker when 3 minutes before 12 o'clock Raise D/G output to 800 to 1000 KW Adjust Power factor to .90 to .92
- C. Place '1B Sync Switch' to 'ON' Adjust diesel speed to move slowly in the Fast direction using '1B D/G Gov Control' pushbutton Close normal breaker when 3 minutes before 12 o'clock Raise D/G output to 100 to 200 KW Adjust Power factor to .90 to .92 Match D/G voltage with line voltage
- D. Place '1B Sync Switch' to 'ON' Adjust diesel speed to move slowly in the Fast direction using Voltage Adjust pushbutton Transfer load from '1B' D/G to 1ATC by obtaining zero amps on 1ATC meter Close normal breaker when 3 minutes before 12 o'clock
 Raise D/G output to 100 to 200 KW Adjust Power factor to .90 to .92

1 Pt

1 Pt Diesel generator '1B' has been started per OP/1/A/6350/002 (Diesel Generator) from the control room. The diesel has been carrying the load separated from the grid. It is time in the procedure to transfer load back to the grid and shutdown the diesel.

Which one (1) of the following describes the actions in proper sequence necessary to remove load from the diesel?

- A. Match D/G voltage with line voltage Place '1B D/G Sync Switch' to 'ON' Adjust diesel speed to move slowly in the Fast direction using '1B D/G Gov Control' pushbutton Close normal breaker when 3 minutes before 12 o'clock Raise D/G output to 800 to 1000 KW Adjust Power factor to .90 to .92
- B. Place '1B Sync Switch' to 'ON' Adjust diesel speed to move slowly in the Fast direction using Voltage Adjust pushbutton Transfer load from '1B' D/G to 1ATD by obtaining zero amps on 1ATD meter Close normal breaker when 3 minutes before 12 o'clock Raise D/G output to 800 to 1000 KW Adjust Power factor to .90 to .92
- C. Place '1B Sync Switch' to 'ON' Adjust diesel speed to move slowly in the Fast direction using '1B D/G Gov Control' pushbutton Close normal breaker when 3 minutes before 12 o'clock Raise D/G output to 100 to 200 KW Adjust Power factor to .90 to .92 Match D/G voltage with line voltage
- Place '1B Sync Switch' to 'ON' Adjust diesel speed to move slowly in the Fast direction using Voltage Adjust pushbutton Transfer load from '1B' D/G to 1ATC by obtaining zero amps on 1ATC meter Close normal breaker when 3 minutes before 12 o'clock Raise D/G output to 100 to 200 KW Adjust Power factor to .90 to .92

Distracter Analysis:

A. Correct:

Plausible:

B. Incorrect:

_

.

47

- Plausible:
- C. Incorrect: Plausible:
- D. Incorrect Plausible:

LEVEL: RO

KA: 064 A4.07 (3.4/3.4)

SOURCE: NEW

LEVEL OF KNOWLEDGE: Comprehension

AUTHOR: CWS

LESSON:

OBJECTIVES:

REFERENCES: OP/1/A/6350/002 Enclosure 4.4 page 2

	Bank	Question: 1050	Answer: B		
1 Pt	Given	the following con	ditions on Unit 1:		
	•	Unit 1 heating u An NLO calls the pegged HIGH Discharge press	p in Mode 3 following a refueling outage e RO and advises that the boric acid filter delta/p is sure on 1A Boric Acid Tank pump is peaged HIGH		
	Which flowpa	one (1) of the fol th from the Boric	lowing describes the effect on the boron injection Acid Tank?		
	А.	No effect after	swapping to the 1B BAT pump.		
	В.	Boron injectior and charging p	n flowpath from BAT via the boric acid pumps ump to NC is inoperable.		
	C.	No effect after	swapping to standby filter in service.		
	D.	Boron injectior 1NV-265B.	flowpath is operable due to availability of		
	Distra	cter Analysis:.			
	А. В.	Incorrect: Plausible: Correct:			
	C.	Plausible: Incorrect:			
	D.	Plausible: Incorrect Plausible:			
	LEVE	_: RO			
	KA : 0	04 K1.16 (3.3/3.5)		
	SOUR	CE: NEW			
	LEVE	OF KNOWLED	GE: Analysis		
	AUTHOR: CWS				
	LESS	DN: OP-MC-PS-	NV		
	OBJE	CTIVES: OP-MC	-PS-NV Objs. 5 & 15		

Ques_1050.doc

1

<u>ر.</u>

REFERENCES: OP-MC-PS-NV pages 43, 51, & 133 SLC 16.9.9 Boration Systems -- Flow Paths

Ques_1050.doc

· · ··--

4

	Bank	Question: 1051	Answer: D
1 Pt	Which system outsic	n one of the following descrims for a double ended brea le Containment?	bes the operational differences to ESF k inside containment versus a LOCA
	А.	On a LOCA outside con isolation signal.	tainment there will be no containment
	В.	There are no operationa	l differences.
	С.	On a LOCA outside con do not automatically op	tainment the containment sump valves en on low FWST level.
	D.	As FWST inventory dep increase in containmen	etes there is no corresponding sump level.
	Distra	acter Analysis:.	
	А.	Incorrect : A manual S/I and charging flow as a re actuate.	will be generated on low pressurizer level sult a containment isolation signal will
	В.	Incorrect: Phase 'B' com containment	ponents will not actuate on LOCA outside
	C.	Incorrect: Not correct the there is water in the sump	ey will open on 180" FWST level whether⊂ ₀ or not.
	D.	Plausible: Correct Plausible:	
	LEVE	L: RO	
	KA : \	N/E-04 EK2.1 (3.5/3.9)	
	SOUF	RCE: NEW	
	LEVE	L OF KNOWLEDGE: Com	prehension
	AUTH	IOR: CWS	

Ques_1051.doc

×,

LESSON: OP-MC-ECC-ISE OP-MC-PS-ND

r v

> OBJECTIVES: OP-MC-PS-ND Obj. 7 OP-MC-ECC-ISE Objs. 5 and 13

REFERENCES: OP-MC-PS-ND page 29 OP-MC-ECC-ISE pages 15 & 29

6

Ques_1051.doc

	Bank Question: 1052 Answer: A				
1 Pt	Which one (1) of the following provides separation between control system and protection system circuits?				
	A. Isolation Amplifier				
	B. Diodes				
	C. Separate input signal				
	D. Or/And gate				
	Distracter Analysis:.				
	A. Correct: Plausible:				
	B. Incorrect:				
	Plausible: C. Incorrect:				
	Plausible: D Incorrect				
	Plausible:				
	LEVEL: RO				
	KA: SYS 016 K5.01 (2.7*/2.8*)				
	SOURCE: NEW				
	LEVEL OF KNOWLEDGE: Memory				
	AUTHOR: CWS				
	LESSON: OP-MC-IC-IPE				
	OBJECTIVES:				
	DEFENCES: OD MC IC IDE page 17				

_

	Bank Question: 1056 Answer: C
1 Pt	Given the following conditions on Unit 1:
	 Loss of Offsite Power coincident with a LOCA Power has been restored to ETA via '1A' D/G while in EP/1/A/5000/ECA-0.0 (<i>Loss of All AC Power</i>) NC Subcooling is -1 degree Pzr level is 0% 1NI-9A (<i>NC Cold Leg Inj from NV</i>) is closed 1NI-10B (<i>NC Cold Leg Inj from NV</i>) is closed Which one (1) of the following procedure is required for optimal recovery of
	the plant?
	A. Go to EP/1/A/5000/ECA-0.1 (Loss of All AC Power Recovery Without S/I Required)
	B. Go to EP/1/A/5000/E-1 (Loss of Reactor or Secondary Coolant)
	C. Go to EP/1/A/5000/ECA-0.2 (Loss of All AC Power Recovery With S/I Required
	D. Go to EP/1/A/5000/ES-1.2 (Post LOCA Cooldown and Depressurization)
	Distracter Analysis:
	A. Incorrect:
	B. Incorrect: Plausible:
	C. Correct:
	D. Incorrect Plausible:
	LEVEL: RO
	KA : 000056 AK1.04 (3.1*/3.2*)
	SOURCE: NEW
	LEVEL OF KNOWLEDGE: Comprehension
	AUTHOR: CWS

Ques_1056.doc

,

•*

LESSON: OP-MC-EP-ECA-0

•

•

OBJECTIVES: OP-MC-EP-ECA-0 Obj 2

REFERENCES: OP-MC-EP-ECA-0 Page 61 EP/1A/5500/ECA 0.0 page 30

Ques_1056.doc
	Bank	Questio	n: 1059	An	swer: D	
1 Pt	Given the following conditions on Unit 1:					
		Large Both ti	break LOC/ rains of NV,	A occurred. NI, ND, NS are	e running	
			Loop A	Loop B	Loop C	Loop D
	S/G (NR) [%]	10	9	10	9
	The tells imple	operators the SRO ement En	are in E-0 (NC tempera closure 3 <i>U</i>	(<i>Reactor Trip o</i> ature is decreas ncontrolled NC	r Safety Injectio sing. The RO is System Coold	on) step 17. The RO s instructed to own.
	Whic contro	h one of t olling feed	he following d flow?	statements co	rrectly describe	es the method for
			REFEREN E-0	ICES PROVID Enclosure3	ED:	
	A.	A. When N/R level is greater than 11% in one S/G throttle feed flow to minimum and maintain N/R level greater than 11% in at least one S/G.				
	В.	When I flow to S/Gs.	N/R level is minimum	greater than and maintain	32% in all S/G N/R level grea	s throttle feed ter than 32% in all
	C.	If N/R I minimi than 4	evel is less ize cooldov 50 gpm.	than 11% in a vn and mainta	all S/Gs throttl in total feedwa	e feed flow to ater flow greater
	D.	lf N/R I minimi than 4	evel is less ize cooldov 50 gpm.	s than 32% in a vn and mainta	all S/Gs throtti in total feedwa	e feed flow to ater flow greater
	Distra	acter Ana	alysis:			
	Α.	Incorre Plausil	ect: ble:			
	В.	Incorre	ect:			
	C.	Incorre	ect			
	D.	Correc	t:			
		Plausil	ble:			

Ques_1059.doc

-- --

..

.`

KA: SYS 061 K5.01 (3.6/3.9)

Lesson Plan Objective: OP-MC-EP-E0 Obj. 6

.....

Source: NEW

v

.~

AUTHOR: CWS

Level of knowledge: Analysis

References:

1. OP-MC-EP-E-0 page 75

2. EP/1/A/5000/E-0 Enclosure 3 - PROVIDED

Ques_1059.doc

1 Pt Given the following conditions on Unit 1:

- RTP 100%
- A CM system transient has caused both FWPT's to trip.
- The turbine and reactor failed to trip automatically.
- The Operator at the Controls, per the immediate actions of FR-S.1 (*Response to Nuclear Power Generation/ATWS*), will
 - 1. Manually trip the Reactor if it fails to trip, insert control rods.
 - 2. Manually trip the Turbine if it fails to trip, runback the turbine in fast action.

Which one (1) of the following describes the bases for the immediate actions in FR-S.1 (Response to Nuclear Power Generation/ATWS)

- A. The safeguards systems are designed assuming that the only heat being added to the NC system is decay heat and NC pump heat. If the reactor will not trip, then the rods are manually inserted to lower reactor power. For an ATWS event with a loss of normal feedwater, a Turbine trip within 30 seconds will prevent challenging the PZR PORV's.
- B. The safeguards systems are designed assuming that the only heat being added to the NC system is decay heat and NC pump heat. If the reactor will not trip, then the rods are manually inserted to lower reactor power. For an ATWS event with a loss of normal feedwater, a Turbine trip within 30 seconds will maintain S/G inventory.
- C. The safeguards systems are designed assuming that the only heat being added to the NC system is from less than 5% power. If the reactor will not trip, then the rods are manually inserted to lower reactor power to less than 5%. For an ATWS event with a loss of normal feedwater, a Turbine trip within 30 seconds will maintain S/G inventory.
- D. The safeguards systems are designed assuming that the only heat being added to the NC system is from less than 5% power. If the reactor will not trip, then the rods are manually inserted to lower reactor power to less than 5%. For an ATWS event with a loss of normal feedwater, a Turbine trip within 30 seconds will prevent challenging the PZR PORV's

Distracter Analysis:.

A. Incorrect: Plausible:

Ques_1061.doc

B. Correct:

.

- Plausible:
- C. Incorrect:
- D. Plausible: Plausible: Plausible:
 - T MUSIC

LEVEL: RO

KA: 000029 EK1.01 (2.8/3.1)

SOURCE: NEW

LEVEL OF KNOWLEDGE: Analysis

AUTHOR: CDC

LESSON: OP-MC-EP-FRS

OBJECTIVES: OP-MC-EP-FRS Obj 4

REFERENCES: OP-MC-EP-FRS pages 23 & 25 EP/1/A/5000/FR-S.1 page 2

One of fission basis I Which	the functions of the Cor product iodine from the OCA.	tainment Spray System (NS) is to remove
Which		containment atmosphere during a design
accom	one (1) of the following plished?	describes how and when this is
А.	During the Injection p subcooled borated wa containment volume.	hase by providing a spray of cold and ater from the FWST into the upper
В.	During the Injection p an alkaline pH from th containment volume.	hase by providing a spray of water with le containment sump into the upper
C.	During the Recirculati and subcooled borate containment volume.	ion phase by providing a spray of cold d water from the FWST into the upper
D.	During the Recirculati with an alkaline pH fro containment volume.	ion phase by providing a spray of water om the containment sump into the upper
Distra	cter Analysis:.	
А.	Incorrect:	
в.	Plausible: Incorrect:	
C.	Plausible: Incorrect:	
	Plausible:	
D.	Correct Plausible:	
LEVEL	.: RO	
KA : 0:	27 K1.01 (3.4/3.7)	
SOUR	CE: NEW	
LEVEI	. OF KNOWLEDGE: M	emory
AUTU	DR: CDC	

.

_

Ques_1062.doc

, ² , , ,

1 Pt

LESSON: OP-MC-ECC-NS

÷

OBJECTIVES: OP-MC-ECC-NS Obj 1

REFERENCES: OP-MC-ECC-NS page 11 MNS Technical Specifications Bases for T.S. 3.6.6 Containment Spray System

Ques_1062.doc

1 Pt Given the following conditions on Unit 1:

- RTP is 100%
- 'B' train is in operation
- CF&E sump HI level alarm is lit.
- All NC Pump Motor Bearing LO KC flow annunciators are lit.
- All NC Pump upper Motor Bearing temperatures are trending up.
- "B" NC Pump Upper Motor Bearing temperature is 197 degrees.
- AP-21(Loss of KC or KC System Leakage) has been implemented.

Which one (1) of the following describes the operator's response to "B" NCP Upper Motor Bearing HI temperature?

AP/1/A/5500/21 Loss KC

- A. Close 1NC-29 (*B Loop PZR Spray Control*), trip the reactor, stop "B" NC Pump and go to EP/1/A/5000/E-0
- B. Trip the reactor, stop "B" NC Pump and go to EP/1/A/5000/E-0
- C. Trip the reactor, trip all NC Pumps and go to EP/1/A/5000/E-0
- D. Close 1NC-29, trip the reactor, trip all NC Pumps and go to EP/1/A/5000/E-0

Distracter Analysis:.

- A. Incorrect:
- Plausible:
- B. Incorrect:
- Plausible: C. Correct:
- Plausible: D. Incorrect
 - Plausible:

LEVEL: RO

KA: 000026 G2.4.47 (3.4/3.7)

SOURCE: NEW

LEVEL OF KNOWLEDGE: Analysis

AUTHOR: CWS

Ques_1063.doc

LESSON: OP-MC-AP-21 OBJECTIVES: OP-MC-AP-21 Obj 4 REFERENCES: OP-MC-AP-21 page 4 ------

Ques_1063.doc

Ś

.....

	Bank Question: 1064 Answer: A
1 Pt	Given the following conditions on Unit 1:
	 Medium size LOCA has occurred with valid Ss, St and Sp signals S/I termination criteria are satisfied One NV pump has been secured Both NI pumps have been secured Both ND pumps have been secured Pzr Spray valves are closed
	Pressurizer level is 25% and decreasing. Which one of the following describes the correct operator actions?
	REFERENCE PROVIDED: ES 1.1
	A. Restart S/I pumps and realign NV S/I flowpath as necessary to restore subcooling and level, GO TO EP/1A/5000/E-1 (<i>Loss of Reactor or Secondary Coolant</i>).
	B. Go to EP/1/A/5000/ES 1.2 (Post LOCA Cooldown and Depressurization).
	C. Go directly to EP/1/A/5000/ES-0.0 (Rediagnosis)
	D. Reinitiate Safety Injection and GO TO EP/1/A/5000/E-0 (Reactor Trip or Safety Injection).
	Distracter Analysis:.
	 A. Correct: Plausible: B. Incorrect: Plausible: C. Incorrect: Plausible: D. Incorrect Plausible:
	LEVEL: RO
	KA : W/E-2 EK2.2 (3.5/3.9)
	SOURCE: NEW
	LEVEL OF KNOWLEDGE: ANALYSIS

---- -----

- -

Ques_1064.doc

×

÷

AUTHOR: CWS

ي. تو ر

4

LESSON: OP-MC- EP-E-1

OBJECTIVES: OP-MC-EP-E-1 Obj. 4

REFERENCES: OP-MC-EP-E-1 pages 65 & 67 EP/1/A/5000/ES-1.1 -----

Ques_1064.doc

Bank Question: 1066

1 Pt. The SRO instructs the Unit 1 RO to adjust NC Pump seal leak off flow by cooling the VCT. The potentiometer on 1KC-132 (*Letdown Heat Exchanger Outlet Temperature Control*) was adjusted to lower VCT temperature 6 degrees.

Which one of the follow is the correct plant response to this adjustment?

- A. VCT temperature decreases KC pump flow decreases KC pump discharge pressure increases NC temperature increase Main Steam pressure increases.
- B. VCT temperature decreases KC Pump flow increases KC Pump discharge pressure decreases NC temperature decrease Main Steam pressure decreases
- C. VCT temperature decreases KC Pump flow increases KC Pump discharge pressure decreases NC temperature increase Main Steam pressure increases
- D. VCT temperature decreases KC Pump flow decreases KC Pump discharge pressure increases NC temperature decreases Main Steam pressure decreases

Distracter Analysis:.

- A. Incorrect:
- Plausible: B. Incorrect:
- Plausible:
- C. Correct: Plausible:
- D. Incorrect Plausible:

LEVEL: RO

KA: SYS 008 A4.06 (2.5*/2.5)

Ques_1066.doc

SOURCE: NEW

\$

2

LEVEL OF KNOWLEDGE: ANALYSIS

AUTHOR: CWS

LESSON: -

OBJECTIVES:

REFERENCES: OP/1A/6200/001 B page 1 & 2

Ques_1066.doc

Ba	nk Question: 1068	Answer: D			
1 Pt. Giv	ven the following conditions or	ı Unit 1:			
	 ORANGE Path on Core (RED Path on Heat Sink 	Cooling			
Wr add	nich one of the following descr dressed prior to the Orange Pa	ibes why Red path on Heat Sink is ath on Core Cooling?			
A.	A Red path indicates th prompt operator action	e CSF is under <u>severe</u> challenge and is required.			
В.	A Red path indicates th action may be taken.	e CSF is <u>not satisfied</u> and operator			
C.	Heat Sink has a <u>higher</u> position on status trees	priority than Core Cooling due to			
D.	A Red path indicates th immediate operator act	e CSF is under <u>extreme</u> challenge and ion is required.			
Dis	stracter Analysis:.				
А. В. С. D.	Incorrect: Plausible: Incorrect: Plausible: Incorrect: Plausible: Correct Answer Plausible:				
LE	VEL: RO				
KA	KA : G2.4.22 (3.0/4/0)				
so	SOURCE: NEW				
LE'	LEVEL OF KNOWLEDGE: Memory				
AU	AUTHOR: CWS				
LE	LESSON: OP-MC- EP-INTRO				
OB	JECTIVES: OP-MC-EP-E-1	Objs. 1 & 3			

7

·····

....

· · · · · ----

Ques_1068.doc

5-

REFERENCES: OP-MC-EP-INTRO pages 21,27,29

· -- · ·

- ----

- -

Ques_1068.doc

j,

.

. <u> </u>	Bank	Question: 1069	Answer: B				
1 Pt.	Unit 1 outage	is in the process of cooling e.	down to Mode 5 to enter refueling				
	•	Steam dumps in Steam Pr Controller in Manual	essure Mode with Steam Dump				
	•	15 minutes after cooldown dumps close.	has begun from 557 degrees steam				
	Which closed	Which one of the following describes the correct reason the steam dumps closed?					
	Α.	Potentiometer set too hig	gh on Steam Dump Controller.				
	В.	Cooled down to P-12.					
	C.	C-7A not reset.					
	D.	Tave and Tref deviation i	s less than 3 degrees.				
	Distra	cter Analysis:.					
	А.	Incorrect: POT has no eff	fect in manual steam dump control				
	В.	Correct: Plausible					
	C.	Incorrect: No effect Plausible: condition requi	red to arm steam dumps when in Tave				
	D.	mode Incorrect No effect Plausible: On a load reje for banks to start modulatir	ction must have greater than 3 degrees				
	I EVEI	• RO	19				
	NA. G	2.2.2 (3.3/3.9)					
	SOUR	CE: NEW					
	LEVEL	. OF KNOWLEDGE: Memo	ory				
	AUTHO	DR: CWS					
	LESSC	DN: OP-MC-STM-IDE					
	OBJE	CTIVES: OP-MC- STM-IDE	Obj. 10				

Ċ,

REFERENCES: OP-MC-STM-IDE pages 35-49 odd only

· · · _____

-

Ques_1069.doc

 \leq

	Ban	k Question: 1070	Answer: C		
1 Pt.	Give	n the following conditions o	n Unit 1:		
	 RN system is in normal alignment RN pump 'B' is running RV pumps are in normal alignment Unit 1 experiences a Safety Injection 				
	Which one of the following describes the cooling water supply provided to lower containment ventilation loads?				
	А.	'A' RN pump			
	В.	'B' RN pump			
	C.	RV pump in AUTO that pressure.	starts on low non-essential header		
	D.	RV pump in AUTO that	starts on safety injection signal.		
	Distr	acter Analysis: 1RN-42/ essential headers. RN essential header press alignment for RN and v question.	A closed on S/I. Lose RN flow to non / pump in AUTO will start on low non sure. Operator needs to know S/I when RV pumps start to answer		
	А.	Incorrect:			
	В.	Incorrect:			
	C.	Correct:			
	D.	Plausible: Incorrect Plausible:			
	LEVE	EL: RO			
	KA:	SYS 076 A1.02 (2.6*/2/6*)			
	SOU	RCE: NEW			
	LEVE	EL OF KNOWLEDGE: M	emory		
	AUTI	HOR: CWS			
r.					
Ques_1070.0	doc				

.....

•

LESSON: OP-MC- CNT-RV

-

...

OBJECTIVES: OP-MC-CNT-RV Obj. 10

REFERENCES: OP-MC-CNT-RV pages 13 & 25 OP/0/A/6400/009 Enclosure 4.1 OP-MC-PSS-RN page 75

Ques_1070.doc

1 Pt(s) Unit 1 is in the process of releasing the Ventilation Unit Condensate Drain Tank (VUCDT) using approved station procedures. Just after the release was initiated, the 1EMF-44 (Ventilation Unit Condensate Drain Tank) power supply fails.

Which one of the following statements correctly describes the effect on this Liquid Waste Release (LWR)?

REFERENCE PROVIDED SLC 16.11.2

- A. 1EMF-44 fails in the conservative direction and both Trip 1 and Trip 2 alarm, terminating the release. The high radiation alarms can not be reset and the release can not be continued.
- B. 1RAD2-F/2, 'EMF-44 LOSS OF CONT VENT DRN TNK SAMPLE FLOW' alarms and the release must be terminated.
- C. 1EMF-44 will alarm Trip 1 and Trip 2 terminating the release. The Trip 2 alarm may be reset only one time, if no further alarms are received. The LWR may proceed provided that station RP performs an analysis of grab samples for radioactivity at a lower limit of detection.
- D. Nothing, there is no effect on this LWR. The LWR may proceed provided that station RP performs an analysis of grab samples for radioactivity at a lower limit of detection.

Distracter Analysis:

- A. Incorrect: The hi rad alarms will not be received upon loss of power supply.
 Plausible: Some bistables and alarms 'fail on' when power is lost or detectors fail.
- B. Incorrect: The LOSS OF SAMPLE FLOW will alarm.
 Plausible: There is an alarm for loss of sample flow, but there is not an alarm for loss of power.
- C. Incorrect: The hi rad alarms will not be received.
 Plausible: Some hi rad alarms may be reset one time to reinitiate the LWR without additional sampling or LWR paperwork.
- D. Correct:

Level: RO

:

KA: SYS 073 A2.02 (2.7/3.2)

Lesson Plan Objective:

Source: New

Level of knowledge: comprehension

References:

1. 1RAD2-F/2 Annunciator Response Procedure 2. SLC 16.11.2

Answer: C

1 Pt. Given the following conditions:

- Unit 1 is in a refueling outage.
- Fuel movement is in progress.
- The Spent Fuel Pool Level Low computer alarm has actuated.
- Initially 1EMF 17 (SPENT FUEL BLDG. REFUEL. BRDG) was reading radiation 7 mrem/hr.
- After 20 minutes 1EMF-17 is 18 mrem/hr.

Which one (1) of the following describes the operator response to the current conditions?

- A. Begin makeup to the pool from the Boric Acid Tank to restore level.
- B. Move the fuel transfer cart to the reactor side and close 1KF-122 (Fuel Transfer Tube Block Valve).
- C. Move the fuel transfer cart to the spent fuel (pit) side and close 1KF-122 (*Fuel Transfer Tube Block Valve*).
- D. Place the weir gate in position and inflate the seals.
- LEVEL: SRO

SOURCE: BANK

LEVEL OF KNOWLEDGE: Memory

REFERENCES: OP-MC-FH-FC pages 19-25 odd only

LESSON: OP-MC-FH-FC

OBJECTIVE: OP-MC-FH-FC Obj. 6

K/A: 036 AA2.02 (3.4/4/1)

1 Pt. Unit 1 is in mode 4.

Given the following conditions:

- (1) Surveillance testing has been recently completed on the ice condenser
- (2) The surveillance test was not satisfactory as described below

Which one (1) of the following situations meets the requirements for a one hour Tech Spec LCO?

- A. The ice condenser door position monitoring system was declared inoperable when one door did not indicate in the open position during a surveillance test. The door was left in the open position.
- B. The ice bed was declared inoperable when it was determined that it failed a surveillance test based on total ice weight less than 2,099,790 pounds at a 95% level of confidence.
- C. The Ice Bed Temperature Monitoring System was declared inoperable when it failed a Tech Spec surveillance test channel check failure.
- D. The ice condenser intermediate deck door was declared inoperable when it was discovered to be obstructed from opening by ice and debris.
- LEVEL: SRO
- SOURCE: BANK
- **REFERENCES:** Tech Spec 3.6.13

LESSON: OP-MC-CNT-NF

OBJECTIVE: OP-MC-CNT-NF Obj. 21

K/A: SYS 025 G2.2.22 (3.4/4.1)

LEVEL OF KNOWLEDGE: Memory

1 Pt. Unit 1 is preparing for a reactor start up following a refueling outage. Given the following conditions:

- T_{avg} = 515 °F
- Plant heatup in progress using NCPs

At 0200, a Station Engineer reports that a mistake had been made in analyzing the containment Appendix J Leak Rate Test results that were conducted prior to exceeding 200 °F in mode 5. Reanalysis indicated that the combined containment leak rate (Type A) had exceeded $1.0 L_a$.

Which one of the following actions are required by Tech Specs in response to this situation?

REFERENCES PROVIDED Tech Spec 3.6.1and Bases

- A. Commence a plant cooldown to reach mode 5 within 36 hours.
- B. Commence a plant cooldown to reach mode 5 within 37 hours.
- C. Commence a plant cooldown to reach mode 5 within 42 hours.
- D. Commence a plant cooldown to reach mode 5 within 43 hours.

Distracter Analysis:

- A. Incorrect:
- Plausible:
- B. Incorrect: Plausible:
- C. Correct: Plausible:
- D. Incorrect Plausible:

SOURCE: BANK

LEVEL: SRO

LEVEL OF KNOWLEDGE: ANALYSIS

KA: SYS 103 A2.01 (2.0*/2.6)

Ques_207.1.doc

OBJECTIVES: OP-MC-ADM-TS Obj. 2

REFERENCES: Tech Spec 3.6.1 and Bases OP-MC-ADM-TS pages 29, 31

Ques_207.1.doc

ي.

7

1 Pt Which one of the following statements complies with the requirements of OMP 4-3 (*EP/AP Implementation Guidelines*) regarding the rules of usage for abnormal procedures (APs) when the emergency procedures (EPs) have been implemented?

- A. APs may not be implemented when EPs have been entered.
- B. Only one AP at a time may be implemented when EPs have been implemented. Concurrent implementation of APs when EPs are in use is not allowed.
- C. APs may be implemented concurrently with EPs. However, the APs were written assuming that SI has not actuated and operators must be careful when using APs if SI has occurred.
- D. APs may be implemented concurrently with EPs with the exception of events where SI has actuated. APs were written assuming the SI had not occurred and cannot be used if SI has actuated.

Distracter Analysis:

- A. Incorrect: APs may be entered after EOPs have been started Plausible: Many plants have this provision - symptomatic EOPs should address all significant safety challenges without requiring APs
- **B.** Incorrect: No limitation on the number of APs Plausible: Makes sense to limit the number of concurrent procedures in use
- C. Correct answer
- D. Incorrect: No explicit prohibition against use of APs when SI has actuated BUT there is a caution and the APs were written for the situation where SI has NOT occurred.
 Plausible: APs were written for the situation where SI has NOT occurred.

LEVEL: SRO

SOURCE: BANK

LEVEL OF KNOWLEDGE: Memory

KA: G 2.4.5 (2.9/3.6)

Ques_338.1.doc

REFERENCE: OMP 4-3 pages 21 & 22

ì

Ques_338.1.doc

Bank Question: 697.3

Answer; C

1 Pt.

ť,

Unit 2 is operating at 100% power. 2NI-59 (*Cold Leg Accumulator Check Valve*) begins to leak at 0200. Given the following accumulator indications:

Time	0200	0300	0400	<u>0500</u>
Level (%)	21%	31%	41%	51%
Pressure (psig)	586	611	636	661
Boron (ppm)	2500	2490	2480	2470

When does the accumulator first exceed a limiting condition for operation?

REFERENCES PROVIDED: Tech Spec 3.5.1 Unit 1 Data Book curve 7.4 Unit 1 Cycle 16 COLR – page 24

- A. 0200
- B. 0300
- **C.** 0400
- D. 0500

Distracter Analysis: Tech Spec values for CLA parameters are: Volume $\geq 6870 (12.3\%)$ but ≤ 7342 gal (38.7%) – exceeded at 0400 (high) Pressure ≥ 585 but ≤ 639 psig – exceeded at 0400 Boron concentration ≥ 2475 ppm but ≤ 2875 ppm – exceeded at 0300

- A. Incorrect Answer: nothing out of spec.
- B. Incorrect: nothing out of spec Plausible:
- C. Correct: the LCO is first exceeded at 0400 on accumulator level Plausible:
- **D.** Incorrect: the LCO is first exceeded at 0400 on accumulator level Plausible:

Level: SRO

KA: G2.1.25 (2.8/3.1)

Lesson Plan Objective: ECC-CLA Obj. 7

Source: Bank

Level of knowledge: comprehension

References:

÷.

r F

1. OP-MC-ECC-CLA page 23

2. Tech Spec 3.5.1 - PROVIDED

3. Unit 1 Data Book Curve 7.4 - PROVIDED

4. Unit 1 Cycle 15 COLR - PROVIDED

Ques_697.3.doc

1 Pt. Unit 1 was operating at 100% when a large break LOCA with loss of offsite power occurs. One diesel generator fails to start. The operators are entering E-1 (Loss of Reactor or Secondary Coolant).

Given the following critical safety function status indications:

• Core Cooling - RED

3

- Subcriticality GREEN
- Containment RED
- Inventory GREEN
- Heat Sink RED
- Integrity RED

Which one of the following describes the highest priority problem, and the appropriate operator action?

- A. Integrity; Transition to FR-P.1, (Response to Imminent Pressurized Thermal Shock).
- B. Core cooling; Transition to FR-C.1, (*Response to Inadequate Core Cooling*).
- C. Heat Sink; Transition to FR-H.1, (Response to Loss of Secondary Heat Sink).
- D. Containment; Transition to FR-Z.1, (Response to High Containment Pressure).

Distracter Analysis:

- A. Incorrect: Core Cooling is the highest priority RED Plausible:
- B. Correct: Plausible:
- **C. Incorrect**: core cooling is the highest priority RED
- **D. Incorrect**: core cooling is the highest priority RED **Plausible**:.

Level: SRO

KA: WE 07 EA 2.1 (3.2/4.0)

Lesson Plan Objective: EP-F0 SEQ 2, 3

Ques_776.1.doc

Source: Bank

.....

-

÷

.

Level of knowledge: Memory

References: 1. OP-MC-EP-F0 pages 13, 15 2. OMP 4-3 pages 15-16

Ques_776.1.doc

ĉ

1 Pt.	Unit 1 is operating at 100% power when the OAC registers a low spent fuel
	pool level alarm. Given the following events and conditions:

- The operators read –2.1 ft SFP level and stable on the main control board.
- The operating KF pump has tripped.
- An NLO reports a large leak in the auxiliary building has stopped.
- Normal SFP makeup is not available.

Which one of the following statements correctly describes the corrective action for this event?

- A. Implement AP/1/A/5500/41 (*Loss of Spent Fuel Cooling or Level*), find and isolate the leak on the KF discharge piping.
- B. Implement AP/1/A/5500/41 (Loss of Spent Fuel Cooling or Level), find and isolate the leak on the KF suction piping.
- C. Implement AP/1/A/5500/21 (Loss of KC or KC System Leakage), and initiate assured makeup due a leak on the discharge piping.
- D. Implement AP/1/A/5500/21 (Loss of KC or KC System Leakage), and initiate assured makeup due to a leak on the suction piping.

Distracter Analysis:

- A. Correct:
- B. Incorrect: The leak is on the discharge piping.
 Plausible: If the candidate confuses the piping immersion depth with the suction pipes, which are at 4 feet.
- C. Incorrect: KF leak not a KC leak Plausible:.
- **D.** Incorrect: Do not use the assured source, and the leak is on the discharge piping.
 Plausible:.

Level: SRO

KA: SYS 033 A2.02(2.7/3.0)

Lesson Plan Objective: OP-MC-FH-KF Obj. 4/5/14

Source: BANK

.>

÷

Level of knowledge: Comprehension

References: 1. OP-MC-FH-KF pages 19, 23, 49

Ques_892.3.doc

1 Pt.	Unit 2 is operating at 100 % power. Given the following events and conditions:					
	• "E	3" essential train components are in service.				
	The ⁻ wants	Test Group Supervisor comes to you the Control Room SRO and s to perform valve stoke testing.				
	Whic	Which one of the following valves would you NOT allow testing?				
	А.	0RN-1 (LLI Supply to RN)				
	B.	2RN-40A (Train A to Non- Ess Hdr Isol)				
	C.	0RN-7A (Train 1A & 2A SNSWP Supply)				
	D.	2RN-64A (AB Non-Ess Return Isol)				
	Distracter Analysis:					
	А. В.	Correct: . Incorrect: . Plausible:				
	C.	Incorrect: Plausible:				
	D.	Incorrect: Plausible: .				
		Level: SRO				
		KA: APE 062 AA2.0(2.9/3.6)				
		Lesson Plan Objective: PSS-RN Obj 7				

Source: Bank

Level of knowledge: comprehension

References: 1. OP-MC-PSS-RN pages 23, 41, 73, 85 2. OP-MC-PSS-KC page 39

	Bank Question: 991.1	Answer: A			
1 Pt.	Which one of the following is a correct list of SAFETY LIMITS?				
	A. Thermal Power, RCS Pressure.	Highest Loop Tave and Pressurizer			
	B. Thermal Power, AFD,	Pressurizer Pressure.			
	C. AFD, QPTR and Reac	tor Power.			
	D. Linear Heat Generation	on Rate, Thermal Power and QPTR.			
	Distracter Analysis:				
	 A. Correct: Plausible: B. Incorrect: Plausible: C. Incorrect: D. Incorrect: Plausible: 				
	Level: SRO Only				
	KA: G 2.1.10 (2.7/3.9)				
	Lesson Plan Objective: (None)				
	Source: New				
	Level of knowledge: memory				
	References: 1. Tech Spec 2.1.1				

Ques_991.1.doc

1 Pt. Unit 1 has experienced a 50% load rejection which resulted in Control Bank "D" Group 1 being greater than 12 steps misaligned from its associated step counter. Tech Spec 3.1.4 Rod Control Group Alignment Limits states:

"All shutdown and control rods shall be OPERABLE; with all individual indicated rod positions within12 steps of their group step counter demand position".

Which one of the following is the bases for this Tech Spec?

- A. Ensure SDM limits are maintained and QPTR is maintained within limits.
- B. Ensure power distribution and SDM limits are preserved.
- C. Ensure QPTR is maintained within limits and rod alignments are correct.
- D. Ensure AFD is maintained and limit power distribution.

Distracter Analysis:

- A. Incorrect:.
- Plausible: B. Correct:
- B. Correct: C. Incorrect:
- Plausible:
- D. Incorrect:. Plausible:

Level: SRO

KA: G2.2.25 (2.5/3.7)

Lesson Plan Objective:OP-MC-IC-IRX Obj. 14

Source: BANK

Level of knowledge: Memory

References: 1.T.S. 3.1.4 Bases

 Bank	Question:	1033	Answer: A	
Unit 1	is operating	at 100% power wh	nen the following occurs:	
• • •	LOCA outs The leak o Containme FWST leve FWST has	side containment an <u>not</u> be isolated ent Sump Level is N el is 178" s <u>not </u> ruptured	lormal	
Which	of the follow	wing procedures wo	ould be used to MITIGATE the event?	?
A. EC	A-1.1 (Los	s of Emergency Co	oolant Recirc)	
B. EC	A-1.2 (LOC	CA Outside Contail	nment)	
C. ES	-1.2 (Post I	LOCA Cooldown a	and Depressurization)	
D. ES	-1.3 (<i>Tran</i> s	fer to Cold Leg Re	ecirc)	
Distra	cter Analys	sis:		
Α.	Correct –			
В.	Incorrect.			
C.	Incorrect			
D.	Incorrect			
	Level: SF	RO		
	KA: EPE V	V/E11 EA2.1 (3.4/4	.2)	
	Lesson Pla	an Objective: OP-N	MC-EP-E1 Obj. 6	
	Source: N	ew		
	Level of kr	nowledge: Analysis		
	Author: CV	VS		
	Reference 1. OP-MC 2. ES 1.3	es: -EP-E1 page 157 Transfer to Cold Leg	g Recirc.	

1 Pt.
1 Pt. Given the following conditions:

٠.

- Pressurizer Level Channel 1 is at 28% level
- Pressurizer Level Channel 2 associated bistables are in the tripped condition due to surveillance testing
- Pressurizer Level Channel 3 fails high.
- N-41 is 8%
- N-42 is 10%
- N-43 is 9%
- N-44 is 9%
- Impulse pressure channel 1 is 11%
- Impulse pressure channel 2 is 9%
- No reactor trip has occurred

Which of the following describes the proper operator response?

- A. Trip the reactor and enter E-0 (Reactor Trip or Safety Injection)
- B. Trip the reactor and enter FR-S.1 (*Response Nuclear Power Generation/ATWS*)
- C. Do not trip the reactor because thermal power is less than P-7
- D. Do not trip the reactor. Initiate unit shutdown.

Distracter Analysis:

- A. Incorrect: This example is not a valid ATWS event. This is a loss of reactor protection. Therefore you do not trip the reactor.
- B. Incorrect: This example is not a valid ATWS event. This is a loss of reactor protection. Therefore you do not trip the reactor.
- C. Incorrect: Greater than P-7. Pzr Hi level trip is in effect
- D. Correct

Level: SRO

KA: APE 029 EA2.02 (4.2/4.4)

Lesson Plan Objective: OP-MC-IC-IPE Obj. 10 & 11

Source: New

5

.7

Level of knowledge: Analysis

Author: CWS

References: 1. OP-MC-IC-IPE pages 47, 79 & 81 2. OMP 4-3 page 9

Ques_1035.doc

	Bank Question: 1037 Answer: D			
1 Pt.	Given the following conditions on Unit 1:			
	 A steam leak has occurred on the main steam header Unit 1 reactor has been tripped and safety injection has actuated The MSIVs will not close 20 minutes into the event lowest loop NC Tcold is 305 degrees 			
	Based on the above conditions which one of the following is the correct procedure flowpath?			
	A. From E-0 Reactor Trip or Safety Injection GO TO FR-P.2 (Response to Anticipated Pressurized Thermal Shock)			
	B. From E-0 go directly to ECA 2.1, (Uncontrolled Depressurization of all Steam Generators)			
	C. From E-0 GO TO FR-P.1, (<i>Response to Imminent Pressurized</i> Thermal Shock)			
	D. From E-0 GO TO E-2, (<i>Faulted Steam Generator Isolation</i>) and then to ECA 2.1			
	Distracter Analysis: A. Incorrect: Plausible: B. Incorrect: Plausible: C. Incorrect: Plausible: D. Correct Plausible:			
	LEVEL: SRO			
	KA : W/E12 EA2.1 (3.2/4.0)			
	SOURCE: NEW			
	LEVEL OF KNOWLEDGE: Comprehension			
	AUTHOR: CWS			

, (* -

OBJECTIVES: OP-MC-EP-E2 Obj 2,6

. . .

> REFERENCES: OP-MC-EP-E2 pages 9, 15 & 23 EP/1/A/5000/F-0 page 7 EP/1/A/5000/E.2 page 2

Ques_1037.doc

	Bank	Question: 1042	Answer: D			
1 Pt.	Given	the following cond	itions on Unit 1:			
	• • • • • •	Chemistry had co A large break LO E-0 <i>Reactor Trip</i> ES-1.3 <i>Transfer</i> E-1 <i>Loss of Reac</i> ES-1.2 <i>Post LOC</i> All Red and Oran 1EMF 51A is reac Pressurizer level	onfirmed two leaking fuel rods CA occurs <i>or Safety Injection</i> is complete to Cold Leg Recirc is complete etor or Secondary Coolant is complete CA Cooldown and Depressurization is in effect. age Paths have been addressed ding 39R/HR is 0%			
	Th pro im	e SRO is currently ocedures. Which o plementation?	considering implementing Yellow Path one of the following describes proper procedure			
	А.	Go to FR-I.3, (<i>R</i> exit ES-1.2	esponse to Voids in the Reactor Vessel) and			
	В.	Stay in ES-1.2 a	nd implement FR-I.3 concurrently			
	C.	Go to FR-Z.3, (<i>R</i> and exit ES-1.2	esponse to High Containment Radiation Level)			
	D.	Stay in ES-1.2 a	nd implement FR-Z.3 concurrently			
	Distracter Analysis:					
	А. В. С. D.	Incorrect: ES1.2 Plausible: Incorrect: FR-I-3 Plausible: Incorrect: ES1. Plausible: Correct Plausible:	2 is the controlling procedure and not to be exited is a lower priority than FR-Z-3 2 is controlling procedure			
	LEVEL: SRO					
	KA : W/E16 EA2.1 (4.3/4.4)					
	SOUR	CE: NEW				
	LEVEI	- OF KNOWLEDG	BE: Analysis			

Ques_1042.doc

·----

*

,*

AUTHOR: CWS

-

_..

ç.

.

LESSON: OP-MC-EP-F0

OBJECTIVES: OP-MC-EP-F0 Obj 3

REFERENCES: OP-MC-EP-F0 page 17 OMP 4-3 page 19

Ques_1042.doc

	Bank Question: 1053	Answer: A			
1 Pt(s)	Given the following conditions on Unit 1:				
	 Mode 3 NC System is at 1700 ps In process of cooling dov Safety Injection has occ NC Pressure going dow Containment pressure g 	sig and 450 degrees wn and depressurizing the NC System urred n in an uncontrolled manner oing up in uncontrolled manner			
	Which one of the following describes the proper procedures to mitigate the above?				
	A. Enter AP/35 (ECCS Ac go to E-0 (Reactor Trip	<i>tuation During Plant Shutdown</i>) and then or Safety Injection).			
	B. Enter E-0 and then go	to AP/35			
	C. Enter AP/35 and then g	jo to AP/34 (Shutdown LOCA)			
	D. Enter E-0 and then go <i>Coolant</i>).	to E-1 (Loss of Reactor or Secondary			
	Distracter Analysis:				
	A. Correct: Plausible: B. Incorrect: Plausible:				
	C. Incorrect: Plausible				
	• D. Incorrect Plausible:				
	LEVEL: SRO				
	KA : 006 G 2.4.4 (4.0/4.3)				
	SOURCE: NEW				
	LEVEL OF KNOWLEDGE: ANALYSIS				
	AUTHOR: CWS				
	LESSON: - AP/1/5500/35 Back	ground Document			

•

÷.

OBJECTIVES: OP-MC-AP-35 Obj. 1 MC-AP-34 Obj. 1

1

REFERENCES: AP/1/5500/35 Background Document pages 2-4 AP/1/A/5500/35 page 3 AP/34 Backdground Document page 2

	Bank	Question: 1054	Answer: C		
Pt	Given	the following conditions or	n Unit 1:		
	• • • • •	Unit 1 is at 100% power. 'A', 'B', and 'C' VL AHU a 'A' and 'C' VL AHUs have Attempts to start 'D' VL A Average temperature in I been 105 degrees. Maintenance indicated it Containment lower comp steady.	are running e tripped and will not restart HU were unsuccessful ower containment for past 365 day will take two days to repair the VL artment temperature is 126 degre	ys has AHUs es and	
	Which Specif	one (1) of the following de fication actions to address	escribes the required Technical the high containment temperature	?	
		Reference	Provided Tech Spec 3.6.5		
	Α.	Restore temperature to	within limits in 8 hours.		
	В.	Reduce temperature to	<125 degrees in 72 hours.		
	C.	No action is required to temperature.	address high containment		
	D.	Be in Mode 3 in 14 hou	rs.		
	Distracter Analysis:.				
	А. В. С. D.	Incorrect: Plausible: Incorrect: Plausible: Correct: Plausible: Incorrect Plausible:			
	LEVEL: SRO				
	KA : 8	SYS 022 G2.1.12 (2.9/4.0)			
	SOUF	RCE: NEW			

Ques_1054.doc

ø

¥

AUTHOR: CWS

.

LESSON: OP-MC-CNT-VUL

OBJECTIVES: OP-MC-CNT-VUL Obj. 11

REFERENCES: OP-MC-CNT-VUL pages 15 & 17 Tech Spec 3.6.5

Ques_1054.doc

Bank	Question: 1055	Answer: D	
Giver	n the following condition	s on Unit 1:	
	In Mode 5 cooling do The '1B' ND pump tr The '1A' ND pump h <i>ND or ND System</i> Lo NC temperature befor NC temperature has AP/1/A/5500/19 (Los	own for a refueling outage. Tipped due to an electrical fault. as been started per AP/1/A/5500/19 (<i>Loss</i> eakage) Encl. 14 (<i>Startup of ND Pumps</i>) ore the pump trip was 150 degrees increased to 207 degrees. as of ND) is in effect	
The S	SRO instructs the RO to	cooldown to the pre-event temperature.	
Whic minin	h one (1) of the followin num flow rate allowed to	g describes the maximum cooldown rate a cooldown?	
	REFERENC	ES PROVIDED	
	AP/1/A/55	00/19 Encl 14	
	DATA BOOK E	ncl. 4.3, curve 1.6b	
А.	Maximum cooldowi rate of 1500 gpm.	n rate of 50 degrees/hr and minimum flo	
В.	Maximum cooldowi rate of 1000 gpm	n rate of 75 degrees/hr and minimum flo	
C.	Maximum cooldowi rate of 2000 gpm.	n rate of 50 degrees/hr and minimum flo	
D.	Maximum cooldowi rate of 1500 gpm.	n rate of 75 degrees/hr and minimum flo	
Distracter Analysis:			
А.	Incorrect:		
	Plausible:		
В.	Incorrect:		
C	Plausible:		
.	Plausible:		
D.	Correct		
	Plausible:		
LEVE	EL: SRO		
	Giver Giver The S Whic minin A. B. C. D. Distr A. B. C. D.	Given the following condition In Mode 5 cooling dd The '1B' ND pump th The '1A' ND pump th ND or ND System Ld NC temperature befa NC temperature befa NC temperature has AP/1/A/5500/19 (Los The SRO instructs the RO to Which one (1) of the following minimum flow rate allowed to <i>REFERENC AP/1/A/55 DATA BOOK E</i> A. Maximum cooldowing rate of 1500 gpm. B. Maximum cooldowing rate of 1000 gpm. C. Maximum cooldowing rate of 1000 gpm. D. Maximum cooldowing rate of 1500 gpm. D. Maximum cooldowing rate of 1500 gpm. C. Maximum cooldowing rate of 1500 gpm. D. Maximum cooldowing rate of 1500 gpm. C. Maximum cooldowing rate of 1500 gpm. D. Correct: Plausible: D. Correct: Plausible: D. Correct: Plausible: D. Correct: Plausible: LEVEL: SRO	

Ques_1055.doc

SOURCE: NEW

•

*

LEVEL OF KNOWLEDGE: Analysis

AUTHOR: CWS

LESSON: OP-MC-AP-19

OBJECTIVES: OP-MC-AP-19 Obj 2

REFERENCES: AP-19 Background Document Enclosure 14 AP/1A/5500019 Enclosure 14 Provided DATA Book Enclosure 4.3 Provided

Ques_1055.doc

SUMMARY FOR ENCLOSURE 14, STARTUP OF ND PUMPS

This enclosure attempts to get a ND Pump started under various potential plant conditions. If a loss of VI has occurred, then numerous compensatory actions are needed and rather than complicate this enclosure, a kickout is provided to a separate enclosure for that plant condition.

A couple of system checks are performed prior to starting an ND train. ND-35 is check closed to prevent an inadvertent inventory loss (may have been opened as a makeup option). If open, an operator is dispatched to stand by so it can be closed prior to pump start.

A step is provided to leave ND L/D in service if the NC System is solid. The setpoint for checking if NC solid is 96% Pzr level, which includes 4% instrument error. Note there still may be some volume above just full indicated level (dome of Pzr), but that amount can't be assumed to be available.

If SI has occurred then control of RN modulating valves is reestablished. Then direction is provided to go the section of the enclosure to start the desired ND Pump.

In preparation for starting a ND Pump, the local pump discharge is setup 2 turns open to prevent water hammer concerns. Pump support conditions are established (RN & KC) and ND-35 is closed at this time, if required. ND suction from the loop is aligned, and ND flow bypassing the ND Hx is aligned. The ND recirc value is de-energized prior to starting pump to prevent any air that may be in the ND Hx from returning to the pump suction.

Several precautions are taken on ND Pump startup addressing voiding concerns. If air entrainment or voiding has occurred, a cue is provided to continue makeup as required, considering void collapse may occur after pump start. Also, a check is made for subcooling. If subcooling can't be restored, FW-27A is aligned open in conjunction with the loop suction valves until after pump start. Once NC System subcooling restored (should happen quickly with the cool FWST water mixed in), FW-27A is closed.

After the ND Pump is started, ND flow is carefully established using ND Pump discharge valve and ND-34, and then flow through the ND Hx is carefully established to maintain NC temperature (considering NC System cooldown limits). A cue is also provided to secure "feed & bleed" when less than 200°F, if it had been established. Finally, a cue is provided to flush the idle ND train if air entrainment may have occurred on it.

Ques_1055.doc

	Bank		
1 Pt.	As a result of thunderstorms Unit 2 has experienced a Loss of Offsite Power and Reactor trip. E-0 (<i>Reactor Trip or Safety Injection</i>) was implemented and the crew has transitioned to ES-0.1 (<i>Reactor Trip Response</i>).		
	The S	SRO asks the RO to check NC temperatures.	
	Whick of the	h one (1) of the following would the RO use to describe the response NC system?	
	Α.	NC Tave STABLE or trending to 557 degrees	
	В.	NC T hots STABLE or trending to 553 degrees	
	C.	NC T colds STABLE or trending to 557 degrees	
	D.	NC Tave STABLE or trending to 553 degrees.	
	Distra	acter Analysis: The reactor coolant pumps have tripped in this scenario. Tave is only checked if the NC pumps are on. Thot	
	А. В.	circulation. T colds will go to 557. 553 degrees is a commonXy used number for steam dump P-12. Incorrect: Plausible: Incorrect: Plausible:	
	А. В. С. D.	circulation. T colds will go to 557. 553 degrees is a commonXy used number for steam dump P-12. Incorrect: Plausible: Incorrect: Plausible: Correct: Plausible: Incorrect Plausible: Incorrect Plausible: Plausible: Incorrect Plausible:	
	A. B. C. D. LEVE	circulation. T colds will go to 557. 553 degrees is a commonXy used number for steam dump P-12. Incorrect: Plausible: Incorrect: Plausible: Correct: Plausible: Incorrect Plausible: Incorrect Plausible: Incorrect Plausible:	
	A. B. C. D. LEVE KA: (circulation. T colds will go to 557. 553 degrees is a commonXy used number for steam dump P-12. Incorrect: Plausible: Incorrect: Plausible: Correct: Plausible: Incorrect Plausible: Incorrect Plausible: SRO 00056 AA2.32 (4.3/4.3)	
	A. B. C. D. LEVE KA: (SOUR	circulation. T colds will go to 557. 553 degrees is a commonXy used number for steam dump P-12. Incorrect: Plausible: Incorrect: Plausible: Correct: Plausible: Incorrect Plausible: Incorrect Plausible: EL: SRO 00056 AA2.32 (4.3/4.3) RCE: NEW	
	A. B. C. D. LEVE KA: (SOUR	circulation. T colds will go to 557. 553 degrees is a commonXy used number for steam dump P-12. Incorrect: Plausible: Incorrect: Plausible: Correct: Plausible: Incorrect Plausible: EL: SRO 00056 AA2.32 (4.3/4.3) RCE: NEW EL OF KNOWLEDGE: Comprehension	
	A. B. C. D. LEVE KA: (SOUR LEVE	circulation. T colds will go to 557. 553 degrees is a commonXy used number for steam dump P-12. Incorrect: Plausible: Incorrect: Plausible: Correct: Plausible: Incorrect Plausible: EL: SRO 00056 AA2.32 (4.3/4.3) RCE: NEW EL OF KNOWLEDGE: Comprehension HOR: CWS	

-

....

OBJECTIVES:

4

•

REFERENCES: AP/09 Background Document pages 3 & 4 EP/1/A/5000/ES-0.1 page 3

Ques_1057.doc

	Bank	Question: 1058	Answer: B			
1 Pt.	Radwaste is in the process of releasing WGDT 'A'. 1EMF -36 L is inoperable due to PM. Trip 2 is received on 0EMF-50 (<i>Waste Gas</i> <i>Discharge</i>). The gaseous waste release is secured as a result of 1WG-160 closing. Radwaste calls the control room SRO and reports 0EMF-50 has been purged and is ready to reinitiate the release.					
	Which SRO	n one (1) of the following de ?	scribes the actions of the control room			
	Α.	The SRO can authorize re-sampling.	up to two (2) restarts without			
	В.	The SRO has Radwaste GWR paperwork, and g	terminate the release and existing enerate new paperwork.			
	C.	The SRO can authorize	one (1) restart without re-sampling.			
	D.	The SRO can authorize 0EMF-50, restart releas (4) hours during release	Radwaste to jumper control actions of and take grab samples once per four a.			
	Distr	Distracter Analysis:.				
	Α.	Incorrect: Would be cor Plausible:	rect if both EMF 36 and 50 were operable			
	B.	Correct: Plausible:				
	C.	Incorrect: Plausible:				
	D.	Incorrect Plausible:				
	LEVEL: SRO					
	KA : 00060 G 2.3.8 (2.3/3.2)					
;	SOURCE: NEW					
	LEVEL OF KNOWLEDGE: Comprehension					
	AUTHOR: CWS					
	LESS	SON: OP-MC-WE-RGR				
	OBJI	OBJECTIVES: OP-MC-WE-RGR Obj 5				

i,

e

REFERENCES: OP-MC-WE-RGR page 13

....

Ques_1058.doc

ć

÷

	Bank Question: 1060 Answer: C
1 Pt.	 Given the following conditions on Unit 1: SGTR in the '1A' S/G E-0 (<i>Reactor Trip or Safety Injection</i>) complete E-3 (<i>Steam Generator Tube Rupture</i>) implemented. Cooldown is secured due to operator exceeding Main Steam Isolation set point.
	Which one (1) of the following describes how the operator continues to cooldown?
	A. Go to Bypass Interlock on steam dumps and continue cooldown with steam dumps.
	B. Reset Main Steam Isolation, open MSIVs and continue cooldown with steam dumps.
	C. Reset Main Steam Isolation and PORVs and continue cooldown using PORVs in manual.
	D. Reset Main Steam Isolation and PORVs and continue cooldown using PORVs in automatic.
	 Distracter Analysis:.
	A. Incorrect:
	Plausible: B. Incorrect: Plausible:
	C. Correct: Plausible:
	D. Incorrect Plausible:
	LEVEL: SRO
	KA : 0041 G2.4.20 (3.3/4.0)
	SOURCE: NEW
	LEVEL OF KNOWLEDGE: Memory

Ques_1060.doc

*

``

AUTHOR: CWS

_

.....

-

LESSON: OP-MC-EP-E3

OBJECTIVES: OP-MC-EP-E3 Obj 4

REFERENCES: OP-MC-EP-E3 pages 75,77,79 EP/1A/5500/E-3 page 19-21

Ques_1060.doc

1 Pt. Given the following:

5

- Both Units operating at 100% power.
- 'A' train RN is operating on both units.
- Operations Test Group is performing 'B' train RN valve stroke timing.
- SRO is instructed to evaluate the consequences of stroking 0RN-284B (*Train 1B and 2B Discharge to RC*)

Which one of the following describes the consequences of allowing the technician to test this valve?

No consequences due to 'A' Train RN running on both units. Α. Closing 0RN-284B will isolate the RN non-essential header Β. return from Unit 2. Closing 0RN-284B will isolate the RN non-essential header C. return from Unit 1. Closing 0RN-284B will isolate RV pump discharge. D. Distracter Analysis: Α. Incorrect: Plausible: B. Correct: Plausible: Incorrect: C. Plausible: D. Incorrect Plausible:

LEVEL: SRO

KA: G 2.2.3 (3.1/3.3)

SOURCE: NEW

LEVEL OF KNOWLEDGE: Comprehension

AUTHOR: CWS

LESSON: OP-MC-PSS-RN

OBJECTIVES: OP-MC-PSS.RN Obj. 8

REFERENCES: OP-MC-PSS-RN page 67

Ques_1065.doc

;

	Bank Question: 1067	Answer: A			
1 Pt.	Which one of the following describe Safety Functions (CSF)?	s the bases for prioritizing Critical			
	A. The CSFs are prioritized to boundaries that protect th radiation.	o address challenges to the e general public from exposure to			
	B. The CSFs are prioritized to that are described in the L	o address design bases accidents ISFAR.			
	C. The CSFs are prioritized to response procedure is im	o ensure the proper optimal plemented.			
	D. The CSFs are prioritized to that would affect operatio equipment.	o address challenges to parameters n of Engineered Safeguard Features			
	Distracter Analysis:.				
	A. Correct: Plausible:				
	B. Incorrect: Plausible:				
	C. Incorrect: Plausible:				
	D. Incorrect Plausible:				
	LEVEL: SRO				
	KA : G 2.4.22 (3/0/4.0)				
	SOURCE: NEW				
	LEVEL OF KNOWLEDGE: Memor	У			
	AUTHOR: CWS				
	LESSON: OP-MC- EP-INTRO				
	OBJECTIVES: OP-MC-EP-E-1 Ob	j. 1 & 3			

۲

<u>ي</u>۲

- - ----

Ques_1067.doc

______. ___

c

à

-

1 Pt(s)	After Channel 1 7300 Process Control Cabinet Channel Operability Test
	was completed the Unit 1 Pressurizer level master malfunctions causing it to
	demand full output while in automatic.

Which one of the following statements correctly describes the basis for the McGuire limit on flow?

- A. Letdown flow rates in excess of 135 gpm are limited to ensure proper demineralizer operation and adhere to the design limits of the letdown piping.
- B. Letdown flow rates in excess of 120 gpm exceed the design limits of the letdown orifice valves and induce resonance vibration.
- C. Charging flow rates in excess of 100 gpm during normal operation can induce vibration in the regenerative heat exchanger tubes.
- **D.** Charging flow rates between 65 gpm and 100 gpm total charging flow will cause flashing in the regenerative heat exchanger.

Distracter Analysis:

- A. Inorrect:
- B. Incorrect:
- Plausible C. Correct:
 - Plausible
- D. Incorrect: Plausible:

Level: SRO

KA: APE 028 AA2.09 (2.9/3.2)

Lesson Plan Objective: OP-MC-PS-NV Obj. 13

Source: New

Level of knowledge: comprehension

References: 1. OP-MC-PS-NV pages 81 & 83 1 Pt(s) As an SRO working on a 'Complex Maintenance Plan' you are asked to evaluate four possible work teams who must repair filter housing in a 1500 mRem/hr radiation field.

Which one of the following work teams would maintain station ALARA?

- A. A qualified male worker who has previously performed this task. He can complete this job in 20 minutes. This worker has exceeded his 'Alert' level for exposure and will require a dose extension.
- B. Two male workers who are qualified to perform the task. Together they can perform the task in 15 minutes. Both workers have already accumulated 325 mRem this year.
- C. A team of a female worker who is qualified to perform the task and a male worker who needs to qualify to this task. The female is a declared pregnant worker. The team will need 15 minutes to complete the task. The female has no dose and the male worker has 200 mRem for the year.
- D. A team of a male and female both are qualified to the task but will take 20 minutes to complete the task. Each has less than 100 mRem this year.

؞؞؞٤٥٤ڹ _ڮ پيند ٢٥٥ ع مين مـ ٢٥٥ ع مين ني ع مي مين ٢٥٥ ني پين ٢٥٥ ني پين ما ٢٥٥ ع مين مي مع مي مين ۲۵ مي پين ۲ من ۲۵ مي پين

Distracter Analysis:

- A. Correct: 500 mR total.
- **B.** Incorrect: 750 per mrem total Plausible
 - C. Incorrect: Declared pregnant worker. Plausible:
 - **D.** Incorrect: 1000 mrem total

Level: SRO

KA: G2.3.2 (2.5/2.9)

Lesson Plan Objective: RAD RP Ojb. 135

Source: New

Level of knowledge: comprehension

Ques_1072.doc

References: 1. OP-MC-RAD-RP page 73

.

Ques_1072.doc

<u> </u>	Bank Question: 1073	Answer: A
1 Pt(s)	The following conditions exist onReactor power is 100%	Unit 1:
	• 1A CA Pump is running with 1 Control) and 1CA-56 (1A CA for post maintenance testing.	ICA-60A (1A CA Pump Disch to 1A S/G Pump Disch to 1B S/G Control) closed
	 N/R level in 1B S/G increases Valve) failing open. 	to 84% due to 1CF-23 (1B S/G Control
	Which one of the following statem the CA system to the above condit	ents correctly describes the response of ions?
	A. 1A CA Pump remains ru 1B CA pump auto starts 1CA-60A and 1CA-56A f 1CA-44B (1B CA Pump I (1B CA Pump to Disch to Depressing the MD CA M pushbutton will cause 1C	nning ail open Disch to 1C S/G Control) and 1CA-40B 1D S/G Control) do not reposition. Iodulating Valve Reset Train 'A' A-60A and 1CA-56A to close.
	B. 1A CA Pump remains ru 1B CA pump auto starts 1CA-60A and 1CA-56A r 1CA-44B and 1CA-40B f Depressing the MD CA M pushbutton will cause 1C	nning emain closed. ail closed. Iodulating Valve Reset Train 'A' A-60A and 1CA-56A to open
	C. 1A CA Pump trips 1B CA pump remains off 1CA-60A and 1CA-56A r 1CA-44B and 1CA-40B Depressing the MD CA M pushbutton will cause 1C	emain closed. do not change position. Iodulating Valve Reset Train 'A' A-60A and 1CA-56A to open.
	D. 1A CA Pump trips 1B CA Pump remains off 1CA-60A and 1CA-56A 1CA-44B and 1CA-40B f Depressing the MD CA M pushbutton will cause 1C	fail open fail open. Iodulating Valve Reset Train 'A' A-60A and 1CA-56A to close.

.

. .

Distracter Analysis:

A. Correct: .

2

E.

- **B.** Incorrect:
- Plausible:.
- C. Incorrect: Plausible
- D. Incorrect: Plausible:.

Level: SRO

KA: APE 054 AA204 (4.2/4.3)

Lesson Plan Objective: CF-CA Obj. #4, OP-MC-ECC-ISE Obj. #13)

Source: New

Level of knowledge: comprehension

References: 1. OP-MC-CF-CA page 13, 2. OP-MC-ECC-ISE page 33

Ques_1073.doc