

Table 3.3.1-1 (page 3 of 7)
Reactor Trip System Instrumentation

FUNCTION	APPLICABLE MODES OR OTHER SPECIFIED CONDITIONS	REQUIRED CHANNELS	CONDITIONS	SURVEILLANCE REQUIREMENTS	ALLOWABLE VALUE	NOMINAL ^(a) TRIP SETPOINT
10. Reactor Coolant Flow—Low	1 ^(g)	3 per loop	M	SR 3.3.1.1 SR 3.3.1.7 SR 3.3.1.10 SR 3.3.1.16	≥ 89.8% of measured loop flow	90% of measured loop flow
11. Reactor Coolant Pump (RCP) Breaker Position	1 ^(g)	1 per RCP	M	SR 3.3.1.14	NA	NA
12. Undervoltage RCPs	1 ^(g)	2 per bus	M	SR 3.3.1.9 SR 3.3.1.10 SR 3.3.1.16	≥ 7877 V each bus	8050 V each bus
13. Underfrequency RCPs	1 ^(g)	3 per bus	M	SR 3.3.1.9 SR 3.3.1.10 SR 3.3.1.16	≥ 53.9 Hz each bus	54.0 Hz each bus
14. a. Steam Generator (SG) Water Level—Low Low	1,2	3 per SG	E	SR 3.3.1.1 SR 3.3.1.7 SR 3.3.1.10 SR 3.3.1.16	≥ 7.0%	7.2%
b. SG Water Level - Low Low Trip Time Delay (TTD)	1,2	4	X	SR 3.3.1.7 SR 3.3.1.10	TTD ≤ 1.01 TD (Note 3) for RCS loop ΔT variable input ≤ 50.7% RTP and TTD=0 for RCS loop ΔT variable input > 50.7% RTP	TTD ≤ TD (Note 3) for RCS loop ΔT variable input 50% RTP TTD=0 for RCS loop ΔT variable input 50% RTP
16. Not used						

(continued)

- (a) A channel is OPERABLE with an actual Trip Setpoint value outside its calibration tolerance band provided the Trip Setpoint value is conservative with respect to its associated Allowable Value and the channel is re-adjusted to within the established calibration tolerance band of the Nominal Trip Setpoint. A Trip Setpoint may be set more conservative than the Nominal Trip Setpoint as necessary in response to plant conditions.
- (g) Above the P-7 (Low Power Reactor Trips Block) interlock.