

August 27, 2003

MEMORANDUM TO: James W. Clifford, Chief, Section 2
Project Directorate I
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

FROM: Victor Nerses, Sr. Project Manager, Section 2 */RA/*
Project Directorate I
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

SUBJECT: SEABROOK STATION, UNIT NO. 1, FACSIMILE TRANSMISSION,
DRAFT REQUEST FOR ADDITIONAL INFORMATION (TAC NO.
MB6611 AND MB6612)

The attached draft RAI was transmitted by facsimile on August 27, 2003, to Mr. Jim Connolly of FPL Energy Seabrook, LLC (the licensee). This draft RAI was transmitted to facilitate the technical review being conducted by NRR and to support a conference call with the licensee to discuss the RAI. The RAI was related to the licensee's October 11, 2002, submittals concerning changes to Technical Specifications associated with core offload decay time and containment penetrations. Review of the RAI would allow the licensee to determine and agree upon a schedule to respond to the RAI. This memorandum and the attachment do not convey or represent an NRC staff position regarding the licensee's request.

Docket No. 50-443

Attachment: Draft RAI

August 27, 2003

MEMORANDUM TO: James W. Clifford, Chief, Section 2
Project Directorate I
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

FROM: Victor Nerses, Sr. Project Manager, Section 2 */RA/*
Project Directorate I
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

SUBJECT: SEABROOK STATION, UNIT NO. 1, FACSIMILE TRANSMISSION,
DRAFT REQUEST FOR ADDITIONAL INFORMATION (TAC NO.
MB6611 AND MB6612)

The attached draft RAI was transmitted by facsimile on August 27, 2003, to Mr. Jim Connolly of FPL Energy Seabrook, LLC (the licensee). This draft RAI was transmitted to facilitate the technical review being conducted by NRR and to support a conference call with the licensee to discuss the RAI. The RAI was related to the licensee's October 11, 2002, submittals concerning changes to Technical Specifications associated with core offload decay time and containment penetrations. Review of the RAI would allow the licensee to determine and agree upon a schedule to respond to the RAI. This memorandum and the attachment do not convey or represent an NRC staff position regarding the licensee's request.

Docket No. 50-443

Attachment: Draft RAI

DISTRIBUTION

PUBLIC

J. Clifford V. Nerses L. Brown M. Hart PDI-2 Reading

Accession Number: ML032390693

OFFICE	PDI-2/PM	SPSB/SC
NAME	VNerses	RDennig
DATE	8/27/03	8/27/03

OFFICIAL RECORD COPY

DRAFT

REQUEST FOR ADDITIONAL INFORMATION
BY THE OFFICE OF NUCLEAR REACTOR REGULATION
FACILITY OPERATING LICENSE NO. NPF-86
FPL ENERGY SEABROOK, LLC
SEABROOK STATION
DOCKET NO. 50-443
TAC NO. MB6611 AND MB6612

In your submittals dated October 11, 2002, as supplemented by letters dated July 16, 2003, July 17, 2003, and August 18, 2003 you take credit for two separate control room air intakes. It appears that west air intake is not shielded from missiles. Please provide adequate information to conclude that the west air intake meets the requirements set forth in General Design Criteria 2 and 4.