

LIC-03-0122 Attachment 4

Calorimetric Uncertainty Evaluation Non-Proprietary Version

TABLE OF CONTENTS

<u>Section & Title</u>	<u>Page</u>
TITLE PAGE	1
RECORD OF REVISIONS	3
TABLE OF CONTENTS	10
1.0 <u>PURPOSE</u>	11
2.0 <u>REFERENCES</u>	12
3.0 <u>ASSUMPTIONS AND GIVEN CONDITIONS</u>	13
4.0 <u>METHOD OF CALCULATION</u>	14
5.0 <u>BODY OF CALCULATION</u>	23
6.0 <u>CONCLUSION</u>	31

ATTACHMENTS:

1. Calorimetric Variables
2. XC105 Nominal data
3. Steam Generator Moisture Carryover Test Results, CE-18074-2087
4. Data Input for Section 5.4
5. Independent Check of Calculations

1.0 PURPOSE

This analysis determines the overall calorimetric uncertainty associated with plant computer application XC105. The analysis accounts for the instrument uncertainties associated with the independent variables that have the largest impact on the calculation of calorimetric power. These variables are:

- Feedwater Flow
- Feedwater Temperature
- Steam Generator Pressure
- Steam Generator Moisture Carryover
- Steam Generator Blowdown Flow
- Steam Generator Blowdown Temperature

This analysis combines the individual instrument uncertainties associated with the independent variables to determine the overall calorimetric uncertainty. The individual contributions to the power uncertainty are combined using a statistical summation to determine the total power measurement uncertainty. This approach is consistent with the methods described in ANSI/ISA-67.04.01-2000, "Setpoints for Nuclear Safety-Related Instrumentation" (Reference 2.3)

This calculation is applicable for use with the CROSSFLOW ultrasonic feedwater flow measurement system.

2.0 REFERENCES

The following are references used in developing this document.

- 2.1 OPPD Production Engineering Division Procedure, "Calculation Preparation, Review and Approval", PED Quality Procedure QP-3, Revision 3, dated 4/8/94.
- 2.2 OPPD Production Engineering Division Standard, "Instrument Loop Uncertainty Setpoint / Tolerance Calculation Methodology" Document Number EEI-3.
- 2.3 ANSI/ISA-67.04.01-2000, "Setpoints for Nuclear Safety-Related Instrumentation"
- 2.4 FC06898, "Steam Generator Pressure and Feedwater Temperature Instrument Uncertainty Analysis", Rev.0
- 2.5 FC06907, "Steam Generator Blowdown Flow and Temperature Instrument Uncertainty Analysis" Rev.0
- 2.6 Basic Engineering Data Collection and Analysis, Vardeman/Jobe.
- 2.7 "Steam Generator Moisture Carryover Test Results", CE-18074-2087 dated August 14,1986.
- 2.8 Calculation FC06091, "Uncertainties Report for Fort Calhoun Station Secondary Calorimetric".
- 2.9 "Applied Numerical Analysis", Sixth Edition, Curtis F. Gerald and Patrick O. Wheatley
- 2.10 "Improved Flow Measurement Accuracy using Crossflow Ultrasonic Flow Measurement Technology", CENPD-397-P-A Rev.01.
- 2.11 "Upgraded ERFCS Functional Requirements Specification", Rev.1.02.20.02.
- 2.12 ASME Steam Tables

3.0 ASSUMPTIONS AND GIVEN CONDITIONS

The following assumptions and given conditions (A&GC) are used in development of this calculation.

[

]

4.0 METHOD OF CALCULATION

[

]

4.1 ENERGY AND FLOW EQUATIONS

[

]

4.1.1 STEAM GENERATOR ENERGY EQUATION (XC101/XC102)

[

4.1.2 STEAM GENERATOR FEEDWATER FLOW EQUATION (XC088/XC089)

[

]

]

4.1.3 STEAM GENERATOR BLOWDOWN FLOW EQUATION (XC086/XC087)

[

]

4.2 CALCULATION OF CALORIMETRIC UNCERTAINTIES

[

]

4.2.1 INSTRUMENT UNCERTAINTIES

[

]

4.2.2 WEIGHTING FACTORS

[

]

[

]

4.2.3 COMBINING ERROR TERMS

[

]

4.3 ONE SIDED 95% CONFIDENCE INTERVAL

{

}

4.4 NSS ENERGY LOSS AND ELECTRICAL ENERGY WEIGHTING FACTORS

[

]

5.2 EQUATIONS										
[

5.3.12									

5.5 NSSS ENERGY LOSS AND ELECTRICAL ENERGY WEIGHTING FACTORS

5.5.1

5.5.2

6.0


CONCLUSIONS

This calculation determined the calorimetric uncertainty based on an upgrade of feedwater flow and temperature instrumentation which is used for the XC105 calculation. [

Allowable Uprate: $2\% - 0.3506\% = 1.6494\%$]

Based on this an uprate of 1.60% is acceptable and enveloped by this analysis.

ATTACHMENT 1



Block Diagram of XC105 Calculation

ATTACHMENT 2

35/60

Reactor Power


XC105 Values		XC105 Inputs		
Time Interval	MW thermal	Parameter	Value	Units
Real Time	1502.87	S/G 2A Blowdown Temperature	499.25	°F T1391
2 Minute Average	1497.52	S/G 2A Blowdown Flow	4.54	" water F1392
5 Minute Average	1497.87	S/G 2A Blowdown Flow	25,555	lb/hr F1392C
10 Minute Average	1498.23	S/G 2B Blowdown Temperature	497.25	°F T1393
30 Minute Average	1498.10	S/G Blowdown Flow	4.48	" water F1394
1 Hour Average	1498.24	S/G Blowdown Flow	25,406	lb/hr F1394C
2 Hour Average	1498.29	S/G 2A Feedwater Temperature	442.31	°F T1396
4 Hour Average	1498.48	S/G 2A Feedwater Flow	359.00	" water F1395
8 Hour Average	1498.61	S/G 2A Feedwater Flow	3,315,690	lb/hr F1395C
		S/G 2B Feedwater Temperature	441.88	°F T1399
		S/G 2B Feedwater Flow	368.50	" water F1398
		S/G 2B Feedwater Flow	3,365,500	lb/hr F1398C
		Feedwater Pressure	1,001.56	psig P1141
		S/G 2A Pressure	817.19	psia P0902A
		Regen Heat Exchanger Temperature	403.70	°F T237
		Letdown Flow	34.00	gpm F212
		S/G 2B Pressure	807.81	psia P0905A
		Charging Pump Flow	38.73	gpm F236


ERF Display: XCF, MWT


[Return to Plant Information Page](#)

[Return to FCS Home Page](#)

ATTACHMENT 3










40/60




41/60







44/60



45/60



46/60



47/60




48/60

[



]

49/60



ATTACHMENT 4

51/60




ATTACHMENT 5


The following documents an independent check that was performed to verify the spreadsheet calculations made in this analysis.

[


]


54/60











59/60



60/60



LIC-03-0122 Attachment 5

Affidavit for Calorimetric Uncertainty Evaluation

I, Tim Leibel, depose and say that I am a Principal of PL Integrated Services LLC (PLIS), duly authorized to make this affidavit, and have reviewed or caused to have reviewed the information which is identified as proprietary and described below. I have personal knowledge of the criteria and procedures utilized by PLIS in designating information as a trade secret, privileged, or as confidential commercial or financial information.


This affidavit is submitted in conformance with the provisions of 10 CFR 2.790 of the Commission's regulations for withholding proprietary information. The information for which proprietary treatment is sought, and which document has been appropriately designated as proprietary, is *Calculation Number FC-6896-P "Secondary Calorimetric Uncertainty Analysis"*.

Pursuant to 10 CFR 2.790(b)(4) of the Commission's regulations, the following is furnished for consideration by the Commission in determining whether the information included in the document listed above should be withheld from public disclosure.

1. The information sought to be withheld from public disclosure is owned and has been held in confidence by PLIS. It consists of the information concerning the technical basis and implementation of a secondary calorimetric uncertainty analysis for the Fort Calhoun Station.
2. The information consists of methodologies for the development and implementation of a secondary calorimetric uncertainty analysis, the application of which results in substantial competitive advantage to PLIS.
3. The information is of a type customarily held in confidence by PLIS and not customarily disclosed to the public.
4. The information is being transmitted to the Commission in confidence under the provisions of 10 CFR 2.790 with the understanding that it is to be received in confidence by the Commission.
5. The information, to the best of my knowledge and belief, is not available in public sources, and any disclosure to third parties has been made pursuant to regulatory provisions or proprietary agreements that provide for maintenance of the information in confidence.
6. Public disclosure of the information is likely to cause substantial harm to the competitive position of PLIS because:
 - a. A similar product or service is provided by competitors.
 - b. PLIS has invested substantial funds and engineering resources in the development of this information. A competitor would have to undergo similar expense in generating equivalent information.
 - c. The information consists of the technical basis and implementation of a secondary calorimetric uncertainty analysis for the Fort Calhoun Station, the application of which provides PLIS a competitive economic advantage. The availability of such information to competitors would enable them to design their product or service to better compete with PLIS, take marketing or other actions to improve their product's position or impair the position of PLIS product, and avoid developing similar technical analysis in support of their processes, methods or apparatus.

Tim Leibel
Principal
PL Integrated Services LLC

Sworn to before me this 27th day of August 2003

 Notary Public

My commission expires: April 4, 2004

