

## CONTAINMENT SYSTEMS

### 3/4.6.2 DEPRESSURIZATION AND COOLING SYSTEMS

#### CONTAINMENT SPRAY SYSTEM

##### LIMITING CONDITION FOR OPERATION

---

3.6.2.1 Two independent Containment Spray Systems shall be OPERABLE with each Spray System capable of taking suction from the RWST\* and automatically transferring suction to the containment sump.

APPLICABILITY: MODES 1, 2, 3, and 4.

ACTION:

With one Containment Spray System inoperable, restore the inoperable Spray System to OPERABLE status within 72 hours or be in at least HOT STANDBY within the next 6 hours; restore the inoperable Spray System to OPERABLE status within the next 48 hours or be in COLD SHUTDOWN within the following 30 hours.

##### SURVEILLANCE REQUIREMENTS

---

4.6.2.1 Each Containment Spray System shall be demonstrated OPERABLE:

- a. At least once per 31 days by verifying that each valve (manual, power-operated, or automatic) in the flow path that is not locked, sealed, or otherwise secured in position is in its correct position;
- b. By verifying OPERABILITY of each pump when tested pursuant to Specification 4.0.5;
- c. At least once per 18 months during shutdown, by:
  - 1) Verifying that each automatic valve in the flow path actuates to its correct position on a Containment Pressure-Hi-3 test signal, and
  - 2) Verifying that each spray pump starts automatically on a Containment Pressure-Hi-3 test signal.
- d. At least once per 10 years by performing an air or smoke flow test through each spray header and verifying each spray nozzle is unobstructed.

\*In MODE 4, when the Residual Heat Removal System is in operation, an OPERABLE flow path is one that is capable of taking suction from the refueling water storage tank upon being manually realigned.

## PLANT SYSTEMS

### TURBINE CYCLE

#### AUXILIARY FEEDWATER SYSTEM

#### SURVEILLANCE REQUIREMENTS

---

##### 4.7.1.2.1a. (Continued)

- 3) Verifying that valves FW-156 and FW-163 are OPERABLE for alignment of the startup feedwater pump to the emergency feedwater header.
  - b. At least once per 92 days on a STAGGERED TEST BASIS by verifying the following pumps develop the required discharge pressure and flow as specified in the Technical Requirements Manual:
    - 1) The motor-driven emergency feedwater pump;
    - 2) The steam turbine-driven emergency feedwater pump when the secondary steam supply pressure is greater than 500 psig. The provisions of Specification 4.0.4 are not applicable for entry into MODE 3;
    - 3) The startup feedwater pump.
  - c. At least once per 18 months during shutdown by:
    - 1) Verifying that each automatic valve in the flow path actuates to its correct position upon receipt of an Emergency Feedwater System Actuation test signal;
    - 2) Verifying that each emergency feedwater pump starts as designed automatically upon receipt of an Emergency Feedwater Actuation System test signal;
    - 3) Verifying that with all manual actions, including power source and valve alignment, the startup feedwater pump starts within the required elapsed time; and
    - 4) Verifying that each emergency feedwater control valve closes on receipt of a high flow test signal.

3/4.7.1 TURBINE CYCLE (Continued)

3/4.7.1.2 AUXILIARY FEEDWATER SYSTEM

The OPERABILITY of the Auxiliary Feedwater System ensures that the Reactor Coolant System can be cooled down to less than 350°F from normal operating conditions in the event of a total loss-of-offsite power.

The electric motor-driven emergency feedwater pump is capable of delivering a total feedwater flow of 650 gpm at a pressure of 1221 psig to the entrance of the steam generators. The steam-driven emergency feedwater pump is capable of delivering a total feedwater flow of 650 gpm at a pressure of 1221 psig to the entrance of the steam generators. The startup feedwater pump serves as the third auxiliary feedwater pump and can be manually aligned to be powered from an emergency bus (Bus 5). The startup feedwater pump is capable of taking suction on the dedicated emergency feedwater volume of water in the condensate storage tank and delivering a total feedwater flow of in excess of 650 gpm at a pressure of 1221 psig to the entrance of the steam generator via either the main feedwater header or with manual alignment to the emergency feedwater flow path. This capacity is sufficient to ensure that adequate feedwater flow is available to remove decay heat and reduce the Reactor Coolant System temperature to less than 350°F when the Residual Heat Removal System may be placed into operation. An exception to the provisions of Specification 4.0.4 allows deferral of surveillance testing for the steam-driven emergency feedwater pump in order to allow entry into Mode 3 during startup. This is necessary since a steam supply pressure of greater than 500 psig is required to provide the requisite motive force to drive the steam-driven emergency feedwater pump. Once secondary steam supply pressure exceeds 500 psig, a 24-hour time limit is administratively imposed to complete the surveillance testing activities. The 24-hour time limit is in-keeping with Specification 4.0.3 requirements.

3/4.7.1.3 CONDENSATE STORAGE TANK

The OPERABILITY of the condensate storage tank with the minimum water volume ensures that sufficient water is available to cool the RCS to a temperature of 350°F. The OPERABILITY of the concrete enclosure ensures this availability of water following rupture of the condensate storage tank by a tornado generated missile. The contained water volume limit includes an allowance for water not usable because of tank discharge line location or other physical characteristics.

3/4.7.1.4 SPECIFIC ACTIVITY

The limitations on Secondary Coolant System specific activity ensure that the resultant offsite radiation dose will be limited to a small fraction of 10 CFR Part 100 dose guideline values in the event of a steam line rupture. This dose also includes the effects of a coincident 1 gpm reactor-to-secondary tube leak in the steam generator of the affected steam line. These values are consistent with the assumptions used in the safety analyses.

3/4.7.1.5 MAIN STEAM LINE ISOLATION VALVES

The OPERABILITY of the main steam line isolation valves ensures that no more than one steam generator will blow down in the event of a steam line rupture. This restriction is required to: (1) minimize the positive reactivity effects of the Reactor Coolant System cooldown associated with the blowdown, and (2) limit the pressure rise within containment in the event the steam line rupture occurs within containment. The OPERABILITY of the main steam isolation valves within the closure times of the Surveillance Requirements are consistent with the assumptions used in the safety analyses.