



444 South 16th Street Mall  
Omaha NE 68102-2247

September 10, 2003  
LIC-03-0121

U. S. Nuclear Regulatory Commission  
ATTN: Document Control Desk  
Washington, DC 20555-0001

Reference: Docket No. 50-285

**SUBJECT: August 2003 Monthly Operating Report (MOR)**

Pursuant to Fort Calhoun Station (FCS) Unit No. 1 Technical Specification 5.9.1.c, Omaha Public Power District (OPPD) submits the attached MOR for August 2003. No commitments are made to the NRC in this letter.

If you have any questions, please contact Mr. Erick Matzke at (402) 533-6855.

Sincerely,

R. T. Ridenoure  
Division Manager  
Nuclear Operations

RTR/EPM/epm

Attachment

- c: T. P. Gwynn, Acting NRC Regional Administrator, Region IV
- A. B. Wang, NRC Project Manager
- J. G. Kramer, NRC Senior Resident Inspector
- INPO Records Center

JE24

LIC-03-0121  
Attachment

### OPERATING DATA REPORT

**DOCKET NO.** 50-285  
**UNIT NAME** Fort Calhoun Station  
**DATE** September 2, 2003  
**COMPLETED BY** E. P. Matzke  
**TELEPHONE** (402) 533-6855

**REPORT PERIOD:** August 2003

**Design Electrical Rating (MWe-Net):** 478  
**Maximum Dependable Capacity (MWe-Net):** 478

|   | <u>MONTH</u>   | <u>YR-TO-DATE</u> | <u>CUMULATIVE</u> |
|---|----------------|-------------------|-------------------|
| <b>Number of Hours Reactor was Critical:</b>  | <u>744</u>     | <u>5,832</u>      | <u>213,074</u>    |
| <b>Number of Hours Generator was On-line:</b> | <u>744</u>     | <u>5,832</u>      | <u>211,760</u>    |
| <b>Unit Reserve Shutdown Hours:</b>           |                |                   |                   |
| <b>Net Electrical Energy Generated (MWh):</b> | <u>345,682</u> | <u>2,709,745</u>  | <u>91,725,775</u> |

#### UNIT SHUTDOWNS

| No. | Date<br>(yy/mm/dd) | Type<br>F: Forced<br>S: Scheduled | Duration<br>(Hours) | Reason <sup>1</sup> | Method of<br>Shutting<br>Down<br>Reactor <sup>2</sup> | Cause & Corrective<br>Action Comments |
|-----|--------------------|-----------------------------------|---------------------|---------------------|---|---------------------------------------|
|     |                    |                                   |                     |                     |   |                                       |

**(1) Reason:**

- A-Equipment Failure (Explain)
- B-Maintenance or Test
- C-Refueling
- D-Regulatory Restriction
- E-Operator Training/License Examination
- F-Administrative
- G-Operational Error (Explain)
- H-Other (Explain)

**(2) Method:**

- 1-Manual
- 2-Manual Trip/Scram
- 3-Automatic Trip/Scram
- 4-Continuation
- 5-Other (Explain)

#### OPERATIONS SUMMARY

The Fort Calhoun Station operated at a nominal 100% power for the month.