

FENOC

FirstEnergy Nuclear Operating Company

Perry Nuclear Power Plant
10 Center Road
P.O. Box 97
Perry, Ohio 44081

September 11, 2003
PY-CEI/NRR-2736L

United States Nuclear Regulatory Commission
Document Control Desk
Washington, D.C. 20555


Perry Nuclear Power Plant
Docket No. 50-440
License No. NPF-58
Monthly Operating Report

Ladies and Gentlemen:

Attached is the August 2003 Monthly Operating Report for Perry Unit 1. Page 1 is the Operating Data Report and page 2 is the Unit Shutdowns Report. This report is submitted in accordance with Technical Specification 5.6.4 and Generic Letter 97-02, "Revised Contents of the Monthly Operating Report."

If you have questions or require additional information, please contact Ms. Toni Phelps at (440) 280-7660.

Very truly yours,



Vernon K. Higaki
Manager - Regulatory Affairs

Attachment

cc: NRC Region III Administrator
NRC Project Manager
NRC Resident Inspector

IE24

OPERATING DATA REPORT

UNIT: Perry
DATE: 9/9/03

1. Docket: 50-440
2. Unit Name: Perry Nuclear Power Plant
3. Reporting Period: August 2003
4. Utility Contact: T. Phelps
5. Telephone: 440-280-7660
6. Design Electrical Rating (Net MWe): 1260
7. Maximum Dependable Capacity (Net MWe): 1235

	<u>This Month</u>	<u>Yr-to-Date</u>	<u>Cumulative</u>
8. Hours Reactor was Critical	<u>607.6</u>	<u>4,412.2</u>	<u>109,315.7</u>
9. Hours Generator On-Line	<u>568.9</u>	<u>4,312.0</u>	<u>106,582.3</u>
10. Unit Reserve Shutdown Hours	<u>0.0</u>	<u>0.0</u>	<u>0.0</u>
11. Net Electrical Energy (MWeH)	<u>678,084.0</u>	<u>5,030,572.0</u>	<u>121,605,783.0</u>

UNIT SHUTDOWNS REPORT MONTH – August 2003

DOCKET NO: 50-440
 NAME: Perry Nuclear Power Plant
 DATE: 9/9/03
 CONTACT: T. Phelps
 TELEPHONE: (440) 280-7660

No.	Date	Type 1	Duration Hours	Reason 2	Method 3	Cause and Corrective Action to Prevent Recurrence
03-02	8/14/03	F	175.1	H	3	The plant entered a forced shutdown on 8/14/03 at 1610 due to grid instability. The unit was synchronized to the grid on 8/21/03 at 2315.

SUMMARY: The Perry Plant shutdown on 8/14/03 due to grid instability. The unit was back on line 8/21/03 and remained on line through the end of the month.

1. TYPE:

F: Forced
 S: Scheduled

2. REASON:

A - Equipment Failure (explain)
 B - Maintenance or Test
 C - Refueling
 D - Regulatory
 E - Operating Training &
 License Examination
 F - Administrative
 G - Operational Error (explain)
 H - Other (explain)

3. METHOD:

1 - Manual
 2 - Manual Scram
 3 - Automatic Scram
 4 - Continuation
 5 - Other