

Dominion Nuclear Connecticut, Inc.
Millstone Power Station
Rope Ferry Road
Waterford, CT 06385



Dominion™

SEP 11 2003

Docket Nos. 50-245

50-336

50-423

B18982

RE: 10 CFR 50, Appendix E
10 CFR 50.47(b)(5)

U.S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, DC 20555

Millstone Power Station, Unit Nos. 1, 2 and 3
Revised Emergency Plan Procedure

In accordance with 10 CFR 50, Appendix E, Dominion Nuclear Connecticut, Inc. hereby notifies the U.S. Nuclear Regulatory Commission that the following Emergency Plan procedure has been implemented:

MP-26-EPI-FAP10-005, "Unit 1 Dose Calculation for Fuel Handling Accident,"
Major Revision 0, Minor Revision 1, transmitted via Attachment 1.

There are no regulatory commitments contained within this letter.

If you should have any questions concerning this submittal, please contact Mr. David W. Dodson at (860) 447-1791, extension 2346.

Very truly yours,

DOMINION NUCLEAR CONNECTICUT, INC.



J. Alan Price
Site Vice President - Millstone

cc: See next page

A045

Attachment (1)

cc: H. J. Miller, Region I Administrator (2 copies)
R. J. Conte, Chief, Operational Safety Branch, Region I

cc: w/o attachment

D. G. Holland, NRC Project Manager, Millstone Unit No. 1
J. R. Wray, NRC Inspector, Region I, Millstone Unit No. 1
R. B. Ennis, NRC Senior Project Manager, Millstone Unit No. 2
V. Nerses, NRC Senior Project Manager, Millstone Unit No. 3
Millstone Senior Resident Inspector

Docket Nos. 50-245

50-336

50-423

B18982

Attachment 1

Millstone Power Station, Unit Nos. 1, 2 and 3

**Emergency Procedures Implementing (EPI) Functional Administrative Procedure (FAP)
MP-26-EPI-FAP10-005, "Unit 1 Dose Calculation for Fuel Handling Accident"
Major Revision 0, Minor Revision 1**

8/6/03

Approval Date

8/12/03

Effective Date

Unit 1 Dose Calculation for Fuel Handling Accident**Control Room Data**

Obtain the following:

RM-SFPI-01
 Channel 1 (mR/hr)

RM-SFPI-01
 Channel 2 (mR/hr)

RM-SFPI-01
 Channel 3 (mR/hr)
Calculation

Perform the following:

$$1) \frac{\text{RM-SFPI-01 Channel 3 (mR/hr)*}}{\text{Factor A}} \times 2 = \text{\# Fuel Assemblies Damaged}$$

*Note: If Channel 3 is inoperative, the higher value between Channels 1 and 2 must be used and Factor A in step 1 changed from 2 to 0.25.

$$2) \frac{\text{\# Fuel Assemblies Damaged}}{\text{TEDE}} \times 0.2 = \text{mRem}$$

$$3) \frac{\text{\# Fuel Assemblies Damaged}}{\text{Skin}} \times 10 = \text{mRem}$$

4) Notify CR-DSEO of results.

NOTE

The basis for the rad monitor factors is for airborne radioactivity released from damaged fuel assemblies, not shine from exposed components.

Prepared by:

Signature

Print

Date/Time

Reviewed by:

Signature

Print

Date/Time