

September 23, 2003

LICENSEE: Rochester Gas & Electric (RG&E)
FACILITY: R.E. Ginna Nuclear Power Plant (Ginna)
SUBJECT: SUMMARY OF TELECOMMUNICATION WITH ROCHESTER GAS &
ELECTRIC CORPORATION (RG&E) TO DISCUSS SCOPING OF
STRUCTURES, SYSTEMS, AND COMPONENTS WITHIN THE SPENT FUEL
POOL AND FIREWATER SYSTEMS RELATIVE TO THE R.E. GINNA
NUCLEAR POWER PLANT LICENSE RENEWAL APPLICATION

On August 28, 2003, the NRC staff (the staff) and representatives from RG&E held a telecommunication conference call (telecon) to discuss potential open items relative to the safety evaluation report (SER) for Ginna. A list of telephone participants is shown in Enclosure 1. The following is a summary of the discussions:

Potential Open Item 2.3.3.3 -1:

Subject: Spent Fuel Pool (SFP) makeup water supply

This potential open item (OI) requested the applicant to justify the exclusion of the alternate SFP makeup water supply piping and valves from the scope of license renewal.

The applicant indicated that the piping and valves from the refueling water storage tank and chemical and volume control system holdup tanks to the SFP are not in scope of license renewal and are not part of the design basis for Ginna although they are described in the updated final safety analysis report (UFSAR). The applicant believes that SFP boiling due to a complete loss of SFP cooling is hypothetical and therefore, make-up to the SFP is not a requirement or assumed in their current licensing basis (CLB). The Ginna design basis is to maintain SFP water at less than 180°F.

The staff stated that a station black out (SBO) is part of the design basis and, as such, a complete loss of SFP cooling is part of the design basis of Ginna. The staff also indicated that, while a make-up to the pool would be necessary under unlikely conditions, those conditions are not hypothetical. For these reasons, the staff believed that a SFP make-up is credited in the applicant's licensing basis and therefore, meets license renewal scoping criterion 10 CFR 54.4 (a)(2).

September 23, 2003

Potential Open Item 2.3.3.6 -1:

Subject: Jockey Pumps

This potential OI requests the applicant to provide the basis for concluding that the firewater service water booster pump, piping, and valves back to the service water system are not in scope of license renewal.

The applicant stated that the firewater jockey pump, piping, and valves are not in scope of license renewal. The applicant stated that jockey pumps are second or third tier functions and provide level control to the firewater system.

The staff considered that the jockey pumps are part of the CLB. The staff explained to the applicant that Section 9.5.1.2.3.2 of the UFSAR states "A 15,000-gal pressure tank (10,000 gal of water) and a 120-gpm centrifugal jockey pump maintain system pressure at a minimum of 100 psig." In addition, Section 4.3.1.2 of the staff's SER governing Fire Protection for Ginna, issued February 14, 1979, states that, "A 15,000 gallon pressure tank (10,000 gallons of water) and a 120 gpm centrifugal jockey pump maintain system pressure at a minimum of 100 psig." The staff mentioned that Section 9.5.1 of the applicant's UFSAR states that the firewater system was designed in accordance with the standards of the National Fire Protection Association (NFPA). The NFPA standards recommends that a pressure maintenance system (which may include jockey pumps) be installed to prevent wear of the main fire water pumps. The staff believes that the UFSAR describes the pressure maintenance function as being provided by the tank and the jockey pumps.

The applicant has had an opportunity to review and comment on this summary.

/RA/

Jonathan Rowley, General Engineer
License Renewal Section A
License Renewal and Environmental Impacts Program
Division of Regulatory Improvement Programs
Office of Nuclear Reactor Regulation

Docket No.: 50-244

Enclosure: As stated

cc w/encl.: See next page

September 23, 2003

Potential Open Item 2.3.3.6 -1:

Subject: Jockey Pumps

This potential OI requests the applicant to provide the basis for concluding that the firewater service water booster pump, piping, and valves back to the service water system are not in scope of license renewal.

The applicant stated that the firewater jockey pump, piping, and valves are not in scope of license renewal. The applicant stated that jockey pumps are second or third tier functions and provide level control to the firewater system.

The staff considered that the jockey pumps are part of the CLB. The staff explained to the applicant that Section 9.5.1.2.3.2 of the UFSAR states "A 15,000-gal pressure tank (10,000 gal of water) and a 120-gpm centrifugal jockey pump maintain system pressure at a minimum of 100 psig." In addition, Section 4.3.1.2 of the staff's SER governing Fire Protection for Ginna, issued February 14, 1979, states that, "A 15,000 gallon pressure tank (10,000 gallons of water) and a 120 gpm centrifugal jockey pump maintain system pressure at a minimum of 100 psig." The staff mentioned that Section 9.5.1 of the applicant's UFSAR states that the firewater system was designed in accordance with the standards of the National Fire Protection Association (NFPA). The NFPA standards recommends that a pressure maintenance system (which may include jockey pumps) be installed to prevent wear of the main fire water pumps. The staff believes that the UFSAR describes the pressure maintenance function as being provided by the tank and the jockey pumps.

The applicant has had an opportunity to review and comment on this summary.

/RA/

Jonathan Rowley, General Engineer
License Renewal Section A
License Renewal and Environmental Impacts Program
Division of Regulatory Improvement Programs
Office of Nuclear Reactor Regulation

Docket No.: 50-244

Enclosure: As stated

cc w/encl.: See next page

Accession No: ML032670809

C:\ORPCheckout\FileNET\ML032670809.wpd

OFFICE	PM:RLEP:DRIP	LA:RLEP:DRIP	PM:RLEP:DRIP	SC:RLEP:DRIP
NAME	JRowley	MJenkins	RArrighi	SLee
DATE	09/16/03	09/16/03	09/16/03	09/23/03

DISTRIBUTION: Summary of Telecon with RG&E Re: Ginna SER with OIs, Dated: 09/23/03
Accession No: ML032670809

HARD COPY

RLEP RF
RArrighi
JRowley

E-MAIL:

PUBLIC
J. Craig
D. Matthews
F. Gillespie
C. Grimes
RidsNrrDe
E. Imbro
G. Bagchi
K. Manoly
W. Bateman
J. Calvo
R. Jenkins
P. Shemanski
H. Nieh
J. Fair
S. Black
B. Boger
D. Thatcher
R. Pettis
G. Galletti
C. Li
J. Moore
R. Weisman
M. Mayfield
A. Murphy
W. McDowell
S. Smith (srs3)
S. Duraiswamy
C. Munson
RLEP Staff

Y.I.Li

ATTENDANCE LIST
CONFERENCE CALL BETWEEN NRC AND
ROCHESTER GAS AND ELECTRIC COMPANY
August 28, 2003

<u>NAME</u>	<u>ORGANIZATION</u>
Russell Arrighi	NRR/DRIP/RLEP
Jonathan Rowley	NRR/DRIP/RLEP
Rani Franovich	NRR/DRIP/RLEP
Antonio Fernandez	OGC
Laura Zaccari	OGC
George Wrobel	RG&E
Dave Wilson	RG&E

R.E. Ginna Nuclear Power Plant

cc:

Kenneth Kolaczyk, Sr. Resident Inspector
R.E. Ginna Plant
U.S. Nuclear Regulatory Commission
1503 Lake Road
Ontario, NY 14519

Regional Administrator, Region I
U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406

Mr. William M. Flynn, President
New York State Energy, Research,
and Development Authority
17 Columbia Circle
Albany, NY 12203-6399

Charles Donaldson, Esquire
Assistant Attorney General
New York Department of Law
120 Broadway
New York, NY 10271

Daniel F. Stenger
Ballard Spahr Andrews & Ingersoll, LLP
601 13th Street, N.W., Suite 1000 South
Washington, DC 20005

Ms. Thelma Wideman, Director
Wayne County Emergency Management
Office
Wayne County Emergency Operations
Center
7336 Route 31
Lyons, NY 14489

Ms. Mary Louise Meisenzahl
Administrator, Monroe County
Office of Emergency Preparedness
1190 Scottsville Road, Suite 200
Rochester, NY 14624

Dr. Robert C. Mecredy
Vice President, Nuclear Operations
Rochester Gas and Electric Corporation
89 East Avenue
Rochester, NY 14649

Mr. Paul Eddy
New York State Department of
Public Service
3 Empire State Plaza, 10th Floor
Albany, NY 12223

Mr. Fred Emerson
Nuclear Energy Institute
1776 I Street, N.W., Suite 400
Washington, DC 20006-3708

George Wrobel
Manager, License Renewal
R.E.Ginna Nuclear Power Plant
1503 Lake Rd.
Ontario, NY 14519

Mr. David F. Wilson
R.E. Ginna Nuclear Power Plant
1503 Lake Rd.
Ontario, NY 14519