

3.5 EMERGENCY CORE COOLING SYSTEMS (ECCS)

3.5.2 ECCS – Operating

LCO 3.5.2 Two ECCS trains shall be OPERABLE.

-----NOTE-----
In MODE 3, both safety injection (SI) pump flow paths may be isolated by closing the isolation valves for up to 2 hours to perform pressure isolation valve testing per SR 3.4.14.1.

APPLICABILITY: MODES 1, 2, and 3.

ACTIONS

| CONDITION | REQUIRED ACTION | COMPLETION TIME |
|--|---------------------------------------|-----------------|
| A. One ECCS train inoperable. | A.1 Restore train to OPERABLE status. | 72 hours |
| B. Required Action and associated Completion Time not met. | B.1 Be in MODE 3. | 6 hours |
| | <u>AND</u> B.2 Be in MODE 4. | 12 hours |

SURVEILLANCE REQUIREMENTS

| SURVEILLANCE | FREQUENCY |
|---|-----------|
| SR 3.5.2.1 Verify each ECCS manual, power operated, and automatic valve in the flow path, that is not locked, sealed, or otherwise secured in position, is in the correct position. | 31 days |
| SR 3.5.2.2 Verify ECCS piping is full of water. | 31 days |

(continued)

SURVEILLANCE REQUIREMENTS (continued)

| SURVEILLANCE | | FREQUENCY |
|---------------------|--|--|
| SR 3.5.2.3 | Verify each ECCS pump's developed head at the test flow point is greater than or equal to the required developed head. | In accordance with the Inservice Testing Program |
| SR 3.5.2.4 | Verify each ECCS automatic valve in the flow path that is not locked, sealed, or otherwise secured in position, actuates to the correct position on an actual or simulated actuation signal. | 18 months |
| SR 3.5.2.5 | Verify each ECCS pump starts automatically on an actual or simulated actuation signal. | 18 months |
| SR 3.5.2.6 | Verify, by visual inspection, each ECCS train containment sump suction inlet is not restricted by debris and the suction inlet debris screens show no evidence of structural distress or abnormal corrosion. | 18 months |

SURVEILLANCE REQUIREMENTS

| SURVEILLANCE | | FREQUENCY |
|--------------|--|-----------------------------------|
| SR 3.5.3.1 | The following SRs are applicable for all equipment required to be OPERABLE: <div> <div>SR 3.5.2.1</div> <div>SR 3.5.2.2</div> <div>SR 3.5.2.3</div> </div> <div> <div>SR 3.5.2.4</div> <div>SR 3.5.2.5</div> <div>SR 3.5.2.6</div> </div> | In accordance with applicable SRs |