

From: Mahesh Chawla
To: Joseph.bauer@exeloncorp.com
Date: 10/2/03 2:03PM
Subject: Request for a License Amendment to Revise the PSV Lift Settings - Byron/Braidwood Units 1 and 2

With reference to your above referenced request, the NRC staff has following questions which they would like to discuss with Exelon. Please let me know your availability to have this conference call. If you have any questions, please call me at (301) 415-8371.

1. In support of the technical specification (TS) changes, reanalyses were performed for several cases to determine the DNBRs and pressurizer water levels. Discuss the methods and computers codes used in the reanalyses for each case and address acceptability of the use of the methods and computers for licensing applications. Also, identify for the reanalyzed events the values of input parameters that are different from that assumed in the analysis of record.
2. The use of PSV setpoints with inclusion of negative tolerances lowers effective PSV opening pressures, which would cause an earlier opening of the PSVs and a lower increase in the RCS pressure during overpressurization events. Lower RCS pressures result in lower departure from nucleate boiling ratios (DNBRs). As documented in the FSAR, the loss of reactor coolant and reactor coolant pump locked rotor are limiting DNBR cases. Discuss for both events whether the calculated DNBRs in the FSAR would be affected by a lower PSV opening pressure or not.
3. The information discussed on pages 11 and 12 of Reference 1 for a qualitative evaluation indicated that the spurious SI event would have similar results from the LOAC with the RCP seal injection event in terms of the change in the number of PSV water cycles and PSV discharge water temperature. The information is not sufficient for the staff to determine the accuracy of the results of the qualitative evaluation. Perform a quantitative analysis using the approved methods and provide the results to show the accuracy of the qualitative evaluation results.
4. Specify the pressure measurement uncertainties associated with the high pressure reactor trip and the PSV, and confirm that they are appropriately considered in the error analysis such that a reactor trip will occur prior to PSV actuation.
5. The information discussed on page 10 of Reference 1 for a loss of power to plant auxiliaries with RCP seal injection references an assessment by the Westinghouse Systems and Equipment Engineering Group that concluded that the PSVs will remain operable following a LOAC event with water relief through the PSVs. Please provide a copy of the Westinghouse assessment for review.

Reference 1: Attachment 1 to a letter from K. Ainger (EGC) to NRC, "Request for a License Amendment to Revise the Pressurizer Safety Valves Lift Settings,' dated June 27, 2003.

CC: Kerri Kavanagh; Summer Sun; William Poertner

Mail Envelope Properties

(3F7C6880.AF3 : 15 : 21352)

Subject: Request for a License Amendment to Revise the PSV Lift Settings - Byron/Braidwood Units 1 and 2

Creation Date: 10/2/03 2:03PM

From: Mahesh Chawla

Created By: MLC@nrc.gov

Recipients	Action	Date & Time
owf2_po.OWFN_DO KAK CC (Kerri Kavanagh) SBS CC (Summer Sun) WKP CC (William Poertner)	Delivered	10/02/03 02:03PM

exeloncorp.com Joseph.bauer (Joseph.bauer@exeloncorp.com)	Transferred	10/02/03 02:03PM
--------------------------------------------------------------	-------------	------------------

Post Office	Delivered	Route
owf2_po.OWFN_DO	10/02/03 02:03PM	exeloncorp.com

Files	Size	Date & Time
MESSAGE	3563	10/02/03 02:03PM

Options

Auto Delete:	No
Expiration Date:	None
Notify Recipients:	Yes
Priority:	Standard
Reply Requested:	No
Return Notification:	None

Concealed Subject:	No
Security:	Standard

To Be Delivered:	Immediate
Status Tracking:	Delivered & Opened