

3/4.9.3 DECAY TIME

LIMITING CONDITION FOR OPERATION

---

3.9.3 The reactor shall be subcritical for at least 80 hours. |

APPLICABILITY: During movement of irradiated fuel in the reactor vessel.

ACTION:

With the reactor subcritical for less than 80 hours, suspend all operations involving movement of irradiated fuel in the reactor vessel. |

SURVEILLANCE REQUIREMENTS

---

4.9.3 The reactor shall be determined to have been subcritical for at least 80 hours by verification of the date and time of subcriticality prior to movement of irradiated fuel in the reactor vessel. |