Document Transmittal Form

TO : NRC C/O PINCKNEY, DAVID DOCUMENT CONTROL DESK WASHINGTON, DC 20555

ID: SECG0101

Date: 10/8/03

Please update your controlled set of documents with the following documents:

Document ID	Revision	Status	Quantity	Format	RecNo
PRC SECG-SECG-TOC-BASIS 000	18	Α	1	н	177791
PRC SECG-SECT.06.4 (BASIS) 000	1	Α	1	н	177829

ALL PAGES of this acknowledgement receipt must be returned to:

Document Management PSEG Nuclear PO Box 236 Hancocks Bridge, NJ 08038

MC N04

Your signature below verifies that:

(1) the above documents have been filed and superseded documents have been removed and destroyed or clearly marked as obsolete.

(2) the mailing address and copyholder information are correct or corrections have been identified on this transmittal.

Place checkmark here to be removed from controlled distribution

Signature:

Date:

AD45

SALEM GENERATING STATION EVENT CLASSIFICATION GUIDE TECHNICAL BASIS -October 08, 2003

CHANGE PAGES FOR REVISION #18

The Table of Contents forms a general guide to the current revision of each section and attachment of the Salem ECG Technical Basis. The changes that are made in this TOC Revision #18 are shown below.

- 1. Check that your revision packet is complete.
- 2. Add the revised documents.

3. Remove and recycle the outdated material listed below.

ADD

REMOVE

Pages	Description	<u>Rev.</u>	<u>Pages</u>	Description	<u>Rev.</u>
All	TOC	18	All	TOC	17
All	Section 6.4	01	All	Section 6.4	00

PSEG Internal Use Only

SALEM ECG TECHNICAL BASIS TABLE OF CONTENTS/SIGNATURE PAGE

SECTION	•	TITLE	<u>REV #</u>	PAGES	DATE
T.O.C.	Tab	e of Contents/Signature Page	18	4	10/08/03
i	Intro	oduction and Usage	00	3	01/21/97
ii	Glos	sary of Acronyms & Abbreviations	00	6	01/21/97
1.0	Fuel	Clad Challenge	01	4	12/29/99
2.0	RCS	Challenge	01	2	07/24/00
3.0	Fissi	on Product Barriers (Table)			
	3.1	Fuel Clad Barrier	02	20	02/27/03
	3.2	RCS Barrier	02	16	01/16/01
	3.3	Containment Barrier	05	26	01/31/03
4.0	ECI	Discretion	00	8	01/21/97
5.0	Faih	ure to Trip	03	9	12/18/01
6.0	Rad	iological Releases/Occurrences			
	6.1	Gaseous Effluent Release	00	42	01/21/97
	6.2	Liquid Effluent Release	00	4	01/21/97
	6.3	In - Plant Radiation Occurrences	00	6	01/21/97
	6.4	Irradiated Fuel Event	01	10	10/08/03
7.0	Elec	trical Power			
	7.1	Loss of AC Power Capabilities	02	11	01/16/01
	7.2	Loss of DC Power Capabilities	00	8	01/21/97
8.0	Syst	em Malfunctions			
	8.1	Loss of Heat Removal Capability	01	10	12/29/99
	8.2	Loss of Overhead Annunciators	02	6	07/24/00
	8.3	Loss of Communications Capability	00	4	01/21/97
	8.4	Control Room Evacuation	01	4	12/18/01
	8.5	Technical Specifications	00	2	01/21/97
9.0	Haza	ards - Internal/External			
	9.1	Security Threats	02	9	02/01/02
	9.2	Fire	02	6	01/16/01
	9.3	Explosion	02	5	01/16/01
	9.4	Toxic/Flammable Gases	03	12	09/26/02
	9.5	Seismic Event	02	4	09/26/02
	9.6	High Winds	01	5	01/16/01
	9.7	Flooding	02	5	01/16/01
	9.8	Turbine Failure/Vehicle Crash/Missile Impact	02	7	01/16/01
	9.9	River Level	01	4	01/16/01



Rev. 18

PSEG Internal	Use	Only
----------------------	-----	------

SALEM ECG TECHNICAL BASIS TABLE OF CONTENTS/SIGNATURE PAGE

SECTION		TITLE	<u>REV #</u>	PAGES	DATE
10.0	Reserve	ed for future use			
	Licensing	is responsible for the Reportable Action Le	evel (Section 1	11)	
11.0	Reports	able Action Levels (RALs)			
	11.1	Technical Specifications	01	9	01/23/01
	11.2	Degraded or Unanalyzed Condition	02	4	01/23/01
	11.3	System Actuation	04	7	04/19/02
	11.4	Personnel Safety/Overexposure	01	7	01/23/01
	11.5	Environmental/State Notifications	02	4	10/01/03
	11.6	After-the-Fact	02	1	02/28/02
	11.7	Security/Emergency Response	03	5	02/28/02
		Capabilities			
	11.8	Public Interest	01	3	01/23/01
\smile	11.9	Accidental Criticality/	02	8	01/23/01
		Special Nuclear Material /			
		Rad Material Shipments - Releases			
	11.10	Voluntary Notifications	01	2	01/23/01

PSEG Internal Use Only

SGS EAL Technical Basis T.O.C. Pg. 3 of 4

REVISION SUMMARY

Biennial Review Performed: Yes _____ No _X___

Updated EAL Basis for 6.4.2.a and 6.4.2.b to correct reference to EALs for other conditions.

PSEG Internal Use Only		SGS EAL Technical	
SIGNATURE PAGE		- 5.	
Prepared By:	Craig Banner	<u>09/17/03</u> Date	
Section/Attachments Rev	rised: <u>N/A</u>	<u> </u>	
	(List Non Editorial Only - Section/Attachments)) Date	
Reviewed By:	N/A 10CEP50 54a Effectiveness Reviewer	N/A Date	
	IUCFKJU.J44 Ellectiveness Keviewei	Date	
Reviewed By:	N/A	N/A	
•	Department Manager	Date	
Reviewed By:	N/A	<u>N/A</u>	
Reviewed By:(Dal A By EP Manager	<u>9/22/03</u> Date	
Reviewed By:	NA	N/A	
	Manager - Quality Assurance (If Applicable)	Date	
	SORC Review and Station Approvals		
NA			
Mitg. No. Salem Cha	airman Vice President - Nuclear	Operations	
-	N/A Date	N/A	
Effective Date of this Rev	vision: <u>10/01/03 /0/</u> 8/03 Date	Date	
		<i>A. 11</i>	

Rev. 17 18

SGS

SGS EAL/RALTechnical Basis

6.0 Radiological Releases/Occurrences

6.4 Irradiated Fuel Event

UNUSUAL EVENT - 6.4.1.a

IC Unplanned increase in Plant Radiation

EAL

An uncontrolled level drop in the Refueling Cavity as indicated by <u>EITHER</u> one of the following:

- Visual observation
- RVLIS Refueling Mode

MODE - 6

BASIS

This EAL condition indicates a possible failure of the Refueling Cavity Seal or RHR System that results in inventory loss from the Refueling Cavity when flooded. Coverage of these events is appropriate due to the potential for higher doses to plant staff. These events have a long lead time relative to potential for radiological release outside the site boundary, thus the impact to public health and safety is very low. Classification as an Unusual Event is warranted as a precursor to a more serious event. Uncontrolled means that the level drop cannot be terminated, or level cannot be maintained by operator action.

Barrier Analysis

N/A

ESCALATION CRITERIA

This event will be escalated to an Alert as a result of uncovery of a fuel assembly and/or indication of high radiation levels on the refueling floor.

DISCUSSION

Design of the Refueling Cavity is such that a liner failure in these volumes is unlikely; however, should such a failure occur, it would come under this EAL. If uncovery of fuel elements occur or

EAL - 6.4.1.a Rev. 01



SGS EAL/RALTechnical Basis

if there is indication of high radiation levels on the refuel floor then the event will be classified as an Alert.

During refueling operations the Reactor Vessel and Refuel Cavity are flooded. During fuel handling operations, the Fuel Transfer Tube will connect the Reactor Cavity and the Spent Fuel Pool. An unexplained lowering of Refuel Cavity level or Spent Fuel Pool level can be an indication that these volumes are draining. A drop in Reactor Cavity and Spent Fuel Pool level may result in a Spent Fuel Pool low level alarm. This alarm would be validated by visual observation of lowering level in the Refuel Cavity/Spent Fuel Pool.

DEVIATION

NUMARC states that this EAL will be applicable in all modes of operation. In modes other than Mode 6 the Reactor Vessel head will be fully tensioned and there will be no interconnection between the Refueling Cavity and the Spent Fuel Pool. In other modes, a loss of Reactor Vessel inventory is addressed in Section 3. Uncontrolled loss of water level in the Spent Fuel Pool, however, is classified under EAL 6.4.1.b in all modes of operation.

REFERENCES

NUMARC NESP-007, AU2.1 OP-AR.ZZ-0003(Q) OHA-C35 OP-AB.FUEL-0002(Q)

6.4 Irradiated Fuel Event

UNUSUAL EVENT - 6.4.1.b

IC Unplanned increase in Plant Radiation

EAL

Valid SFP Low Level alarm - OHA C-35

AND

Visual observation of an uncontrolled level drop in the Spent Fuel Pool

MODE - All

BASIS

These EAL conditions indicate a possible failure of the Spent Fuel Pool Cooling System that results in inventory loss from the Spent Fuel Pool. This EAL also works in conjunction with the loss of Refueling Cavity EAL for Mode 6 operations, with the Spent Fuel Pool and Refueling Cavity connected via the Fuel Transfer Canal.

Coverage of this event is appropriate due to the potential for higher doses to plant staff. This event has a long lead time relative to potential for radiological release outside the site boundary, thus the impact to public health and safety is very low. Classification as an Unusual Event is warranted as a precursor to a more serious event. Uncontrolled means that the level drop <u>cannot</u> be terminated, or level <u>cannot</u> be maintained by operator action.

Barrier Analysis

N/A

ESCALATION CRITERIA

Emergency Classification will escalate to an Alert as a result of uncovery of a irradiated fuel as indicated by high radiation levels in the Fuel Handling Building.

EAL - 6.4.1.b Rev. 01

DISCUSSION

Design of the Spent Fuel Pool (SFP) is such that a liner failure in this volume is unlikely; however, should such a failure occur, it would be classified under this EAL. Lowering of water level in the SFP to below the level of the spent fuel bundles may result in a rise in the airborne contamination level in the Fuel Handling Building. If uncovery of fuel elements occurs or if there is indication of high radiation levels in the Fuel Handling Building, then the event will be classified as an Alert.

This alarm would be validated by visual observation of lowering level in the Spent Fuel Pool. The added requirement for an uncontrolled drop in SFP level with a low level alarm is included to allow normal makeup to recover level for minor level deviations due to evaporation losses, etc.

DEVIATION

None

REFERENCES

NUMARC NESP-007, AU2.2 OP-AR.ZZ-0003(Q) OHA-C35 OP-AB.FUEL-0002(Q)

6.4 Irradiated Fuel Event

ALERT - 6.4.2.a

IC Major Damage to Irradiated Fuel or Loss of Water Level that has or will result in the Uncovering of Irradiated Fuel Outside the Reactor Vessel

EAL

Major Damage to Irradiated Fuel reported in the Fuel Handling Bldg.

<u>AND</u>

Valid High Alarm is received on EITHER one of the following RMS channels:

- R5
- R32A

AND

Valid High Alarm received from EITHER one of the following RMS channels:

- R41
- R45

MODE - All

BASIS

Major Damage to an irradiated fuel bundle that results in a High Fuel Handling Building Radiation Monitor alarm coincident with a Plant Vent Effluent Process Radiation Monitor alarm warrants declaration of an Alert, due to the potential for an offsite release exceeding the Technical Specification limit. The intent of this EAL is to classify those events that result in the actual release of fission products from an irradiated Fuel Bundle, due to physical damage. Events that result in higher radiation levels due to shine, as a result of lowered shielding, but do <u>not</u> involve a release of fission products should <u>not</u> be classified under this EAL, but should be classified EAL 6.4.2.c, when those conditions exist.

Major Damage is defined as physical damage to an Irradiated Fuel Bundle that results from either dropping or physical contact with other components, such that the magnitude of the

damage <u>specifically</u> results in actuation of an Area Radiation Alarm. Valid is defined as the High alarm occurring as a result of the damage to the irradiated fuel bundle.

Barrier Analysis

N/A

ESCALATION CRITERIA

Emergency Classification will escalate to a Site Area Emergency when loss of control of radioactive materials causes significant offsite doses.

DISCUSSION

The Fuel Handling Building Area Monitors provide an early warning of developing problems which may be related to a damaged fuel bundle. The Plant Vent Exhaust Rad Monitors are Process Monitors and are designed to detect a release of Fission Products. Hence, they are included as part of the EAL threshold, to confirm the magnitude of damage to an irradiated fuel bundle.

DEVIATION

None

REFERENCES

NUMARC NESP-007, AA2.1 OP-AR.ZZ-0003(Q) OHA-C35 OP-AB.FUEL-0002(Q) NUREG/CR-4982 NRC Information Notice no. 90-08 10CFR50

> EAL - 6.4.2.a Rev. 01

6.4 Irradiated Fuel Event

ALERT - 6.4.2.b

IC Major Damage to Irradiated Fuel or Loss of Water Level that has or will result in the Uncovering of Irradiated Fuel Outside the Reactor Vessel

EAL

Major Damage to Irradiated Fuel reported in the Containment

AND

Valid High Alarm received on <u>ANY</u> one of the following RMS channels:

- R2
- R10A
- R10B

AND

Valid High Alarm received from <u>ANY</u> one of the following RMS channels:

- R11A
- R12A
- R12B

MODE - All

BASIS

Major Damage to an irradiated fuel bundle that result in a High Containment Area Radiation Monitor alarm coincident with a Containment Process Radiation Monitors alarm warrants declaration of an Alert, due to the potential for an offsite release exceeding the Technical Specification limit. The intent of this EAL is to classify those events that result in the potential release of fission products from an irradiated Fuel Bundle, due to physical damage. Events that result in higher radiation levels due to shine, as a result of lowered shielding, but do <u>not</u> involve a release of fission products should <u>not</u> be classified under this EAL, but should be classified EAL 6.4.2.c, when those conditions exist. **Major Damage** is defined as physical damage to an Irradiated Fuel Bundle that results from either dropping or physical contact with other components, such that the magnitude of the damage <u>specifically</u> results in actuation of an Area Radiation Alarm. Valid is defined as the High alarm occurring as a result of the damage to the irradiated fuel bundle.

Barrier Analysis

N/A

ESCALATION CRITERIA

Emergency Classification will escalate to a Site Area Emergency when loss of control of radioactive materials causes significant offsite doses.

DISCUSSION

The Containment Area Monitors provide an early warning of developing problems which may be related to a damaged fuel bundle. The Containment Rad Monitors are Process Monitors and are designed to detect a release of Fission Products. Hence, they are included as part of the EAL threshold, to confirm the magnitude of damage to an irradiated fuel bundle.

DEVIATION

None

REFERENCES

NUMARC NESP-007, AA2.1 OP-AR.ZZ-0003(Q) OHA-C35 OP-AB.FUEL-0002(Q) NUREG/CR-4982 NRC Information Notice no. 90-08 EPA 400-R-92-001, Manual of Protective Action Guide and Protective Actions for Nuclear Incidents

6.4 Irradiated Fuel Event

ALERT - 6.4.2.c/6.4.2.d

IC Major Damage to Irradiated Fuel or Loss of Water Level that has or will result in the Uncovering of Irradiated Fuel Outside the Reactor Vessel

EAL

EITHER one of the following:

• Unplanned rise on <u>ANY</u> one of the following Area Rad Monitors or by general area rad survey indicates \geq 2000 mRem/hr

- R2
- R5
- R9
- R32A

• Visual observation of Irradiated Fuel uncovered

MODE - All

BASIS

This EAL indicates a possible failure of the Refueling Cavity Seal, RHR System, or Spent Fuel Pool Cooling System that results in inventory loss from the Refueling Cavity when flooded or the Spent Fuel Pool. Design of the Refueling Cavity and Spent Fuel Pool is such that a liner failure in these volumes is unlikely; however, should such a failure occur, it would come under this EAL. Lowering of water level in the Spent Fuel Pool to such a value as to cause Dose Rates to increase to this value will result in evacuation of the local areas. Uncovery of irradiated fuel elements can lead to their fuel clad failure due to loss of cooling.

The term "unplanned" is defined as those events which are not associated with a pre-planned evolutions such that radiation levels are increasing for reasons which cannot be immediately explained. The EAL addresses radiation levels which would impede operation of systems required to continue efforts to stop the loss of Refueling water level. Radiation levels could be indicated by ARM or radiological survey. The Dose Rate of 2000 mRem/hr was chosen as a threshold based upon NAP-24 Administrative Dose Limits and Extension criteria which has Senior Radiation Protection Supervisor approval required prior to exceeding 2000 mRem/yr.

EAL - 6.4.2.c/ 6.4.2.d Rev. 01 This value is low enough to ensure classification of an Alert before personnel access is severely hampered and high enough to allow any unplanned rise in normal radiation level, by a factor of 1000, to be classified as an Unusual Event per EAL 6.3.1.

Visual observation of irradiated fuel uncovered will result in onsite dose levels changing significantly.

The Area Radiation Monitors included in this EAL are:

- R2 Containment, General Area Low
- R5 Fuel Handling Building Area Fuel Pool
- R9 Fuel Handling Building Fuel Storage Area
- R32A Spent Fuel Handling Crane, Area Monitor

Barrier Analysis

N/A

ESCALATION CRITERIA

This event will be escalated to a Site Area Emergency when loss of control of radioactive materials causes significant offsite doses.

DISCUSSION

It is understood that a drop in Refueling Cavity water level will cause Dose Rates to rise due to the uncovery of irradiated Reactor components other than a spent fuel assembly. However, Dose Rates in excess of 2 Rem/hr indicate a loss of level such that recovery options may be limited and thus an Alert declaration is warranted.

DEVIATION

None

REFERENCES

NUMARC NESP-007, AA2.3 and AA2.4 OP-AR.ZZ-0003(Q) OHA-C35 OP-AB.FUEL-0002(Q) NUREG/CR-4982 NRC Information Notice no. 90-08