



8 7 6 5 4 3 2 1

H

G

F

E

D

C

B

A

- NOTES:**
1. THE EMERGENCY DIESEL GENERATOR FUEL OIL TANKS AREA FIRE PROTECTION SYSTEM (DELIUGE SYSTEM) HAS BEEN PURCHASED UNDER FSC-2028, UNIT 2 ELECTRICAL GROUP TO PROVIDE WIRING FOR CONTROLS.
 2. SEE M-219, SH-4 FOR TYPICAL TRIM DETAILS FOR UNIT 1 AND M-229, SH-4 FOR UNIT 2 TYPICAL TRIM DETAILS.
 3. SH-7 IS CONNECTED TO THE CITY DOMESTIC WATER SUPPLY AND IS NOT INSTALLED ON THE AND FIREWATER SYSTEM. SH-7 IS LOCATED BESIDE THE INCENDIAR BULPING NORTH OF THE MAINTENANCE FACILITY.
 4. PS-149 WAS INSTALLED FOR FUTURE EXPANSION TO THE FIREWATER SYSTEM IN THE SWITCH YARD.
 5. VALVES THAT ARE IN PHANTOM ARE LOCATED ON M-219 FIRE WATER P&ID. THE VALVES ARE SHOWN ON THIS DRAWING FOR REFERENCE ONLY.
 6. SEE YELLOW Dwg. M-1124 FOR LOADING DOCK SPRINKLER DETAIL VALVES.
 7. DELETED.
 8. DELETED.
 9. VALVES PS-67 AND PS-77 WERE ABANDONED IN PLACE BY OCP 89-2825-A.

LEGEND	
—	SYSTEM/AMR REPORT
—	WATER SUPPRESSION FIRE PROTECTION/82-R-2005-08
—	LICENSE RENEWAL BOUNDARY
ARKANSAS NUCLEAR ONE UNIT 2 RUSSELLVILLE, ARKANSAS	
PIPING & INSTRUMENT DIAGRAM UNIT ONE / UNIT TWO OUTSIDE FIRE WATER LOOP	
DRAWING NO	SHEET REVISION
LRA-M-2219	5 0

D-30