



- NOTES:
1. THE FOLLOWING IDCS ARE OUTSTANDING AND NOT INCORPORATED IN REVISION 21 IDCN # 3217 DCP # 683 IDCN # 3888 DCP # 812.
 2. THE CIS "CLOSE" SIGNAL CAN BE OVERRIDDEN WITH THIS HANDSWITCH, WHEN REQUIRED, TO REESTABLISH CFW TO THE RCP'S.
 3. TEMPORARY START-UP STRAINERS ARE REMOVED DURING NORMAL OPERATION.
 4. ONLY ONE OF TWO COOLERS REQUIRED DURING NORMAL OPERATION. 2E22B IS SHOWN IN SERVICE WITH 2E22A IN STAND-BY.

LEGEND		
—	SYSTEMS/AMR REPORT	
—	CONTAINMENT PENETRATIONS/82-R-2085-B6	
—	LICENSE RENEWAL BOUNDARY	

**ARKANSAS NUCLEAR ONE
UNIT 2
RUSSELLVILLE, ARKANSAS**

**PIPING & INSTRUMENT DIAGRAM
COMPONENT COOLING WATER SYSTEM**

DRAWING NO	SHEET	REVISION
LRA-M-2234	1	0

Entergy