Tennessee Valley Authority, Post Office Box 2000, Spring City, Tennessee 37381-2000

OCT 1 3 2003

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D. C. 20555

Gentlemen:

In the Matter of) Docket No.50-390
Tennessee Valley Authority)

WATTS BAR NUCLEAR PLANT (WBN) UNIT 1 - STEAM GENERATOR (SG) TUBE INSPECTION - 15 DAY REPORT

This letter fulfills the reporting requirements contained in Technical Specification (TS) 5.9.9, "SG Tube Inspection Report." In accordance with TS 5.9.9, listed below are the number of steam generator tubes that were plugged or sleeved during the WBN Unit 1 Cycle 5 refueling outage:

Results of WBN Inservice Inspections		
	Number of Tubes	
SG Number	Plugged	Sleeved
1	122	0
2	82	0
3	43	0
4	53	148
Totals	300	148

A047

Printed on recycled paper

There are no regulatory commitments identified in this report. If you have any questions concerning this report, please contact me at (423) 365-1824.

Sincerely,

P. L. Pace
Manager, Site Licensing
and Industry Affairs

cc: NRC Resident Inspector
Watts Bar Nuclear Plant
1260 Nuclear Plant Road
Spring City, Tennessee 37381

Ms. Margaret H. Chernoff, Project Manager
U.S. Nuclear Regulatory Commission
MS 08G9
One White Flint North
11555 Rockville Pike
Rockville, Maryland 20852-2738

U.S. Nuclear Regulatory Commission
Region II
Sam Nunn Atlanta Federal Center
61 Forsyth St., SW, Suite 23T85
Atlanta, Georgia 30303