



Tennessee Valley Authority, Post Office Box 2000, Spring City, Tennessee 37381-2000

OCT 13 2003

U.S. Nuclear Regulatory Commission  
ATTN: Document Control Desk  
Washington, D. C. 20555

Gentlemen:

In the Matter of ) Docket No.50-390  
Tennessee Valley Authority )

WATTS BAR NUCLEAR PLANT (WBN) UNIT 1 - STEAM GENERATOR (SG) TUBE  
INSPECTION - 15 DAY REPORT

This letter fulfills the reporting requirements contained in  
Technical Specification (TS) 5.9.9, "SG Tube Inspection Report."  
In accordance with TS 5.9.9, listed below are the number of steam  
generator tubes that were plugged or sleeved during the WBN Unit  
1 Cycle 5 refueling outage:

Results of WBN Inservice Inspections		
	Number of Tubes	
SG Number	Plugged	Sleeved
1	122	0
2	82	0
3	43	0
4	53	148
<b>Totals</b>	<b>300</b>	<b>148</b>

A047

U.S. Nuclear Regulatory Commission

Page 2

OCT 13 2003

There are no regulatory commitments identified in this report.  
If you have any questions concerning this report, please contact  
me at (423) 365-1824.

Sincerely,



P. L. Pace  
Manager, Site Licensing  
and Industry Affairs

cc: NRC Resident Inspector  
Watts Bar Nuclear Plant  
1260 Nuclear Plant Road  
Spring City, Tennessee 37381

Ms. Margaret H. Chernoff, Project Manager  
U.S. Nuclear Regulatory Commission  
MS 08G9  
One White Flint North  
11555 Rockville Pike  
Rockville, Maryland 20852-2738

U.S. Nuclear Regulatory Commission  
Region II  
Sam Nunn Atlanta Federal Center  
61 Forsyth St., SW, Suite 23T85  
Atlanta, Georgia 30303