

October 21, 2003

LICENSEE: Pacific Gas and Electric Company

FACILITY: Diablo Canyon Nuclear Power Plant, Units 1 and 2

SUBJECT: SUMMARY OF MEETING HELD ON OCTOBER 7, 2003, TO DISCUSS STEAM GENERATOR ISSUES

On October 7, 2003, representatives of Pacific Gas and Electric Company (PG&E) met with the NRC staff to make a presentation on steam generator (SG) issues for Diablo Canyon Nuclear Power Plant, Units 1 and 2.

The meeting began with PG&E's discussion of the license amendment request (LAR) currently being reviewed by the NRC staff for the use of the probability of prior cycle detection (POPCD) method for Unit 2 Cycle 12 operational assessment. The meeting continued with a presentation on the use of a permanent POPCD for future cycles, PG&E's strategy for SG operation until replacement, and planned chemical cleaning of the SGs. PG&E further discussed the wedge region alternate repair criteria exclusion zone reduction, increase of main steam line break (MSLB) leak rate limit, Alloy 800 sleeving and related future LAR, increase of 15 percent plugging limit, and locking of the tube support plate (TSP) to prevent TSP displacement and potential for tube burst under postulated MSLB conditions.

PG&E provided responses to the verbal questions from the NRC staff and discussed tentative schedules for submittal of the future LARs on the subjects discussed in the meeting.

An attendance list is provided in the attachment. The presentation slides used during the meeting are available in ADAMS under Accession No. ML032820023.

/RA/

Girija S. Shukla, Project Manager, Section 2
Project Directorate IV
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket Nos. 50-275
and 50-323

Attachment: Attendance List

cc w/att: See next page

October 21, 2003

LICENSEE: Pacific Gas and Electric Company

FACILITY: Diablo Canyon Nuclear Power Plant, Units 1 and 2

SUBJECT: SUMMARY OF MEETING HELD ON OCTOBER 7, 2003, TO DISCUSS STEAM GENERATOR ISSUES

On October 7, 2003, representatives of Pacific Gas and Electric Company (PG&E) met with the NRC staff to make a presentation on steam generator (SG) issues for Diablo Canyon Nuclear Power Plant, Units 1 and 2.

The meeting began with PG&E's discussion of the license amendment request (LAR) currently being reviewed by the NRC staff for the use of the probability of prior cycle detection (POPCD) method for Unit 2 Cycle 12 operational assessment. The meeting continued with a presentation on the use of a permanent POPCD for future cycles, PG&E's strategy for SG operation until replacement, and planned chemical cleaning of the SGs. PG&E further discussed the wedge region alternate repair criteria exclusion zone reduction, increase of main steam line break (MSLB) leak rate limit, Alloy 800 sleeving and related future LAR, increase of 15 percent plugging limit, and locking of the tube support plate (TSP) to prevent TSP displacement and potential for tube burst under postulated MSLB conditions.

PG&E provided responses to the verbal questions from the NRC staff and discussed tentative schedules for submittal of the future LARs on the subjects discussed in the meeting.

An attendance list is provided in the attachment. The presentation slides used during the meeting are available in ADAMS under Accession No. ML032820023.

/RA/

Girija S. Shukla, Project Manager, Section 2
Project Directorate IV
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket Nos. 50-275
and 50-323

Attachment: Attendance List

cc w/att: See next page

DISTRIBUTION:

PUBLIC

RidsNrrDlpm (LMarsh/ELeeds)
RidsNrrPMGShukla
RidsOgcMailCenter
TMensha (NRR/PMAS)
KKarwoski (NRR/DE/EMCB)
SLong (NRR/DSSA/SPSB)

PDIV-2 Reading
RidsNrrDlpmLpdiv (HBerkow)
RidsNrrLAEPeyton
RidsAcrcAcnwMailCenter
LLund (NRR/DE/EMCB)
WSifre (Region 4)

TChan (NRR/DE/EMCB)
JWu (NRR/DE/EMEB)
CKhan (NRR/DE/EMCB)
KManoli (NRR/DE/EMEB)

Package No.: ML032950074

Meeting Notice: ML032680967

ADAMS Accession No.: ML032940689

NRC-001

OFFICE	PDIV-2/PM	PDIV-2/LA	PDIV-2/SC
NAME	GShukla:sab	EPeyton	SDembek
DATE	10/20/03	10/17/03	10/21/03

OFFICIAL RECORD COPY

DOCUMENT NAME: C:\ORPCheckout\FileNET\ML032940689.wpd

MEETING ATTENDEES

MEETING WITH PACIFIC GAS AND ELECTRIC COMPANY TO DISCUSS STEAM GENERATOR ISSUES FOR DIABLO CANYON

OCTOBER 7, 2003

PACIFIC GAS & ELECTRIC

S. Ketelsen
J. Arhar
T. Baldwin
D. Beals

WESTINGHOUSE

T. Pitterle
B. Keating
R. Smith
M. Hu

FRAMATOME

J. Fleck

NRC

S. Dembek
G. Shukla
L. Lund
C. Khan
K. Karwoski
S. Long
K. Manoli
J. Wu
T. Chan

Diablo Canyon Power Plant, Units 1 and 2

cc:

NRC Resident Inspector
Diablo Canyon Power Plant
c/o U.S. Nuclear Regulatory Commission
P.O. Box 369
Avila Beach, CA 93424

Mr. Pete Wagner
Sierra Club California
2650 Maple Avenue
Morro Bay, California 93442

Ms. Nancy Culver
San Luis Obispo
Mothers for Peace
P.O. Box 164
Pismo Beach, CA 93448

Chairman
San Luis Obispo County Board of
Supervisors
Room 370
County Government Center
San Luis Obispo, CA 93408

Mr. Truman Burns
Mr. Robert Kinoshian
California Public Utilities Commission
505 Van Ness, Room 4102
San Francisco, CA 94102

Diablo Canyon Independent Safety
Committee
ATTN: Robert R. Wellington, Esq.
Legal Counsel
857 Cass Street, Suite D
Monterey, CA 93940

Regional Administrator, Region IV
U.S. Nuclear Regulatory Commission
Harris Tower & Pavillion
611 Ryan Plaza Drive, Suite 400
Arlington, TX 76011-8064

Richard F. Locke, Esq.
Pacific Gas & Electric Company
P.O. Box 7442
San Francisco, CA 94120

Mr. David H. Oatley, Vice President
and General Manager
Diablo Canyon Power Plant
P.O. Box 56
Avila Beach, CA 93424

City Editor
The Tribune
3825 South Higuera Street
P.O. Box 112
San Luis Obispo, CA 93406-0112

Mr. Ed Bailey, Radiation Program Director
Radiologic Health Branch
State Department of Health Services
P.O. Box 942732 (MS 178)
Sacramento, CA 94234-7320

Mr. James D. Boyd, Commissioner
California Energy Commission
1516 Ninth Street (MS 31)
Sacramento, CA 95814

Mr. James R. Becker, Vice President
Diablo Canyon Operations
and Station Director
Diablo Canyon Power Plant
P.O. Box 3
Avila Beach, CA 93424

Mr. Gregory M. Rueger
Senior Vice President, Generation and
Chief Nuclear Officer
Pacific Gas and Electric Company
Diablo Canyon Power Plant
P.O. Box 3
Avila Beach, CA 93424